



OLIN 3001

EPA Est. No.
33576-CA-1
33576-KS-1
33576-NY-1

Aug 7 1975
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
OR ECONOMIC POISON REGISTERED
UNDER NO.

Chemical formulation for industrial cooling water treatment

DIRECTIONS FOR USE IN INDUSTRIAL RECIRCULATING COOLING WATER TOWERS.

Begin treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired. Badly fouled systems must be cleaned before treatment is begun.

To control fungal slimes add OLIN 3001 at the rate of 1¾ qts. to 4 gals. per 1,000 gals. of water (Approx. 60 to 600 ppm available chlorine) directly to the cooling tower drip pan near the inlet to the recirculating pump. Apply as frequently as necessary to maintain control. Control may also be obtained by adding to the drip pan sufficient OLIN 3001 to maintain 1.0 ppm residual chlorine for 4 hours. Approx. 1 fl. oz. of OLIN 3001 will provide approx. 1.0 ppm available chlorine. Check available chlorine with a test kit and if below 1.0 ppm repeat dosage until this value is obtained and hold this value for 4 hours. Apply this method of control as frequently as necessary to maintain control.

OLIN 3001 is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Apply this product only as specified on this label.

EPA REG. NO. 33576-5-AA-50607

WARNING

Keep Out of Reach of Children

Harmful if swallowed. Skin and eye contact may cause severe irritation.

Do not allow contact with eyes, skin, mucous membranes or clothing. Do not mix with acids or other chemicals. Flush spilled product with water. Do not reuse empty containers. Keep in a cool dry place in original container.

ANTIDOTE: External—flood skin or eyes with plenty of water for 15 minutes. If irritation to skin persists, get medical attention. For eyes—call physician immediately. Internal—drink large quantities of water or milk. Follow with milk of magnesia, vegetable oil, or beaten eggs. Call physician immediately.

ACTIVE INGREDIENTS: Sodium Hypochlorite.....12.5%
INERT INGREDIENTS:87.5%
AVAILABLE CHLORINE:12.5%

NOTE: DEGRADES WITH AGE. USE A TEST KIT AND INCREASE DOSAGE AS NECESSARY TO OBTAIN REQUIRED LEVEL OF AVAILABLE CHLORINE.

1174

FOR INDUSTRIAL USE ONLY

gal. Net Contents

 **WATER SERVICES**

Kansas City, Kansas 66115

Olin Corporation

Stamford, Conn. 06904