



NO UNDER NO. SUBJECT
TO ATTACHED COMMENTS.

OLIN 3004

EPA Est. No.
33576-CA-1
33576-KS-1
33576-NY-1

Algicide for industrial recirculating cooling water towers

DIRECTIONS FOR CONTROLLING THE GROWTH OF ALGAE IN RECIRCULATING COOLING WATER TOWERS.

1. Clean badly fouled systems before starting treatment.
2. When the system is noticeably fouled, add an initial dosage of 8.5 fl. ozs. of Olin 3004 per 1,000 gallons of water in the system. Repeat if necessary until control is evident.
3. Where algae control is evident, use a subsequent dose of 4.25 fl. ozs. of Olin 3004 per 1,000 gallons of water in the system twice a week or as needed to maintain control.
4. Add Olin 3004 directly to the cooling tower drip pan (cold water basin) near the inlet to the recirculating pump.

ACTIVE INGREDIENTS: Sodium Chlorite*25%
INERT INGREDIENTS75%
(*AVAILABLE CHLORINE39%)

Contains 2.58 lbs. Sodium Chlorite per gallon at 70°.

EPA Registration No. 33576-7-AA-50607

475

FOR INDUSTRIAL USE ONLY

gals. Net Contents

DANGER

Keep Out of Reach of Children

Strong Oxidant.

May be harmful or fatal if swallowed. May cause chemical burns. May cause irritation of skin, eyes, nose and throat. Do not get in eyes, on skin or on clothing. Do not mix with other chemicals. Mix only with water. Keep container closed when not in use.

FIRST AID: External—flood skin or eyes with plenty of water for 15 minutes. If irritation to skin persists, get medical attention. For eyes—call physician immediately. Internal—drink large quantities of water or milk. Follow with milk of magnesia, vegetable oil, or beaten eggs. Call physician immediately.

Rinse empty container thoroughly with water and discard in a safe place. Do not reuse empty container.

SPILL: If spilled, flush with plenty of water. If spilled on clothing wash clothing thoroughly.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Do not contaminate water by cleaning of equipment or disposal of waste. Apply this product only as specified on this label.

Olin WATER SERVICES Kansas City, Kansas 66115

Olin Corporation Stamford, Conn. 06904