



UNIVERSITY MICROFILMS
SERIALS ACQUISITION
300 N ZEEB RD
ANN ARBOR MI 48106
SERIALS ACQUISITION
300 N ZEEB RD
ANN ARBOR MI 48106

OLIN 3003

EPA Est. No.
33576-CA-1
33576-KS-1
33576-NY-1

Algicide for use in industrial recirculating cooling water systems

OLIN 3003 is recommended for evaporative condensers, closed systems, open cooling towers.

OLIN 3003 can be prescribed to meet virtually any cooling system problem that involves algae or odors. Each formulation of OLIN ALGICIDE contains different primary ingredients toxic to Algae growth. Thus two different formulations should be kept on hand to be alternated at regular intervals.

Begin treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired. Badly fouled systems must be cleaned before treatment is begun.

RECOMMENDATIONS FOR USE

INITIAL DOSAGE: 1.0 lb. OLIN 3003/1,000 gals. This is equivalent to 15 ppm of available chlorine. Repeat as necessary to get a reading of 1. ppm available chlorine in system for 4 hours, as determined by a suitable chlorine test kit.

MAINTENANCE DOSAGE: 0.5 to 1.0 lb. OLIN 3003/1,000 gals. Every week, or as needed to maintain control.

ACTIVE INGREDIENTS: Sodium dichloro-s-triazinetrione dihydrate 22.5%
INERT INGREDIENTS 77.5%

*(Available Chlorine--12%)

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Apply this product only as specified on this label.

Do not reuse empty drum. Return to drum reconditioner or rinse well with soap solution and discard. Do not contaminate water by disposal of waste.

WARNING

Keep Out of Reach of Children

Oxidizing Material

AVOID contact with eyes, skin or clothing.

Harmful if swallowed. Harmful to skin and eyes.

AVOID breathing dust. AVOID contact with organic material.

FIRST AID: In case of contact, wash skin with plenty of water. Flush eyes for at least fifteen minutes and get medical attention. In case of swallowing, give a tablespoon of salt in glass of warm water. Repeat until vomit is clear. Call a physician.

EPA Registration No. 33576-18-AA-50607

176

FOR INDUSTRIAL USE ONLY

lb. Net Wt.

Olin WATER SERVICES

Olin Corporation

Kansas City, Kansas 66115

Stamford, Conn. 06904