



OLIN 3204

ED UNDER NO.

EPA Est. No.
33576-CA-1
33576-KS-1
33576-NY-1

Algicide for use in industrial recirculating cooling water systems

OLIN 3204 is used to control algae, bacteria and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algae growth, microbiological slime and other deposits.

RECOMMENDATIONS FOR USE: An initial slug addition of 3.6 to 9.0 fluid ounces of OLIN 3204 per 1,000 gallons of contained water, to provide a concentration of 29 to 73 parts per million of OLIN 3204 based on the total weight of water in the system is recommended. Repeat until control is achieved. Subsequent slug additions of 0.9 to 9.0 fluid ounces of OLIN 3204 per 1,000 gallons of contained water (7.3 to 73 parts per million of OLIN 3204) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

EPA REG. NO. 33576-27-AA-50607

CAUTION

Keep Out of Reach of Children

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

ACTIVE INGREDIENT:15%
Poly [oxyethylene (dimethyliminio) ethylene-
(dimethyliminio) ethylene dichloride]15%
INERT INGREDIENTS:85%
Weight of active ingredient.....1.3 pounds
This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label.

Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place.

1174

FOR INDUSTRIAL USE ONLY

lb. Net Wt.

Olin WATER SERVICES

Olin Corporation

Kansas City, Kansas 66115

Stamford, Conn. 06904