

HVAC ALGAECIDE No. 101 COMPOSITION

APPLICATION

HVAC ALGAECIDE No. 101 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 4.0 to 10.0 fluid ounces of HVAC ALGAECIDE No. 101 per 1000 gallons of water to provide a concentration of 32 to 80 parts per million of HVAC ALGAECIDE No. 101 based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 1.0 to 10.0 fluid ounces of HVAC ALGAECIDE No. 101 per 1000 gallons of water (8 to 80 parts per million of HVAC ALGAECIDE No. 101) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

CAUTION

KEEP OUT OF THE REACH OF CHILDREN

Harmful if swallowed. Do not get in eyes. Avoid contact with skin. In case of contact, flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment or disposal of wastes. Use only as directed on label.

Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place.

MANUFACTURED BY HVAC SERVICES, INC. 2011 Greenspring Drive Timonium, Md. 21093

EPA REG. No. 33733 - 1