

# BETZ ENTEC 360

34571-11  
ACCEPTED  
JUL

## PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

### DANGER

HARMFUL OR FATAL IF SWALLOWED.  
CORROSIVE. DO NOT TAKE INTERNALLY.

## ENVIRONMENTAL HAZARDS

PHYSICAL AND CHEMICAL HAZARDS  
CHEMICAL HAZARD: STRONG OXIDIZING  
AGENT

## Contents PELLETS

Active ingredient	
Sodium dichloro-s-triazinetrione dihydrate	99.5%
Inert ingredients	0.5%
Minimum available chlorine	89%
EPA Reg. No. 34571-11	
Net Weight and Volume	as marked on Container

KEEP OUT OF REACH OF CHILDREN

### DANGER

FIRST AID

## DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

### RECIRCULATING COOLING WATER SYSTEMS

BETZ Entec 360 aids in the control of bacterial, fungal and algal films in evaporative condensers, heat exchangers, water systems, commercial and industrial cooling towers, influent systems such as flow through, intake pipes, lagoons, etc., industrial water scrubbing systems and brewery pasteurizers. This product may be added to systems either continuously or intermittently or as required. The frequency of feeding and duration of the treatment will depend upon the severity of the problem.

**BADLY FOULED SYSTEMS** must be cleaned before treatment is begun.

### FOR CONTROL OF BACTERIA AND FUNGI

#### INTERMITTENT OR SLUG METHOD

**INITIAL DOSE:** When the system is noticeably fouled, add 0.1 to 1.5 pound to 1000 gallons or 12 to 180 parts per million of water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE:** When microbial control is evident, add 0.05 to 1.0 pound to 1000 gallons or 6 to 120 parts per million of water in the system every 3 days or as needed to maintain control.

#### CONTINUOUS FEED METHOD

**INITIAL DOSE:** When the system is noticeably fouled, add 0.1 to 1.5 pound to 1000 gallons or 12 to 180 parts per million of water in the system.

**SUBSEQUENT DOSE:** Continuously feed to maintain a dosage of 0.05 to 1.0 pound to 1000 gallons or 6 to 120 parts per million of water in the system.

STORE IN A D

KEEP CONTAINER COVERED — DO NOT

