

# BETZ ENTEC 361

34571-12

ACCEPTED

JUL 2 1980

## PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

### DANGER

HARMFUL OR FATAL IF SWALLOWED. HIGHLY  
CORROSIVE. DO NOT TAKE INTERNALLY.

## ENVIRONMENTAL HAZARDS

## PHYSICAL AND CHEMICAL HAZARDS CHEMICAL HAZARD: STRONG OXIDIZING AGENT

## Contents: PELLETS

Active ingredient  
Trichloro-s-triazinetriene 99.5%

Inert ingredients 0.5%

Minimum available chlorine 89%  
EPA Reg. No. 34571-12

Net Weight and Volume  
as marked on Container

KEEP OUT OF REACH OF CHILDREN

### DANGER

#### FIRST AID

## DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

### RECIRCULATING COOLING WATER SYSTEMS

BETZ Entec 361 aids in the control of bacterial growth and slime in recirculating cooling water systems. It is used in industrial water cooling systems, brewery pasteurizers, etc. This product may be used in systems either continuously or intermittently. The frequency of feeding and dosing of the product will depend upon the severity of the problem.

**BADLY FOULED SYSTEMS** must be cleaned before treatment is begun.

### FOR CONTROL OF BACTERIA AND SLIME

#### INTERMITTENT OR SLUG METHOD

**INITIAL DOSE:** When the system is noticeably fouled, add 0.1 to 1.0 pound to 1000 gallons or 12 to 120 parts per million of water in the system. Repeat until control is obtained.

**SUBSEQUENT DOSE:** When microbial growth is controlled, add 0.1 to 1.5 pound to 1000 gallons or 12 to 60 parts per million of water in the system every 3 days or as needed to maintain control.


#### CONTINUOUS FEED METHOD

**INITIAL DOSE:** When the system is noticeably fouled, add 0.1 to 1.0 pound to 1000 gallons or 12 to 120 parts per million of water in the system.

**SUBSEQUENT DOSE:** Continuously feed to maintain a dosage of 0.1 to 0.5 pound to 1000 gallons or 12 to 60 parts per million of water in the system.

STORE IN

KEEP CONTAINER COVERED — 80-1



# CONTAINER LABEL

Active ingredient: 1,1-Dichloro-2,2-bis(4-chlorophenyl)ethane (D.D.T.) 95%  
Inert ingredients: 5%  
Net weight: 5 lb (2.27 kg)  
EPA Reg. No. 100-100000  
Not for sale in California  
Keep out of reach of children

**DANGER**

FIRST AID

## DIRECTIONS FOR USE

For use only on the following pests: Bacteria, Fungi, and Algae in recirculating cooling water systems.

### RECIRCULATING COOLING WATER SYSTEMS

BETZ Ento-367 adds to the control of bacteria, fungi, and algae in recirculating cooling water systems. It is used in heat exchangers, water systems, commercial and industrial cooling towers, and other systems such as flow-through air conditioning systems, aquaculture, industrial water scrubbing systems, and brewery pasteurizers. The product may be added to the systems either continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend upon the severity of the problem.

**BADLY FOULED SYSTEMS** must be treated before treatment begins.

### FOR CONTROL OF BACTERIA AND FUNGI

#### INTERMITTENT OR SLUG METHOD

**INITIAL DOSE:** When the system is not heavily fouled, add 0.1 to 0.5 pound to 1000 gallons or 12 to 120 parts per million of water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE:** When a system is heavily fouled, add 0.5 to 1.0 pound to 1000 gallons or 12 to 120 parts per million of water in the system every 2 days until control is achieved.

#### CONTINUOUS FEED METHOD

**INITIAL DOSE:** When the system is not heavily fouled, add 0.1 to 0.5 pound to 1000 gallons or 12 to 120 parts per million of water in the system.

**SUBSEQUENT DOSE:** When a system is heavily fouled, add 0.5 to 1.0 pound to 1000 gallons or 12 to 120 parts per million of water in the system.

### FOR CONTROL OF ALGAE

#### INTERMITTENT OR SLUG METHOD

**INITIAL DOSE:** When the system is not heavily fouled, add 0.1 to 0.5 pound to 1000 gallons or 12 to 120 parts per million of water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE:** When a system is heavily fouled, add 0.5 to 1.0 pound to 1000 gallons or 12 to 120 parts per million of water in the system.

#### CONTINUOUS FEED METHOD

**INITIAL DOSE:** When the system is not heavily fouled, add 0.1 to 0.5 pound to 1000 gallons or 12 to 120 parts per million of water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE:** When a system is heavily fouled, add 0.5 to 1.0 pound to 1000 gallons or 12 to 120 parts per million of water in the system.

### STORAGE AND DISPOSAL

Keep product dry in tightly closed container. When not in use, store in a cool, dry, well-ventilated area. Do not store near food, feed, or other products. Do not use near water. Do not use near children and pets. Do not use near fire.

Do not use empty container for other products. Empty container should be disposed of in a safe manner. Do not use for other purposes. Do not use for other purposes.

### FOR INDUSTRIAL USE ONLY

For use only in industrial settings. Do not use in residential settings. Do not use in public areas. Do not use in food processing areas.

STORE IN A DRY PLACE  
KEEP CONTAINER COVERED DO NOT STORE AT ELEVATED TEMPERATURES