

35317-20001

10/2/2012

1/14



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON, DC 20460

OFFICE OF
PREVENTION PESTICIDES
AND TOXIC SUBSTANCES

OCT 2 2012

Paul A Taubler
Regulatory Affairs Manager
Kuehne Chemical Company Inc
c/o Agent David H Dawe
D H Dawe & Associates Inc
16841 Four Seasons Dr
Dumfries VA 22025

Subject **SODIUM HYPOCHLORITE SOLUTION, 12.5%**
EPA Registration No 35317-20001
Application Date August 24 2012
Receipt Date September 05, 2012

Dear Mr Dawe

This acknowledges receipt of your Notification submitted under the provision of PR Notice 98-10 and FIFRA section 12(a) (1) (c)

Proposed Notification

Registrant is changing the primary brand name and adding label language

General Comment

Based upon a review of the material submitted the label changes are in compliance with PR Notice 91-2 and in agreement with the label requirements

Should you have any questions or comments concerning this letter you may contact me by telephone at (703) 308-0410 or by e-mail at harris.monisha@epa.gov or Glen McLeod by telephone at (703) 347-0181 or by e-mail at mcleod.glen@epa.gov When submitting information or data in response to this letter a copy of this letter should accompany the submission to facilitate processing

Sincerely,

A handwritten signature in black ink, appearing to read "Monisha Harris".

Monisha Harris
Product Manager (32)
Regulatory Management Branch II
Antimicrobials Division (7510P)



United States
Environmental Protection Agency
Washington DC 20460

<input type="checkbox"/>	Registration
<input type="checkbox"/>	Amendment
<input checked="" type="checkbox"/>	Other

OPP Identifier Number

Application for Pesticide - Section I

1 Company/Product Number 35317 20001	2 EPA Product Manager M Harns	3 Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4 Company/Product (Name) Sodium Hypochlorite Solution 12.5%	PM# 32	
5 Name and Address of Applicant (Include ZIP Code) Kuehne Chemical Company Inc 86 N Hackensack Avenue South Kearney NJ 07032-4675 <input type="checkbox"/> Check if this is a new address	6 Expedited Review In accordance with FIFRA Section 3(c)(3) (b)(i) my product is similar or identical in composition and labeling to EPA Reg No _____ Product Name _____	

Section - II

<input type="checkbox"/> Amendment Explain below	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> Me Too Application
<input checked="" type="checkbox"/> Notification Explain below	<input type="checkbox"/> Other Explain below

Explanation Use additional page(s) if necessary (For section I and Section II)

Notification of label language changes and additions per PR Notice 98 10

This notification is consistent with the provisions of PR Notice 98 10 and EPA regulations at 40 CFR 152.46 and no other changes have been made to the labeling or the confidential statement of formula of this product. I understand that it is a violation of 18 U.S.C. Sec. 1001 to willfully make any false statement to EPA. I further understand that if this notification is not consistent with the terms of PR Notice 98 10 and 40 CFR 152.46 this product may be in violation of FIFRA and I may be subject to enforcement action and penalties under sections 12 and 14 of FIFRA.


Section - III

1 Material This Product Will Be Packaged In			
Child Resistant Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	2 Type of Container <input type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify) <u>Tank trucks</u>
* Certification must be submitted		If Yes Unit Packaging wgt	No Per Container
3 Location of Net Contents Information <input type="checkbox"/> Label <input type="checkbox"/> Container		4 Size(s) Retail Container Bulk	5 Location of Label Directions <input type="checkbox"/> On label <input type="checkbox"/> On label accompanying product
6 Manner in Which Label is Affixed to Product		<input type="checkbox"/> Lithograph <input type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled	<input type="checkbox"/> Other _____

Section - IV

1 Contact Point (Complete items directly below for identification of individual to be contacted if necessary to process this application)		
Name David H Dawe	Title Senior Regulatory Specialist	Telephone No (Include Area Code) 703/494-6500
Certification I certify that the statements which I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.		6 Date Application Received (Stamped)
2 Signature 	3 Title Agent (D H Dawe & Associates LLC)	
4 Typed Name David H Dawe	5 Date 8/30/2012	

3/17



D.H. Dawe & Associates

16841 Four Seasons Dr "Science applied to business for Success"
Dumfries VA 22025
Phone (703) 590-7570
Cell (559) 960-2245
E-mail dhdawe@dhdawe.com

August 24, 2012

Ms Monisha Harris
Document Processing Desk (NOTIF)
Office of Pesticide Programs (7504P)
U S Environmental Protection Agency
One Potomac Yard
2777 S Crystal Drive
Arlington, VA 22202

Re Notification consistent with PR Notice 98-10
Regarding label language changes and additions (Reg No 35317-20001)

Dear Ms Harris

On behalf of Kuehne Chemical Company, Inc D H Dawe & Associates, LLC is submitting a notification consistent with PR Notice 98-10 that changes the primary brand name, selected label language, and adds label language Enclosed please find two copies of the label and circulars (one highlighted to show changes), an application, and a copy of Kuehne's letter designating D H Dawe & Associates, LLC as the agent for Kuehne Chemical Co , Inc

Should you have any questions, please let me know

David H Dawe

D H Dawe & Associates, LLC (Agent)

Enclosure

SODIUM HYPOCHLORITE SOLUTION, 12.5%

ACTIVE INGREDIENT
SODIUM HYPOCHLORITE
OTHER INGREDIENT
TOTAL

12.5%*
87.5%
100.0%

*Available chlorine 11.9%

KEEP OUT OF REACH OF CHILDREN

DANGER

FIRST AID

IF IN EYES Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses if present after the first 5 minutes then continue rinsing eye. Call a poison control center or doctor for treatment advice.

IF ON SKIN OR CLOTHING Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.

IF INHALED Move person to fresh air. If person is not breathing call 911 or an ambulance. Then give artificial respiration preferably mouth to mouth if possible. Call a poison control center or doctor for treatment advice.

IF SWALLOWED Drink large amounts of water. DO NOT induce vomiting. Call a physician or poison control center immediately.

NOTE TO PHYSICIAN Probable mucosal damage may contraindicate the use of gastric lavage. Have product container or label with you when calling a poison control center or doctor for treatment advice.

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER Corrosive Causes irreversible eye and skin damage. Do not get in eyes, on skin or on clothing. Wear face shield or goggles and rubber gloves when handling this product. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, using tobacco or using the toilet. Avoid breathing vapors. Vacate poorly ventilated areas as soon as possible. Do not return until odors have dissipated. Remove and wash contaminated clothing before reuse.

ENVIRONMENTAL HAZARDS

This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or waters unless this product is specifically identified and addressed in an NPDES permit. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

PHYSICAL OR CHEMICAL HAZARDS

STRONG OXIDIZING AGENT Mix only with water according to label directions. Mixing this product with chemicals (e.g. ammonia, acids, salts, etc.) or organic matter (e.g. urine, feces, etc.) will release chlorine gas which is irritating to eyes, lungs and mucous membranes.

Manufactured by
KUEHNE CHEMICAL COMPANY INC
86 N HACKENSACK AVENUE
SOUTH KEARNY, NJ 07032-4675
(973) 589 0700

EPA REG NO 35317 20001

EPA EST NO 35317 NJ 1
EPA EST NO 35317 DE 1

ANSI / NSF 60
DRINKING WATER TREATMENT ADDITIVE

Net Contents

DIRECTIONS FOR USE
IT IS A VIOLATION OF FEDERAL LAW TO USE THIS PRODUCT
MANNER INCONSISTENT WITH ITS LABELING

NOTE This product degrades with age. Use a chlorine test kit and inc dosage as necessary to obtain the required level of available chlorine.

For specific use directions see KUEHNE Circular for each particular application.

CIRCULAR NUMBER K586A

sanitization of hard nonporous surfaces (stainless steel tops)

CIRCULAR NUMBER K586B

sanitization of commercial laundry

CIRCULAR NUMBER K586C

Agricultural uses: agents to wash or assist in lye peeling of fruits and vegetables (sodium hypochlorite only); agents to help control microorganisms on mushrooms (pins) and potatoes (post harvest); agents to help control microorganisms on eggs for human consumption.

CIRCULAR NUMBER K586D

disinfection of human drinking water (emergency/public & individual) and human drain water systems (water mains)

CIRCULAR NUMBER K586E

disinfection of hard nonporous surfaces (sealed tile and fiberglass glass, stainless steel)

CIRCULAR NUMBER K586F

agents to help control microorganisms in sewage waste water, industrial and pulp and paper process water systems

CIRCULAR NUMBER K586G

algicides, slimeicides in cooling towers or evaporative condensers

CIRCULAR NUMBER K586H

sanitization of porous food contact surfaces (wooden butcher blocks)

CIRCULAR NUMBER K586I

sanitization of porous non food contact surfaces (tile walls, concrete floors)

CIRCULAR NUMBER K586J

disinfection of swimming pool water, spas/hot tubs, hydrotherapy pools


CLEANING FORMULATIONS, BLEACHING, AND NON PESTICIDE CHEMICAL MANUFACTURING This product may be used for cleaning formulations, bleaching, and pesticide chemical manufacturing. Only specifically designed handling and dispensing equipment should be used in accordance with the manufacturer's instructions and according to the instructions or product formulations defined by the use facility.

STORAGE AND DISPOSAL

Pesticide Storage Store this product in a cool, dry area away from direct sunlight and heat to prevent deterioration. In case of a spill, flood area with large quantities of water.

Pesticide Disposal Do not contaminate food or feed by storage, disposal or cleaning of equipment. Product or rinsates that cannot be used should be diluted with water before disposal in a sewer.

Container Disposal Refillable container: Refill this container with pesticide only. Do not reuse this container for any other purpose. Cleaning the container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling the container is the responsibility of the refiller.



Kuehne COMPANY

5/19

86 North Hackensack Avenue, South Kearny, New Jersey 07032-4673

Phone (973) 589-0700

Fax (973) 589-4866

SODIUM HYPOCHLORITE SOLUTION, 12 5%

12 5% BY WEIGHT CIRCULAR

ACTIVE INGREDIENT

SODIUM HYPOCHLORITE

12 5%*

OTHER INGREDIENT

87 5%

TOTAL

100 0%

*Available chlorine 11 9%

CIRCULAR NO. K586A

SANITIZATION OF HARD NONPOROUS SURFACES

DIRECTIONS FOR USE

RINSE METHOD

A solution of 100 ppm available chlorine may be used in the sanitizing solution if a chlorine test kit is available. Solutions containing an initial concentration of 100 ppm available chlorine must be tested and adjusted periodically to insure that the available chlorine does not drop below 50 ppm. Prepare a sanitizing solution of approximately 100 ppm by thoroughly mixing 1 oz. of this product with 10 gallons of water. If no test kit is available, prepare a sanitizing solution by thoroughly mixing 2 oz. of this product with 10 gallons of water to provide approximately 200 ppm available chlorine by weight.

Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. If solution contains less than 50 ppm available chlorine, as determined by a suitable test kit, either discard the solution or add sufficient product to reestablish a 200 ppm residual. Do not rinse equipment with water after treatment and do not soak equipment overnight.

Sanitizers used in automated systems may be used for general cleaning but may not be reused for sanitizing purposes.

IMMERSION METHOD

A solution of 100 ppm available chlorine may be used in the sanitizing solution if a chlorine test kit is available. Solutions containing an initial concentration of 100 ppm available chlorine must be tested and adjusted periodically to insure that the available chlorine does not drop below 50 ppm. Prepare a sanitizing solution of approximately 100 ppm by thoroughly mixing 1 oz. of this product with 10 gallons of water. If no test kit is available, prepare a sanitizing solution by thoroughly mixing 2 oz. of this product with 10 gallons of water to provide approximately 200 ppm available chlorine by weight.

Clean equipment in the normal manner. Prior to use, immerse equipment* in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. If solution contains less than 50 ppm available chlorine, as determined by a suitable test kit, either discard the solution or add sufficient product to reestablish a 200 ppm residual. Do not rinse equipment with water after treatment.

Sanitizers used in automated systems may be used for general cleaning but may not be reused for sanitizing purposes.

FLOW/PRESSURE METHOD

Disassemble equipment and thoroughly clean after use. Assemble equipment in operating position prior to use. Prepare a volume of approximately 200 ppm available chlorine sanitizing solution equal to 110% of volume capacity of the equipment by mixing the product in a ratio of 2 oz product with 10 gallons of water. Pump solution through the system until full flow is obtained at all extremities the system is completely filled with the sanitizer and all air is removed from the system. Close drain valves and hold under pressure for at least 2 minutes to insure contact with all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine.

CLEAN-IN-PLACE METHOD

Thoroughly clean equipment after use. Prepare a sanitizing solution of approximately 200 ppm available chlorine equal to 110% of volume capacity of the equipment by mixing the product in a ratio of 2 oz product with 10 gallons of water. Pump solution through the system until full flow is obtained at all extremities the system is completely filled with the sanitizer and all air is removed from the system. Close drain valves and hold under pressure for at least 10 minutes to insure contact with all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine. Rinse system with potable water prior to use.

SPRAY/FOG METHOD

Pre-clean all surfaces prior to use of the product. Use a 200 ppm available chlorine solution to control bacteria, mold or fungi and a 600 ppm solution to control bacteriophage. Prepare a sanitizing solution of approximately 200 ppm of sufficient size by thoroughly mixing the product in a ratio of 2 oz product with 10 gallons of water. Prepare a sanitizing solution of approximately 600 ppm by thoroughly mixing the product in a ratio of 6 oz product with 10 gallons water. Use spray/fogging equipment which can resist hypochlorite solutions. Always empty and rinse spray/fog equipment with potable water after use. Thoroughly spray or fog all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours. Prior to using equipment, rinse all surfaces treated with a 600 ppm solution with a 200 ppm solution.

SANITIZATION OF NONPOROUS NON-FOOD CONTACT SURFACES**RINSE METHOD**

Prepare a sanitizing solution by thoroughly mixing 2 oz of this product with 10 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

IMMERSION METHOD

Prepare a sanitizing solution by thoroughly mixing in an immersion tank 2 oz of this product with 10 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.

SPRAY/FOG METHOD

Pre-clean all surfaces after use. Prepare a sanitizing solution of approximately 200 ppm available chlorine of sufficient size by thoroughly mixing the product in a ratio of 2 oz of product

with 10 gallons of water Use spray or fogging equipment which can resist hypochlorite solutions Prior to using equipment thoroughly spray or fog all surfaces until wet allowing excess sanitizer to drain Vacate area for at least 2 hours

CIRCULAR NO. K586B

COMMERCIAL LAUNDRY SANITIZERS

DIRECTIONS FOR USE

Wet fabrics or clothes should be spun dry prior to sanitization Thoroughly mix 2 oz of this product with 10 gallons of water to yield approximately 200 ppm available chlorine Promptly after mixing the sanitizer add the solution into the pre-wash prior to washing fabrics/clothes in the regular wash cycle with a good detergent Test the level of available chlorine if solution has been allowed to stand Add more of this product if the available chlorine has dropped below 200 ppm

CIRCULAR NO. K586C

AGRICULTURAL USES

DIRECTIONS FOR USE

POST HARVEST PROTECTION

Potatoes can be sanitized after cleaning and prior to storage by spraying with a sanitizing solution at a level of 1 gallon of sanitizing solution per ton of potatoes Thoroughly mix 1 oz of this product to 2 gallons of water to obtain approximately 500 ppm available chlorine

FOOD EGG SANITIZATION

Thoroughly clean all eggs Thoroughly mix 2 oz of this product with 10 gallons of warm water to produce a solution containing approximately 200 ppm available chlorine solution The sanitizer temperature should not exceed 130 °F Spray the warm sanitizer so that the eggs are thoroughly wetted Allow the eggs to thoroughly dry before casing or breaking Do not apply a potable water rinse The solution should not be reused to sanitize eggs

FRUIT & VEGETABLE WASHING

Thoroughly clean all fruits and vegetables in a wash tank Thoroughly mix 5 oz of this product in 200 gallons of water to make a sanitizing solution of approximately 25 ppm available chlorine After draining the tank submerge fruit or vegetables for 2 minutes in a second wash tank containing the recirculating sanitizing solution Spray rinse vegetables with the sanitizing solution prior to packaging Rinse fruit with potable water only prior to packaging

CIRCULAR NO. K586D

DISINFECTION OF DRINKING WATER (EMERGENCY/PUBLIC/INDIVIDUAL SYSTEMS)

DIRECTIONS FOR USE

PUBLIC SYSTEMS

Mix a ratio of 1 oz of this product to 100 gallons of water Begin feeding this solution with a hypochlorinator until a free available chlorine residual of at least 0.2 ppm and no more than 0.6

ppm is attained throughout the distribution system. Check water frequently with a chlorine test kit. Bacteriological sampling must be conducted at a frequency no less than that prescribed by the National Interim Primary Drinking Water Regulations. Contact your local Health Department for further details.

INDIVIDUAL SYSTEMS DUG WELLS

Upon completion of the casing (lining) wash the interior of the casing (lining) with a solution containing approximately 100 ppm available chlorine using a stiff brush. This solution can be made by thoroughly mixing 1 oz. of this product into 10 gallons of water. After covering the well pour the disinfecting solution into the well through both the pipe sleeve opening and the pipeline. Wash the exterior of the pump cylinder also with the disinfecting solution. Start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Consult your local Health Department for further details.

INDIVIDUAL WATER SYSTEMS DRILLED, DRIVEN & BORED WELLS

Run pump until water is as free from turbidity as possible. Pour a disinfecting solution containing approximately 100 ppm available chlorine solution into the well. This solution can be made by thoroughly mixing 1 oz. of this product into 10 gallons of water. Add 5 to 10 gallons of clean chlorinated water to the well in order to force the disinfectant into the rock formation. Wash the exterior of pump cylinder with the disinfectant. Drop pipeline into well, start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Deep wells with high water levels may necessitate the use of special methods for introduction of the disinfectant to the well. Consult your local Health Department for further details.

INDIVIDUAL WATER SYSTEMS FLOWING ARTESIAN WELLS

Artesian wells generally do not require disinfection. If analyses indicate persistent contamination the well should be disinfected. Consult your local Health Department for further details.

EMERGENCY DISINFECTION

When boiling of water for 1 minute is not practical water can be made potable by using this product. Prior to addition of the sanitizer remove all suspended material by filtration or by allowing it to settle to the bottom. Decant the clarified contaminated water to a clean container and add 1 drop of this product to 20 gallons of water. Allow the treated water to stand for 30 minutes. Properly treated water will have a slight chlorine odor, if not, repeat dosage and allow the water to stand an additional 15 minutes. The treated water can then be made palatable by pouring it between clean containers several times.

PUBLIC WATER SYSTEMS

RESERVOIRS - ALGAE CONTROL

Hypochlorinate streams feeding the reservoir. Suitable feeding points should be selected on each stream at least 50 yards upstream from the points of entry to the reservoir.

MAINS

Thoroughly flush section to be sanitized by discharging from hydrants. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.

NEW TANKS, BASINS, ETC

Remove any physical soil from surface. Place 20 oz of this product for each 5 cubic feet of working capacity (approximately 500 ppm available chlorine). Fill to working capacity and allow to stand for at least 4 hours. Drain and flush with potable water and return to surface.

NEW FILTER SAND

Apply 80 oz of this product for each 150 to 200 cubic feet of sand. The action of the product dissolving as the water passes through the bed will aid in disinfecting the new sand.

NEW WELLS

Flush the casing with a 50 ppm available chlorine solution of water containing 5 oz of this product for each 100 gallons of water. The solution should be pumped or fed by gravity into the well after thorough mixing with agitation. The well should stand for several hours or overnight under chlorination. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary.

EXISTING EQUIPMENT

Remove equipment from service, thoroughly clean surfaces of all physical soil. Disinfect by placing 21 oz of this product for each 5 cubic feet capacity (approximately 500 ppm available chlorine). Fill to working capacity and let stand at least 4 hours. Drain and place in service. If the previous treatment is not practical, surfaces may be sprayed with a solution containing 5 oz of this product for each 5 gallons of water (approximately 1000 ppm available chlorine). After drying, flush with water and return to service.

EMERGENCY DISINFECTION AFTER FLOODS**WELLS**

Thoroughly flush contaminated casing with a solution containing approximately 500 ppm available chlorine. Prepare this solution by mixing 5 oz of this product with 10 gallons of water. Backwash the well to increase yield and reduce turbidity, adding sufficient chlorinating solution to the backwash to produce a 10 ppm available chlorine residual as determined by a chlorine test kit. After the turbidity has been reduced and the casing has been treated, add sufficient chlorinating solution to produce a 50 ppm available chlorine residual. Agitate the well water for several hours and take a representative water sample. Retreat well if water samples are biologically unacceptable.

RESERVOIRS

In case of contamination by overflowing streams, establish hypochlorinating stations upstream of the reservoir. Chlorinate the inlet water until the entire reservoir obtains a 0.2 ppm available chlorine residual as determined by a suitable chlorine test kit. In case of contamination from surface drainage, apply sufficient product directly to the reservoir to obtain a 0.2 ppm available chlorine residual in all parts of the reservoir.

BASINS, TANKS, FLUMES, ETC

Thoroughly clean all equipment then apply 20 oz of product per 5 cubic feet of water to obtain 500 ppm available chlorine, as determined by a suitable test kit. After 24 hours drain, flush, and return to service. If the previous method is not suitable, spray or flush the equipment with a solution containing 5 oz of this product for each 5 gallons of water (approximately 1000 ppm available chlorine). Allow to stand for 2 to 4 hours, flush, and return to service.

10/14

FILTERS

When the sand filter needs replacement apply 80 oz of this product for each 150 to 200 cubic feet of sand When the filter is severely contaminated additional product should be distributed over the surface at the rate of 80 oz per 20 square feet Water should stand at a depth of 1 foot above the surface of the filter bed for 4 to 24 hours When filter beds can be backwashed of mud and silt, apply 80 oz of this product per each 50 sq ft allowing the water to stand at a depth of 1 foot above the filter sand After 30 minutes drain water to the level of the filter After 4 to 6 hours drain and proceed with normal backwashing

DISTRIBUTION SYSTEM

Flush repaired or replaced section with water Establish a hypochlorinating station and apply sufficient product until a consistent available chlorine residual of at least 10 ppm remains after a 24 hour retention time Use a chlorine test kit

EMERGENCY DISINFECTION AFTER FIRES

CROSS CONNECTIONS OR EMERGENCY CONNECTIONS

Hypochlorination or gravity feed equipment should be set up near the intake of the untreated water supply Apply sufficient product to give a chlorine residual of at least 0.1 to 0.2 ppm at the point where the untreated supply enters the regular distribution system Use a chlorine test kit

EMERGENCY DISINFECTION AFTER DROUGHTS

SUPPLEMENTARY WATER SUPPLIES

Gravity or mechanical hypochlorite feeders should be set up on a supplementary line to dose the water to a minimum chlorine residual of 0.2 ppm after a 20 minute contact time Use a chlorine test kit

WATER SHIPPED IN BY TANKS, TANK CARS, TRUCKS, ETC

Thoroughly clean all containers and equipment Spray a solution containing approximately 500 ppm available chlorine and rinse with potable water after 5 minutes This solution is made by mixing 5 oz of this product for each 10 gallons of water During the filling of the containers dose with sufficient amounts of this product to provide at least a 0.2 ppm chlorine residual Use a chlorine test kit

EMERGENCY DISINFECTION AFTER MAIN BREAKS

MAINS

Before assembly of the repaired section flush out mud and soil Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time When chlorination is completed the system must be flushed free of all heavily chlorinated water

CIRCULAR NO. K586E

DISINFECTION OF NONPOROUS NON-FOOD CONTACT SURFACES

DIRECTIONS FOR USE

RINSE METHOD

Prepare a disinfecting solution by thoroughly mixing 6 oz of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight Clean equipment surfaces in the normal manner Prior to use rinse all surfaces thoroughly with the disinfecting

11/19

FILTER BEDS-SLIME CONTROL

Remove filter from service drain to a depth of 1 ft above filter sand and add 80 oz of product per 20 sq ft evenly over the surface Wait 30 minutes before draining water to a level that is even with the top of the filter Wait for 4 to 6 hours before completely draining and backwashing filter

PULP AND PAPER MILL PROCESS WATER SYSTEMS

SLUG FEED METHOD

Initial Dose When system is noticeably fouled apply 52 to 104 oz of this product per 10 000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine Repeat until control is achieved

Subsequent Dose When microbial control is evident add 11 oz of this product per 10 000 gallons of water in the system daily or as needed to maintain control and keep the chlorine residual at 1 ppm Badly fouled systems must be cleaned before treatment is begun

INTERMITTENT FEED METHOD

Initial Dose When system is noticeably fouled apply 52 to 104 oz of this product per 10 000 gallons of water in the system to obtain 5 to 10 ppm available chlorine Apply half (or 1/3 1/4 or 1/5) of this initial dose when half (or 1/3 1/4 or 1/5) of the water in the system has been lost by blowdown

Subsequent Dose When microbial control is evident add 11 oz of this product per 10 000 gallons of water in the system to obtain a 1 ppm residual Apply half (or 1/3 1/4 or 1/5) of this initial dose when half (or 1/3 1/4 or 1/5) of the water in the system has been lost by blowdown Badly fouled systems must be cleaned before treatment is begun

CONTINUOUS FEED METHOD

Initial Dose When system is noticeably fouled, apply 52 to 104 oz of this product per 10 000 gallons of water in the system to obtain 5 to 10 ppm available chlorine

Subsequent Dose Maintain this treatment level by starting a continuous feed of 1 oz of this product per 1,000 gallons of water lost by blowdown to maintain a residual of approximately 1 ppm Badly fouled systems must be cleaned before treatment is begun

CIRCULAR NO. K586G
COOLING TOWER & EVAPORATIVE CONDENSER WATER
DIRECTIONS FOR USE

SLUG FEED METHOD

Initial Dose When system is noticeably fouled apply 52 to 104 oz of this product per 10 000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine Repeat until control is achieved

Subsequent Dose When microbial control is evident add 11 oz of this product per 10 000 gallons of water in the system daily or as needed to maintain control and keep the chlorine residual at 1 ppm Badly fouled systems must be cleaned before treatment is begun

INTERMITTENT FEED METHOD

Initial Dose When system is noticeably fouled apply 52 to 104 oz of this product per 10 000 gallons of water in the system to obtain 5 to 10 ppm available chlorine Apply half (or 1/3 1/4 or 1/5) of this initial dose when half (or 1/3 1/4 or 1/5) of the water in the system has been lost by blowdown

Subsequent Dose When microbial control is evident add 11 oz of this product per 10 000 gallons of water in the system to obtain a 1 ppm residual Apply half (or 1/3 1/4 or 1/5) of this initial dose when half (or 1/3 1/4, or 1/5) of the water in the system has been lost by blowdown Badly fouled systems must be cleaned before treatment is begun

CONTINUOUS FEED METHOD

Initial Dose When system is noticeably fouled apply 52 to 104 oz of this product per 10 000 gallons of water in the system to obtain 5 to 10 ppm available chlorine

Subsequent Dose Maintain this treatment level by starting a continuous feed of 1 oz of this product per 1 000 gallons of water lost by blowdown to maintain a residual of approximately 1 ppm Badly fouled systems must be cleaned before treatment is begun

CIRCULAR NO. K586H

SANITIZATION OF POROUS FOOD CONTACT SURFACES

DIRECTIONS FOR USE

RINSE METHOD

Prepare a sanitizing solution by thoroughly mixing 6 oz of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight Clean surfaces in the normal manner Prior to use rinse all surfaces thoroughly with the sanitizing solution maintaining contact with the sanitizer for at least 2 minutes Rinse all surfaces with a solution containing approximately 200 ppm available chlorine prepared by thoroughly mixing the product in a ratio of 2 oz product with 10 gallons of water Do not soak equipment overnight

IMMERSION METHOD

Prepare a sanitizing solution by thoroughly mixing in an immersion tank 6 oz of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight Clean equipment in the normal manner Prior to use immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain Immerse all surfaces in a solution containing approximately 200 ppm available chlorine prepared by thoroughly mixing the product in a ratio of 2 oz product with 10 gallons of water

SPRAY/FOG METHOD

Pre-clean all surfaces after use Prepare a sanitizing solution of approximately 600 ppm available chlorine of sufficient size by thoroughly mixing the product in a ratio of 6 oz product with 10 gallons of water Use spray or fogging equipment which can resist hypochlorite solutions Always empty and rinse spray/fog equipment with potable water after use Thoroughly spray or fog all surfaces until wet allowing excess sanitizer to drain Vacate area for at least 2 hours Prior to using equipment rinse all surfaces with a 200 ppm available chlorine solution Prepare a sanitizing solution of approximately 200 ppm by thoroughly mixing 2 oz of this product with 10 gallons of water

CIRCULAR NO. K586I

SANITIZATION OF POROUS NON-FOOD CONTACT SURFACES

DIRECTIONS FOR USE

RINSE METHOD

Prepare a sanitizing solution by thoroughly mixing 6 oz of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

IMMERSION METHOD

Prepare a sanitizing solution by thoroughly mixing in an immersion tank, 6 oz of this product with 10 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.

SPRAY/FOG METHOD

After cleaning, sanitize non-food contact surfaces with a solution containing approximately 600 ppm available chlorine by thoroughly mixing the product in a ratio of 6 oz of this product with 10 gallons of water. Use spray or fogging equipment which can resist hypochlorite solutions. Always empty and rinse spray/fog equipment with potable water after use. Prior to using equipment, thoroughly spray or fog all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours.

CIRCULAR NO. K586J

DISINFECTION OF SWIMMING POOLS, SPAS/HOT TUBS, AND HYDROTHERAPY POOLS

DIRECTIONS FOR USE

SWIMMING POOL WATER DISINFECTION

For a new pool or spring start-up, superchlorinate with 52 to 104 oz of product for each 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Check the level of available chlorine with a test kit. Adjust and maintain pool water pH to between 7.2 and 7.6. Adjust and maintain the alkalinity of the pool to between 50 and 100 ppm. To maintain the pool, add manually or by a feeder device 11 oz of this product for each 10,000 gallons of water to yield an available chlorine residual between 0.6 and 1.0 ppm by weight. Stabilized pools should maintain a residual of 1.0 to 1.5 ppm available chlorine. Test the pH, available chlorine residual, and alkalinity of the water frequently with appropriate test kits. Frequency of water treatment will depend upon temperature and number of swimmers.

Every 7 days, or as necessary, superchlorinate the pool with 52 to 104 oz of product for each 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Check the level of available chlorine with a test kit. Re-entry into treated pools is prohibited above levels of 4 ppm due to risk of bodily harm.

At the end of the swimming pool season or when water is to be drained from the pool chlorine must be allowed to dissipate from treated pool water before discharge Do not chlorinate the pool within 24 hours prior to discharge

WINTERIZING POOLS

While water is still clear and clean apply 3 oz of product per 1000 gallons while filter is running to obtain a 3 ppm available chlorine residual as determined by a suitable test kit Cover pool prepare heater filter and heater components for winter by following manufacturer's instructions

SPAS, HOT-TUBS, IMMERSION TANKS, ETC

SPAS/HOT-TUBS

Apply 5 oz of product per 1000 gallons of water to obtain a free available chlorine concentration of 5 ppm as determined by a suitable chlorine test kit Adjust and maintain pool water pH to between 7.2 and 7.8 Some oils lotions fragrances cleaners etc may cause foaming or cloudy water as well as reduce the efficiency of the product

To maintain the water apply 5 oz of product per 1000 gallons of water over the surface to maintain a chlorine concentration of approximately 5 ppm Use of spas and hot tubs when chlorine concentrations are above 5 ppm is prohibited

After each use shock treat with 8 oz of this product per 500 gallons of water to control odor and algae

During extended periods of disuse add 3 oz of product daily per 1000 gallons of water to maintain approximately 3 ppm chlorine concentration

HUBBARD AND IMMERSION TANKS

Add 5 oz of product per 200 gallons of water before patient use to obtain a chlorine residual of 25 ppm as determined by a suitable test kit Adjust and maintain the water pH to between 7.2 and 7.6 After each use drain the tank Add 5 oz to a bucket of water and circulate this solution through the agitator of the tank for 15 minutes and then rinse out the solution Clean tank thoroughly and dry with clean cloths

HYDROTHERAPY TANKS

Add 1 oz of this product per 1000 gallons of water to obtain a chlorine residual of 1 ppm as determined by a suitable chlorine test kit Pool should not be entered until the chlorine residual is below 3 ppm Adjust and maintain the water pH to between 7.2 and 7.6 Operate pool filter continuously Drain pool weekly and clean before refilling