

S-75 MICROBIOCIDE will control algae found in recirculating cooling tower waters.

S-75 MICROBIOCIDE is economical to use because it is concentrated. It should be handled with care.

WARNING:

KEEP OUT OF REACH OF CHILDREN. CAUSES EYE DAMAGE. DO NOT GET IN EYES, ON SKIN, OR ON CLOTHING. WEAR GOGGLES OR FACE SHIELD AND RUBBER GLOVES WHEN HANDLING. HARMFUL OR FATAL IF SWALLOWED. MAY BE HARMFUL IF ABSORBED THROUGH THE SKIN.

FIRST AID:

IF SWALLOWED, GIVE PATIENT DOSES OF POWDERED CHARCOAL IMMEDIATELY OR ALL HE CAN SWALLOW OF RAW EGG WHITE, MILK, GRUEL, OR FLOUR AND WATER. THEN INDUCE VOMITING WITH SALT, SOAP, OR MUSTARD IN WARM WATER. CALL A PHYSICIAN IMMEDIATELY.

IN CASE OF SKIN CONTACT, WASH PROMPTLY AND THOROUGHLY WITH AN ABRASIVE SOAP AND COOL WATER AND FINALLY WITH GLYCERIN. IN CASE OF PERSISTANT IRRITATION OF THE SKIN, OBTAIN MEDICAL ATTENTION.

IF THE PRODUCT GETS INTO EYES, IT CAUSES EYE DAMAGE; THEREFORE, FLOOD EYES IMMEDIATELY AND THOROUGHLY WITH COOL WATER FOR 15 TO 30 MINUTES. SEE A PHYSICIAN IF ANY IRRITATION PERSISTS. REMOVE AND WASH CONTAMINATED CLOTHING BEFORE REUSE.

NET WEIGHT OF CONTENTS
SHOWN ELSEWHERE ON CONTAINER

S-75
MICROBIOCIDE
WATER TREATMENT MICROBIOCIDE
FOR COMMERCIAL AND INDUSTRIAL
COOLING TOWERS

ACCEPTED
29 1975

<u>ACTIVE INGREDIENTS</u>	15%
2-(Thiocyanomethylthio) benzothiazole	8%
2-Hydroxypropyl methanethiolsulfonate	7%
<u>INERT INGREDIENTS</u>	85%
Weight per gallon	7.68 pounds
Weight of active ingredients per gallon	1.15 pounds
<u>EPA REGISTRATION NO.</u>	35378-6

MANUFACTURED BY
AQUA/PROCESS CHEMICALS
2408 Yorktown #178
Houston, Texas 77027

WARNING
KEEP OUT OF REACH OF CHILDREN. SEE LEFT PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS.

APPLICATIONS

To control algae, use S-75 MICROBIOCIDE as directed. For best results, slug feed. The frequency of addition of microbicide needed depends on many factors. To optimize your use of S-75 MICROBIOCIDE follow this procedure. Should tower be heavily fouled, a pre-cleaning is required.

1. Initially use 5.3 to 8 fluid ounces per 1000 gallons of water to be treated (40 to 60ppm of S-75).

Slug additions should be made in the sump of cooling towers.

Repeat the initial dose every five days or increase the frequency if needed.

2. When the above treatment level is successful, use 4 to 8 fluid ounces per 1000 gallons of water (30 - 60ppm S-75) to maximize efficiency. Repeat weekly as needed.

Should algae develop again, go back to initial dosage.

Cooling tower waters that are inherently low in algae growth. (May be adequately controlled by the lower range of these dosages; slug fed every seven days.)

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment, or disposal of wastes. Apply this product only as specified on this label.

Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place away from water supplies.