




3. Submit five (5) copies of your final printed labeling before you release the product for shipment. Refer to the A-79 Enclosure for a further description of final printed labeling.

If these conditions are not complied with, the registration will be subject to cancellation in accordance with FIFRA sec. 6(e). Your release for shipment of the product constitutes acceptance of these conditions.

A stamped copy of the label is enclosed for your records.

A handwritten signature in cursive script, appearing to read "James H. Banks".

John H. Lee  
Product Manager (31)  
Disinfectants Branch  
Registration Division (TS-767C)

Enclosure

RD/DIS:JOB-51605:LEE:vq:CBI-26:Kendrick & Co. 898-1270:2/13/85:Del.2/22/85

Algaecide 200

**ACTIVE INGREDIENT:**

Potassium dimethyldithiocarbamate ..... 20.0Z

**INERT INGREDIENTS** ..... 80.0Z

This product contains 1.81 lb. of active ingredient per gallon and weighs 9.05 lb. per gallon.

**KEEP OUT OF REACH OF CHILDREN  
WARNING**

**PRECAUTIONARY STATEMENTS  
HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

**WARNING** Causes eye damage and skin irritation. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Avoid contamination of food. Wear goggles or face shield and rubber gloves when handling. Wash thoroughly after handling.

**STATEMENT OF PRACTICAL TREATMENT.** In case of skin contact, wash with plenty of soap and water. Remove contaminated clothing and wash before reuse. If product gets in the eyes, flush immediately with copious amounts of clean, cool water for at least 15 minutes. Get medical attention immediately. If product is swallowed, call a physician immediately. If patient is conscious, induce vomiting by stroking or tickling the patient's throat or far back on patient's tongue. Emetics such as 2 teaspoonful (10 mL) of ipecac syrup or 1 teaspoonful (5 mL) of dry mustard in warm water to form a paste or even soap in warm water can be used. Repeat until vomit fluid is clear. Then have patient drink plenty of milk, gelatin solution, beaten egg whites, flour and water, or other nonacidic demulcent. Never induce vomiting or give anything by mouth to an unconscious person.  
*Note to physician:* Probable mucosal damage may contraindicate gastric lavage.

**ENVIRONMENTAL HAZARDS** This pesticide is toxic to fish. Do not apply in marine and/or estuarine or fields. Do not discharge treated effluents into lakes, streams, ponds, or public waters unless in accordance with a NPDES permit. For guidance, contact your Regional Office of the Environmental Protection Agency.

ACCEPTED  
with COMMENTS  
EPA Letter Dated

Manufactured by:  
The L. A. Lux Company  
2285 Scranton Road  
Cleveland, OH 44113

FEB 21 1985

EPA REG. NO. \_\_\_\_\_ EPA EST. NO. \_\_\_\_\_

Under the Pesticide Control Act of 1972, as amended, for the pest registered under EPA Reg. No. 35969-9

NET CONTENTS

**DIRECTIONS FOR USE  
GENERAL CLASSIFICATION**

It is a violation of Federal law to use this pesticide in a manner inconsistent with its labeling.

Algaecide 200 is used in industrial cooling tower systems and industrial air-washing systems. Prior to the use of Algaecide 200 in recirculating cooling tower systems, systems should be cleaned of microbial slime, and other deposits. Then make an addition of 8.6 fl. oz. of Algaecide 200 to 30 to 45 ppm of Algaecide 200 of water in the system. Repeat initial dosage until control is achieved. Add an additional 2.9 to 8.6 fl. oz. of Algaecide 200 per 1000 gal. of water ( 15 to 45 ppm Algaecide 200 ) every 1 to 5 days or as needed. The frequency of addition depends upon the severity of the microbiological problem and the amount of bleedoff from the sump of recirculating cooling tower systems.

Algaecide 200 is used in industrial water systems to maintain effective mist-eliminating components. Prior to the use of Algaecide 200 to remove bacterial slime and other deposits, the system should be cleaned. Then add 17.2 fl. oz. of Algaecide 200 to the system. Repeat initial dosage until control is evident. Add an additional 10.0 to 17.2 fl. oz. of Algaecide 200 per 1000 gal. of water should be employed every 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the microbiological problem. Additional additions may be made to the sump or the water collection tank.

Algaecide 200 is used to control bacteria, including sulfate-reducing organisms, in waterflooding operations. In systems fouled with microorganisms, Algaecide 200 should be added as a slug dose of 20 to 40 ppm ( 2.38 to 4.76 fl. oz. per 1000 gal. of water treated ). This should be followed by a continuous addition of Algaecide 200 employing a chemical concentration of 20 ppm, based on total weight of fluid. Add Algaecide 200 to heater-treater dump, gathering lines, or receiving tanks upstream to the filter.

Algaecide 200 is also used to control bacteria in water-based drilling muds, completion fluids, and based drilling fluids containing starch, gums, sugars, or other solids. Add Algaecide 200 to the fluid at a concentration of 0.04 to 0.20% by volume.

**STORAGE AND DISPOSAL**

Do not contaminate water, food, or feed by storage or disposal. **STORAGE** Do not expose to extreme temperatures. Do not stack more than 10 drums. Drums should be placed in overpack drums for disposal. Spills should be cleaned up and disposed of in a sanitary landfill. Keep container closed when not in use.

**PESTICIDE DISPOSAL** Pesticide wastes are toxic. Improper disposal is a violation of Federal Law. If these wastes cannot be disposed of by other procedures approved by state and local officials, contact your State Pesticide or Environmental Control Agency, or the nearest Regional Office for guidance.

**CONTAINER DISPOSAL:**  
**PLASTIC** Triple rinse (or equivalent). Then offer for recycling or reuse, or for incineration, or, if allowed by state and local officials, by other procedures approved by state and local officials.  
**METAL** Triple rinse (or equivalent). Then offer for recycling or reuse, or for incineration, or, if allowed by state and local officials, by other procedures approved by state and local officials.