

## DIRECTIONS FOR USE:

Systems must be cleaned to remove algal growth, microbiological slime and other deposits prior to use of Water Guard #161. Slug additions of Water Guard #161 should be made in the sump of water cooling towers.

Initial Dose: An initial slug addition of 3.9 to 9.75 fluid ounces of Water Guard #161 per 1,000 gallons of water, to provide a concentration of 32 to 80 parts per million of Water Guard #161 based on the total weight of water in the system, is recommended. Repeat until control is achieved.

Subsequent Dose: Additions of 1.0 to 9.75 fluid ounces of Water Guard #161 per 1,000 gallons of water in the system (8 to 80 parts per million of Water Guard #161) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem.

## FIRST AID:

Avoid contact with skin and eyes. Harmful if swallowed. Avoid contamination of food.

External: Flush area of contact with plenty of water for at least 15 minutes.

Eyes: Flush eyes with water for at least 15 minutes. If eye irritation persists, get medical attention,

Internal: Induce vomiting, Call a Physician immediately.

## ENVIRONMENTAL HAZARDS:

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on this label. Do not rinse empty drum print the drum to reconditioner or destroy by perforating or crushing and burying.

FEB 10 1976

THE PEDENAL INSECTICIDE PORQUEIDE AND RODENTICIDE ACT

FOR ROOMOMIC POISON RECHETER-

IN CHECK HO.