

SOUTHERN  
RESEARCH

TESTING AND  
LABORATORIES

Directions for use as a microbiocide for use in industrial recirculating water cooling towers to reduce the number of living algae.

Begin treatment when the system is in jeopardy of becoming effected or after cleaning systems whose efficiency is already impaired.

Initial Dose: When the system is noticeably fouled, apply 1/4 lb. (4 briquettes) to 1/2 lb. (8 briquettes) of BB-90 per 700 gallons of water in the system. Repeat until control is achieved.

Subsequent Dose: When microbial control is evident add 1/8 lb. (2 briquettes) to 1/4 lb. (4 briquettes) of BB-90 per 700 gallons of water in or as needed to maintain control. Badly fouled systems must be cleaned before treatment is begun.

Feed BB-90 at the sump of industrial recirculating water cooling towers.

DO NOT reuse container. Destroy when empty.

Sold By:  
**SOUTHERN TESTING AND  
RESEARCH LABS., INC.**  
Water-Guard Division  
607 Park Ave. Wilson, N. C.  
237-4175

37648-4  
ACCEPTED

"BB 90"

MAR 6 1973

FEDERAL INSECTICIDE  
HERBICIDE AND FUNGICIDE ACT  
FEDERAL TOXIC SUBSTANCE CONTROL  
ACT UNDER NO. 13805-5. SUBJECT  
OF ATTACHED COMMENTS.

Active Ingredients 90%

Sodium Pentachlorophen-  
ate 79%

Sodium Salts of other  
chlorphenates 11%

Inert Ingredients 10%

NET WEIGHT

1 oz. per briquette

EPA Reg. No. 13805-5

**DANGER**

Keep out of reach of children

Absorbed through skin from solution, may cause eye damage or skin irritation. Harmful or fatal if swallowed

Do not breathe dust.

Do not get in eyes, on skin, or clothing.

Do not take internally.

Wash thoroughly after handling.

This product is toxic to fish and wild-life. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public waters. Do not contaminate water by cleaning of equipment, or disposal of wastes. Apply this product only as specified on this label.

**FIRST AID**

External-Wash freely with soap and water.

Eyes-Flush for at least 15 minutes with water

Internal - Induce vomiting.

**CALL PHYSICIAN**