

39959-2

5/16/2012

Page 1 of 2

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON, D.C. 20460

MAY 16 2012

OFFICE OF CHEMICAL SAFETY
AND POLLUTION PREVENTION

Flora Malekzadeh
Chem Inc
13560 Colombard Court
Fontana, California 92337-7600

Subject: 7618
EPA Registration No.: 39959-2
Application Date: 03/15/2012
Receipt Date: 03/26/2012

Dear Ms. Malekzadeh:

The following amendment submitted in connection with registration under FIFRA, as amended, is acceptable.

Proposed Amendment

- Label revisions

General Comments

A stamped label is enclosed for your records. Submit three (3) copies of your final printed label before distributing or selling the product bearing the revised labeling.

Should you have any questions or comments concerning this letter, you may contact Jaclyn Carl by telephone at (703) 347-0213 or by e-mail at carl.jaclyn@epa.gov.

When submitting information or data in response to this letter, a copy of this letter should accompany the submission to facilitate processing.

Sincerely,

Jacqueline Campbell-McFarlane
Product Manager (34)
Regulatory Management Branch II
Antimicrobials Division (7510P)

CONCURRENCES

SYMBOL	SURNAME	DATE					

ACCEPTED

MAY 16 2012

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide, registered under EPA Reg. No. 399592



a subsidiary of Harpue Enterprises, Inc.

13560 Colombar Court, Fontana, CA 92337 • (951) 681-9697

EPA EST. NO. 39959-CA-1
EPA EST. NO. 61688-AL-1

EPA REG. NO. 39959-2

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, smoking tobacco or using toilet.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

WARRANTY

Seller's guarantee shall be limited to the terms of the label, and subject thereto. The buyer assumes any risk to persons or property arising out of use or handling and accepts the product on these conditions.

IN CASE OF EMERGENCY
Endangering life or property involving this product, call INFOTRAC (800)535-5053

Net contents: 30 GALLONS
Lot No.:

7618

A SPECIALIZED FORMULATION OF ORGANIC SCALE AND CORROSION INHIBITORS CONTAINING A MICROBIOCIDAL FOR USE IN CONTROLLING ALGAE AND BACTERIA IN COMMERCIAL AND INDUSTRIAL RECIRCULATING WATER COOLING TOWERS AND INDUSTRIAL AIR WASHING SYSTEMS. THIS PRODUCT IS SPECIFICALLY DESIGNED AS A COMPLETE ALL-IN-ONE LIQUID TREATMENT PROGRAM.

ACTIVE INGREDIENTS:

- Poly (oxyethylene (dimethyliminio) ethylene- (dimethyliminio) ethylene dichloride) 5%
- INERT INGREDIENTS:** 95%
- TOTAL** 100%

This product contains 0.43 lbs. of active ingredient per gallon and weighs 8.71 lbs. per gallon.

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

FIRST AID

- If Swallowed:**
 - Call a poison control center or doctor immediately for treatment advice.
 - Have person sip a glass of water if able to swallow.
 - Do not induce vomiting unless told to do so by a poison control center or doctor.
 - If in Eyes:**
 - Do not give anything by mouth to an unconscious person.
 - Hold eye open and rinse slowly and gently with water for 15-20 minutes.
 - Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye.
 - Call a poison control center or doctor immediately for treatment advice.
 - If on Skin or Clothing:**
 - Take off contaminated clothing.
 - Rinse skin immediately with plenty of water for 15-20 minutes.
 - Call a poison control center or doctor for treatment advice.
- Have MSDS and, if available, the product container or label with you when calling a poison control center or a doctor, or going for treatment.

SEE SIDE PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

7618 is used to control scale, corrosion, algae, and bacteria in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 12 to 30 fluid ounces of 7618 per 1000 gallons of water to provide a concentration of 96 to 240 parts per million of 7618, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 3.0 to 30 fluid ounces of 7618 per 1000 gallons of water (24 to 240 parts per million of 7618) must be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions must be made in the sump of water cooling towers.

CONTINUOUS FEED METHOD

INITIAL DOSE:

When the system is noticeably fouled, apply 12 to 30 fluid ounces of 7618 per 1000 gallons of water used in the system.

SUBSEQUENT DOSE:

When microbial control is evident, add 3.0 to 30 fluid ounces of 7618 per 1000 gallons of water used in the system per day.

7618 is used to control scale, corrosion, and bacteria in industrial air washing systems that maintain effective mist eliminating components. Prior to its use, system must be cleaned to remove bacterial slime and other deposits. An initial slug dose of 44.4 to 74.1 fluid ounces of 7618 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 30.3 to 74.1 fluid ounces of 7618 per 1000 gallons of water must be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleed off and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the air wash system.

STORAGE AND DISPOSAL

Do not contaminate water, food, or feed by storage or disposal.

STORAGE: Do not stack more than four drums high. Leaking or damaged drums must be placed in over pack drums for disposal. Spills must be absorbed in sawdust or sand and disposed of in a sanitary landfill. Keep container closed when not in use.

PESTICIDE DISPOSAL: Waste resulting from the use of this product must be disposed of on site or at an approved waste disposal facility.

CONTAINER HANDLING: (4 and 5 gallon) Non refillable container. Do not reuse or refill this container. Triple rinse container (or equivalent) promptly after emptying. Offer for reconditioning if appropriate. Triple rinse as follows: empty remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container 1/4 full with water and recap. Shake for 10 seconds. Pour rinse into application equipment or a mix tank or store for later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times.

CONTAINER HANDLING: (15, 30, and 55 gallon drums) Refillable container. Refill this container with 7618 only. Do not reuse this container for any other purpose. Cleaning the container before final disposal is the responsibility of the person disposing of the container. To clean the container before application equipment or mix tank. Fill the container about 10 percent full with water. Agitate vigorously or recirculate water with the pump for 2 minutes. Pour or pump rinse into application equipment or rinse collection system. Repeat this rinsing procedure two more times.

CONTAINER HANDLING: 275-300 gallon tote or IBC Refillable container. Refill this container with 7618 only. Do not reuse this container for any other purpose. Cleaning the container before final disposal is the responsibility of the person disposing of the container. To clean the container before application equipment or mix tank. Fill the container about 10 percent full with water. Agitate vigorously or recirculate water with the pump for 2 minutes. Pour or pump rinse into application equipment or rinse collection system. Repeat this rinsing procedure two more times.

272