

DIRECTIONS PANEL FOR AIR WASHERS AND EVAPORATIVE COOLERS (INDUSTRIAL/COMMERCIAL)
LABEL

COOPER-GRIFFIN AIR WASHER BIOCIDES is used to control bacteria in industrial air-washing systems which maintain effective mist-eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of COOPER-GRIFFIN AIR WASHER BIOCIDES per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of COOPER-GRIFFIN AIR WASHER BIOCIDES per 1000 gallons of water should be employed each 1 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

COOPER-GRIFFIN AIR WASHER BIOCIDES is also used to control algae, bacteria, and fungi in evaporative coolers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 6.13 to 15.32 fluid ounces of COOPER-GRIFFIN AIR WASHER BIOCIDES per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of COOPER-GRIFFIN AIR WASHER BIOCIDES, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.53 to 15.32 fluid ounces of COOPER-GRIFFIN AIR WASHER BIOCIDES per 1000 gallons of water (12 to 120 parts per million of COOPER-GRIFFIN AIR WASHER BIOCIDES) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of the evaporative cooler.

DIRECTIONS PANEL FOR RESIDENTIAL EVAPORATIVE COOLERS

(HOME-USE LABEL)

COOPER-GRIFFIN AIR WASHER BIOCIDES is used to control algae, bacteria, and fungi in residential evaporative coolers. Prior to its use, system must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 0.6 to 1.5 fluid ozs of COOPER-GRIFFIN AIR WASHER BIOCIDES per 100 gallons of water is recommended. Initial dosage should be continued once a day until control is evident.

Subsequent additions of 0.15 to 1.5 fluid ozs should be employed every 2 to 3 days or as needed to maintain control.

Under the Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide registered under EPA Reg. No. 40602-21

SEP 24 1982

ACCEPTED
with comments
by EPA Letter Dated: