

BEST DOCUMENT AVAILABLE

ACCEPTED
7-27-79
40988-2
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTRA-
TION UNDER NO.

Custom Chemical

556

P.O. Box 192
Hurst, Texas 76053
(Metro) Phone 817/572-1621

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

ACTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.
PRACTICAL TREATMENT: IF HST A.D. is swallowed, promptly drink a large quantity of milk, egg whites, or cold solution. If these are not available, drink large quantities of water. Avoid alcohol. Do not induce vomiting.
ENVIRONMENTAL HAZARDS: This product is toxic to fish. Keep out of waterways. Do not allow this product to be required for applications containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

Manufactured by

Custom Chemical
P.O. Box 192
Hurst, Texas 76053
EPA Reg. No. 40988-2

EPA EST. NO. 40988-1X-1

NET CONTENTS

Custom Tower Algicide

ACTIVE INGREDIENT

Poly(oxyethylene (dimethyliminio) ethylene-
(dimethyliminio) ethylene dichloride)..... 10.0%

INERT INGREDIENT..... 90.0%

This product contains 0.85 pounds of active ingredient per gallon and weighs 8.49 pounds per gallon.

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

(See additional precautions and first aid on side panel)

**DIRECTIONS FOR USE
GENERAL CLASSIFICATION**

It is a violation of federal law to use this product in a manner inconsistent with its labeling.

Custom Tower Algicide is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits.

An initial slug addition of 6.13 to 15.32 fluid ounces of Custom Tower Algicide per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of Custom Tower Algicide, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.53 to 15.32 fluid ounces of Custom Tower Algicide per 1000 gallons of water (12 to 120 parts per million of Custom Tower Algicide) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

STORAGE & DISPOSAL

Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal, or cleaning of equipment. The container must be triple rinsed (or equivalent) and offered for recycling, reconditioning, or disposal in an approved landfill or buried in a safe place. Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.