KA 630

ACCEPTED

H/7/6-2

SEP 1 7 1980

Under the Federal Insecticide.
Ferryicide, and Radanficide Act
as amended, for the resuccide
TA Reg. No.

KEEP OUT OF REACH OF CHILDREN

CAUTION

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

DIRECTIONS FOR USE GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

KA 630 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 1.90 to 4.75 fluid ounces of KA 630 per 1000 gallons of water to provide a concentration of 16 to 40 parts per million of KA 630, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 0.47 to 4.75 fluid ounces of KA 630 per 1000 gallons of water (4 to 40 parts per million of KA 630) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedo:f and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

KA 630 is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 7.1 to 11.9 fluid ounces of KA 630 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 4.8 to 11.9 fluid ounces of KA 630 per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

<u> </u>	
STORAGE & DISPOSAL: Keep co contaminate water, food, or feed by stor Rinsate that cannot be used or reprocess proved for pesticides or buried in a safe dumping is prohibited.	age, disposal or cleaning of equipment, ed should be disposed of in a landfill ap-
☐ METAL CONTAINERS: Triple rinse and offer for recycling, reconditioning, or disposal in an approved landfill or bury in a safe place.	PLASTIC CONTAINERS: Do not reuse empty container. Triple rinse and incinerate or dispose of in an approved landfill or bury in safe place.
Manufact Keith As 4867 N. M	sociates

Manufactured by: Keith Associates 4867 N. Main Street Acworth, GA 30101 EPA REG. NO. 41716-2 EPA EST. NO.		23
NET CONTENTS		~`\

BEST DOCUMENT AVAILABLE