# GC Algacide ACCEPTED 42389-2 JAN 3 0 1981 Funai as a .. **ACTIVE INGREDIENT:** EPA Hez No. Poly[oxyethylene (dimethyliminio) ethylene-

.... 10.0% (dimethyliminio) ethylene dichloride] ..... INERT INGREDIENT ..... 90.0%

This product contains 0.85 lb. of active ingredient per gallon and weighs 8.49 lb. per gallon.

### **KEEP OUT OF REACH OF CHILDREN**

# CAUTION

#### PRECAUTIONARY STATEMENTS

#### HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors, Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this

## DIRECTIONS FOR USE GENERAL (LASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

GC Algacide is used to control agae, bacteria, and fungli in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 6.13 to 15.32 fluid ounces of GC Algacide per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of GC Algacide. based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.53 to 15.32 fluid ounces of GC Algacide per 1000 gallons of water (12 to 120 parts per million of GC Algacide) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

GC Algacide is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of GC Algacide per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug and initial dosage until control is evident. of 16.9 to 41.2 fluid ounces of GC Algacide per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

STORAGE & DISPOSAL: Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal or cleaning of equipment. Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

- C METAL CONTAINERS: Triple C PLASTIC CONTAINERS: Do not rinse and offer for recycling, reconditioning, or disposal in an approved landfill or bury in a safe place.
  - reuse empty container, Triple rinse and incinerate or dispose of in an approved landfill or bury in safe place.

Manufactured by: Gold Coast Chemical, Inc.

pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

