

WEST C-111 MICROBIOCIDES

ACTIVE INGREDIENT

Polyoxyethylene (dimethyliminio) ethylene-
(dimethyliminio) ethylene dichloride

INERT INGREDIENT

40.0%

This product contains 5.76 lb. of active ingredient per gallon and weighs 9.6 lb. per gallon.

KEEP OUT OF REACH OF CHILDREN

CAUTION

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg white, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

ACCEPTED
43436-1
MAR 6 1980

BEST DOCUMENT AVAILABLE

**DIRECTIONS FOR USE
GENERAL CLASSIFICATION**

It is a violation of Federal law to use this product inconsistent with its labeling.

WEST C-111 is used to control algae, bacteria, and fungi in commercial and industrial water cooling towers. Prior to use, towers must be cleaned to remove algal growth, microbiological deposits. An initial slug addition of 0.9 to 2.2 fluid ounces per 1000 gallons of water to provide a concentration of 8 million of WEST C-111, based on the total weight of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 0.2 to 2.2 fluid ounces of WEST C-111 per 1000 gallons of water (2 to 20 parts per million) of WEST C-111 should be employed every 2 to 5 days or as needed. The frequency of slug additions should be based upon the relative amount of bleedoff and the severity of the problem. Slug additions should be made in the sump or to the water collection trays of the tower.

WEST C-111 is used to control bacteria in industrial systems that maintain effective mist eliminating cooling towers. Use systems should be cleaned to remove bacterial deposits. An initial slug dose of 3.33 to 5.55 fluid ounces of WEST C-111 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 2.0 to 5.75 fluid ounces of WEST C-111 per 1000 gallons of water should be employed every 2 to 5 days or as needed. The frequency of addition depends upon amount of bleedoff and severity of the bacterial problem. Slug additions should be made to the sump or to the water collection trays of the tower.

STORAGE & DISPOSAL: Keep container closed. Do not contaminate water, food, or feed by storage or cleaning of equipment. Do not reuse empty container (or equivalent) and dispose of container in a non-hazardous, approved landfill or bury in a safe place. Residuals and reprocessed should be disposed of in a non-hazardous landfill or buried in a safe place away from water. Dumping is prohibited.

Manufactured by
WATER & ENERGY SYSTEMS TECHNOLOGIES

139 West Victoria Street
Gardena, CA 90248

EPA REG. NO. 43436-1

EPA F

NET WEIGHT 50 LBS.