CHEMICALS CORP. CEPTED 4 36 15 960 CA COMPLETE ANT REPORT FE CON MULTURE ANT RECOMPLETE FE CON MULTURE ANT FE CON MULTUR

ACTIVE INGREDIENT Poly [oxyethylene (dimethyliminio) ethylene- (dimetnyliminio) ethylene dichloride]	15.0	٥/٥	
	85.0	٥/٥	

This product contains  $1 + \frac{34}{2}$  lb. of active ingredient per gallon and weighs  $8 + \frac{3}{2}$  lb. per gallon.

KEEP OUT OF REACH OF CHILDREN

## CAUTION

## PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

**CAUTION:** Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk. egg whites, gelatin solution, or. if these are not available drink large quantities of water. Avoid alcohol. Call a physician immediately.

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

## DIFECTIONS FOR USE GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner incon stutent with its labeling

QAC is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth. microbiological slime, and other deposits. An initial slug addition of 4.0 to 10.0 fluid ounces of QAC per 1000 gallons of water to provide a concentration of \_ 32 to 80 QAC parts per million of . based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident

Subsequent slug additions of 1.0 to 10.0 fluid ounces of QAC per 1000 gallons of water (\_\_\_\_\_\_\_\_ to 80 \_\_\_\_\_\_\_ parts per million of \_\_\_\_\_\_\_ QAC \_\_\_\_\_\_) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

QAC is used to control bacteria in industrial airwashing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits An initial slug dose of 14.8 to 24.7 QAC fluid ounces of per 1000 gallons of water is recommended. Repeat initial oosage until control is evident. Subse-24.7 10.1 quent slug additions of to fluid ounces of QAC per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleudoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

**STORAGE & DISPOSAL:** Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal, or cleaning of equipment. The container must be triple rinsed (or equivalent) and offered for recycling, reconditioning, or disposal in an approved landfill or buried in a safe place. Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

 Manufactured by:

 Damson Chemicals Corporation

 366 Madison Avenue

 New York New York 10017

 EPA REG NO.

 43687-1

 EPA REG NO.