

Progressive Products

# SPECTRO BLEND 2

44043-3

3614 East Pawnee  
Wichita, Kansas 67218  
(316) 685-9185

ACCEPTED  
44043-3  
JUL 3 1980  
The Federal Insecticide  
Fungicide and Fertilizer Act  
of 1947, as amended  
EPA Reg. No. 44043-3  
EPA Reg. No.



ACTIVE INGREDIENT

Polyoxyethylene (dimethyliminol) ethylene  
(dimethyliminol) ethylene dihydrochloride

INERT INGREDIENT

This product contains 5.53% active ingredient per gallon  
5.53 lb. per gallon

**KEEP OUT OF REACH OF CHILDREN**  
**CAUTION**

## DIRECTIONS FOR USE GENERAL CLASSIFICATION

Use the quantity of the following to use this product in a number of ways  
not with the label.

SPECTRO BLEND 2 is used to control algae, bacteria, and fungi in  
cooling towers, commercial and industrial water cooling towers. Prior to its  
use, systems must be cleaned to remove algal growth, microbiological  
slime, and other deposits. An initial application of 5.0 to 12.5 fluid ounces  
of SPECTRO BLEND 2 per 1000 gallons of water to provide a concentration  
of 40 to 100 parts per million of SPECTRO BLEND 2 based on the total  
weight of water in the system is recommended. Repeat initial dosage until  
control is evident.

Subsequent slug additions of 1.0 to 10 fluid ounces of SPECTRO  
BLEND 2 per 1000 gallons of water (10 to 100 parts per million of SPECTRO  
BLEND 2) should be employed every 2 to 5 days or as needed. The  
frequency of application depends upon the relative amount of bleedoff and the  
severity of the microbiological problem. Slug additions should be made in  
the sump of water cooling towers.

SPECTRO BLEND 2 is used to control bacteria in industrial air washing  
systems that utilize recirculating water and air compressors. Prior to its  
use, systems should be cleaned to remove bacterial slime and other  
deposits. An initial dosage of 2.5 to 25 fluid ounces of SPECTRO  
BLEND 2 per 100 gallons of water is recommended. Repeat initial dosage  
until control is evident. Subsequent slug additions of 1.44 to 5.63 fluid  
ounces of SPECTRO BLEND 2 per 100 gallons of water should be employed  
every 2 to 5 days or as needed. The frequency of application depends upon the  
severity of the microbiological problem. Slug additions should be made in  
the sump of air washing systems.