

THIS LABEL IS PRINTED IN ENGLISH

44185-2

Carlin Laboratories


P.O. Box 17591
Jacksonville, Florida 32216
Phone 904 733 3035

JUL 3 1980

Approved by the Federal Insecticide, Fungicide, and Rodenticide Administration for the purposes stated under EPA Reg. No.

FORMULA # M-82

When Water Becomes a Slave



ACTIVE INGREDIENTS
EPA REGISTRATION NO. 44185-2
NET WEIGHT 100 LBS

CAUTION

DIRECTIONS FOR USE

GENERAL CLASSIFICATION

Use only in accordance with the Federal Law to which this product is registered and in accordance with the labeling.

COOLING TOWERS CARLIN FORMULA M 82 - For the control of algae and bacteria in cooling towers. Apply a slug addition of 4.0 to 10.0 fluid ounces of CARLIN FORMULA M 82 per 1000 gallons of water to the cooling tower. Repeat the slug addition of 4.0 to 10.0 fluid ounces of CARLIN FORMULA M 82 per 1000 gallons of water to the cooling tower every 7 to 14 days or as needed. The system should be checked for the amount of bleed off and the amount of water added to the system.

AIR WASHING SYSTEMS CARLIN LAB'S CARLIN FORMULA M 82 - For the control of algae and bacteria in air washing systems. Apply a slug addition of 4.0 to 10.0 fluid ounces of CARLIN FORMULA M 82 per 1000 gallons of water to the air washing system. Repeat the slug addition of 4.0 to 10.0 fluid ounces of CARLIN FORMULA M 82 per 1000 gallons of water to the air washing system every 7 to 14 days or as needed. The system should be checked for the amount of bleed off and the amount of water added to the system.