

# IWE 6030 C

**ACCEPTED**  
 44220-2  
 SEP 25 1980  
 Under the Federal Insecticide,  
 Fungicide and Rodenticide Act,  
 as amended, for the pesticide  
 registered under  
 EPA Reg. No.

### ACTIVE INGREDIENT

Poly[oxyethylene (dimethyliminio) ethylene  
 (dimethyliminio) ethylene dichloride] ..... 30.0%

INERT INGREDIENT ..... 70.0%

This product contains 2.67lb of active ingredient per gallon and weighs 8.9lb per gallon


**KEEP OUT OF REACH OF CHILDREN  
 CAUTION**

**PRECAUTIONARY STATEMENTS  
 HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

**CAUTION.** Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

**FIRST AID.** If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds or public water. For guidance, contact the regional office of the Environmental Protection Agency.



*Meta*

**DIRECTIONS FOR USE  
 GENERAL CLASSIFICATION**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

**IWE 6030 C** is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 1.90 to 4.75 fluid ounces of **IWE 6030 C** per 1000 gallons of water to provide a concentration of 16 to 40 parts per million of **IWE 6030 C**, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 0.47 to 4.75 fluid ounces of **IWE 6030 C** per 1000 gallons of water (4 to 40 parts per million of **IWE 6030 C**) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers. **IWE 6030 C** is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 7.1 to 11.9 fluid ounces of **IWE 6030 C** per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 4.8 to 11.9 fluid ounces of **IWE 6030 C** per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

**STORAGE & DISPOSAL** Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal, or cleaning of equipment. The container must be triple rinsed (or equivalent) and offered for recycling, reconditioning, or disposal in an approved landfill or buried in a safe place. Rinse that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

USE THIS LABEL FOR METAL CONTAINERS

Manufactured by:  
 INDUSTRIAL WATER ENGINEERING, INC  
 P O Box 13536  
 Alt. Albuquerque, NM 87192

19

EPA REG NO 44220-2      EPA EST NO 44220-NM-01

NET CONTENTS

BEST DOCUMENT AVAILABLE