



564

KEEP OUT OF REACH OF CHILDREN
DANGER

PRACTICAL TREATMENT (FIRST AID)
If swallowed: Do not induce vomiting. Give 1-2 glasses of water by olive oil or cooking oil. Get medical attention immediately.
If on skin: Brush off excess. Flush area with skin with cold water for at least 15 minutes. If irritation persists, get medical attention.
If in Eyes: Flush with cold water for at least 15 minutes. Get medical attention.

PHYSICAL AND CHEMICAL HAZARDS
STRONG OXIDIZING AGENT

Agent: Mix only with water. Do not use clean, dry, or wet surfaces. Do not use product for any purpose not intended. Do not use remnants of any other product in this container. Cause: A violent reaction may occur on exposure to contamination with organic matter. Caution: Do not mix with other chemical reactions with generation of hazardous gases. Do not use for generation of fire and explosion. Contamination: Decomposition of residual container if possible as they may be in operation. Wash and dry thoroughly. Large quantities of water should be used.

PRECAUTIONARY STATEMENTS
HAZARDOUS TO HUMANS
AND DOMESTIC ANIMALS

DANGER: Irritant to eyes, skin, and respiratory tract. May cause severe eye irritation. Avoid contact with eyes, skin, and clothing. Wash thoroughly with soap and water. If irritation persists, get medical attention.

ENVIRONMENTAL HAZARDS
This product is highly toxic to aquatic life. Do not discharge into water bodies. Use only in closed systems. Do not use in areas where it may be in contact with plants or animals.

STORAGE AND DISPOSAL
Store in a cool, dry place. Do not store in areas where it may be in contact with plants or animals. Do not use in areas where it may be in contact with plants or animals. Do not use in areas where it may be in contact with plants or animals.

DIRECTIONS FOR USE: Use control of microbial organisms in recirculating cooling water towers and evaporating condensors.

INITIAL TREATMENT: Place 0.1 to 1.0 lbs of 564 per 1000 gals. of water in the sump of a cooling tower in an area of constant water flow. Repeat daily until fouling is controlled.

CONTINUOUS TREATMENT: Replenish the supply each day. Use rate will depend on the severity of the fouling. Normal dosages will range from 0.1 to 1.0 lbs. per 1000 gals. of water contained in a system.

INTERMITTENT TREATMENT: Use the product at 0.1 to 1.0 lbs. per 1000 gals. of water contained in the system on alternating days.

ACTIVE INGREDIENT:
Tri-Nitro-s-triazinetrioxide 99%
Available Chlorine 89%
Inert ingredients 1%

REG. NO. 45723-7 UNCL. NO. 45723

Manufactured by Hydro Dynamics, Shillington, Pa. 19607