

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS
AND DOMESTIC ANIMALS**

DANGER: Highly Corrosive. Causes skin and eye damage. May be fatal if swallowed. Do not get in eyes, on skin or on clothing. Wear goggles or face shield and rubber gloves when handling. Irritating to nose and throat. Avoid breathing dust. Remove and wash contaminated clothing before reuse.

ENVIRONMENTAL HAZARDS: This product is toxic to fish. Do not discharge into lakes, streams, ponds, or public waters unless in accordance with an NPDES Permit. For guidance contact the regional office of EPA.

PHYSICAL & CHEMICAL HAZARDS
STRONG OXIDIZING AGENT: Strong Oxidizing Agent. Mix only with water. Use clean dry utensils. Do not add this product to any dispensing device containing remnants of any other product. Such use may cause a violent reaction leading to fire or explosion. Contamination with moisture, organic matter, or other chemicals may start a chemical reaction, with generation of heat, liberation of hazardous gases, and possible generation of fire and explosion. In case of contamination or decomposition, do not reseal container. If possible isolate container in open air or well ventilated area. Flood with large volumes of water, if necessary.

A LATEN 3515 TABLET
WEIGHS 7 OZ.

NET CONTENTS

E.P.A. Reg. No. 46616-5
E.P.A. Est. No. 46616-IL-C1

LATEN 3515

ACTIVE INGREDIENT:
*Trichloro-s-triazinetrione 99.0%
INERT INGREDIENTS: 1.0%
*Available Chlorine: 89%

DANGER KEEP OUT OF REACH OF CHILDREN

PRACTICAL TREATMENT: (FIRST AID): If swallowed feed bread soaked in milk followed by olive oil or cooking oil. Call a physician immediately.

If on skin: Brush off excess chemical and flush skin with cold water for at least 15 minutes. If irritation persists, get medical attention.

If in Eyes: Flush with cold water for at least 15 minutes. Get medical attention.

SEE ADDITIONAL PRECAUTIONS ON SIDE PANEL

46616-5
Laten Chemical

P.O. Box 264
Palatine, IL 60078

DIRECTIONS FOR USE IN COOLING TOWERS

It is a violation of Federal law to use this product in a manner inconsistent with its labeling

INITIAL APPLICATION: Prior to the use of Laten 3515, systems should be cleaned to remove microbiological residues, dirt, and other environmental debris. Then add an initial dose of 1-2 tablets (0.4 - 0.9 lbs.) per 1000 gallons system water. Repeat the dosage as often as necessary to maintain a free chlorine residual of at least 1.0 ppm for four hours.

It is recommended that Laten 3515 tablets be added to a corrosion resistant dissolving basket, or similar device, suspended in the cooling tower basin or sump at the point of greatest turbulence.

SUBSEQUENT APPLICATION: After microbiological control is evident, add 1/2 - 1 tablet (0.2 - 0.4 lbs.) per 1000 gallons system water. Repeat the dosage as often as necessary to maintain a free chlorine residual of at least 1.0 ppm for four hours. The frequency of addition depends upon the amount of system bleed-off and the severity of the microbiological problem. Most systems, however, should be treated 2 - 4 times per week.

It is recommended that Laten 3515 tablets be added to a corrosion resistant dissolving basket, or similar device suspended in the cooling tower basin or sump at the point of greatest turbulence.

STORAGE AND DISPOSAL: Keep product dry in tightly closed container when not in use. Store in a cool, dry, well ventilated area away from heat or open flame. In case of decomposition isolate container, if possible, and flood with large amounts of water to dissolve all material before discarding. Place in trash collection or dispose in approved landfill area, or bury in a safe place.