

PM 32 54679-3 2-18-98 10/2
US ENVIRONMENTAL PROTECTION AGENCY
OFFICE OF PESTICIDES PROGRAMS
REGISTRATION DIVISION (75-767)
WASHINGTON, DC 20460

EPA REGISTRATION NO.

54679-3

DATE OF ISSUANCE

FEB 18 1998

TERM OF ISSUANCE

NAME OF PESTICIDE PRODUCT

Custom Chlor 200

NOTICE OF PESTICIDE: REGISTRATION
 REREGISTRATION

(Under the Federal Insecticide, Fungicide,
and Rodenticide Act, as amended)

NAME AND ADDRESS OF REGISTRANT (Include ZIP code)

Custom Controls & Pumps, Inc.
P. O. Drawer 490
Silver Springs, Fl 34489-0513

NOTE: Changes in labeling formula differing in substance from that accepted in connection with this registration must be submitted to and accepted by the Registration Division prior to use of the label in commerce. In any correspondence on this product always refer to the above U.S. EPA registration number.

On the basis of information furnished by the registrant, the above named pesticide is hereby Registered/Reregistered under the Federal Insecticide, Fungicide, and Rodenticide Act.

A copy of the labeling accepted in connection with this Registration/Reregistration is returned herewith.

Registration is in no way to be construed as an indorsement or approval of this product by this Agency. In order to protect health and the environment, the Administrator, on his motion, may at any time suspend or cancel the registration of a pesticide in accordance with the Act. The acceptance of any name in connection with the registration of a product under this Act is not to be construed as giving the registrant a right to exclusive use of the name or to its use if it has been covered by others.

This product is conditionally registered in accordance with FIFRA section 3(c)(7)(A) provided that you:

1. Submit and/or cite all data required for registration/reregistration of your product under FIFRA section 3(c)(5) and section 4 when the Agency requires all registrants to similiar products to submit such data.
2. Add the phrase "EPA Registration No. 54679-3" to your label before you release the product for shipment.
3. Submit one copy of your final printed labeling before you release the product for shipment. Refer to the A-79 Enclosure for a further description of final printed labeling.

A stamped copy of the label is enclosed for your records.

If these conditions are not complied with, the registration will be subject to cancellation in accordance with FIFRA section 6(e). Your release for shipment of the product consititutes acceptance of these conditions.

Robert S. Brennis
Product Manager (32)
Antimicrobial Program Branch
Regulatory Division (7504C)

ATTACHMENT IS APPLICABLE

SIGNATURE OF APPROVING OFFICIAL

DATE

CUSTOM CHLOR-200

CHLORINATING SOLUTION

ACTIVE INGREDIENT:

SODIUM HYPOCHLORITE	12.5%
INERT INGREDIENTS	87.5%
	100%

KEEP OUT OF REACH OF CHILDREN DANGER

STATEMENT OF PRACTICAL TREATMENT (FIRST AID) IF CONTACT WITH EYES, flush with water for at least 15 minutes. Get prompt medical attention.

IF CONTACT WITH SKIN OCCURS, wash with plenty of soap and water.

IF SWALLOWED, drink large amounts of water. DO NOT induce vomiting. Call a physician or poison control center immediately.

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS DANGER

Corrosive, may cause severe skin irritation or chemical burns to broken skin. Causes eye damage. May be fatal if swallowed. Avoid breathing vapors. Do not get in eyes, on skin or on clothing. Wear goggles or face shield and rubber gloves when handling this product. Wash hands after handling. Vacate poorly ventilated areas as soon as possible. Do not return until odors have dissipated.

ENVIRONMENTAL HAZARDS

This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or public waters unless product is specifically identified and addresses in an NPDES permit. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance contact you State Water Board or Regional Office of the EPA.

PHYSICAL OR CHEMICAL HAZARDS

STRONG OXIDIZING AGENT. Mix only with water according to label directions. Mixing this product with chemicals (e.g. ammonia, acids, detergents, etc.) or organic matter (e.g. urine, feces, etc.) will release chlorine gas which is irritating to eyes, lungs, and mucous membranes.

DIRECTIONS FOR USE

It is a violation of federal law to use this product in a manner inconsistent with its labeling.

NOTE: This product degrades with age. Use a chlorine test kit and increase dosage, as necessary, to obtain the required level of available chlorine.

SWIMMING POOL WATER DISINFECTION

For a new pool or spring start-up, superchlorinate with 54 to 108 oz. of product for each 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Check the level of available chlorine with a test kit. Adjust and maintain pool water pH to between 7.2 to 7.6. Adjust & maintain the alkalinity of the pool to between 50 to 100 ppm.

To maintain the pool, add manually or by a feeder device 12 oz. of this product for each 10,000 gallons of water to yield an available chlorine residual between 0.6 to 1.0 ppm by weight. Stabilized pools should remain a residual of 1.0 to 1.5 ppm available chlorine. Test the pH, available chlorine residual and alkalinity of the water frequently with appropriate test kits. Frequency of water treatment will depend upon temperature and number of swimmers.

Every 7 days, or as necessary, superchlorinate the pool with 54 to 108 oz. of product for each 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Check the level of available chlorine with a test kit. Do not re-enter pool until the chlorine residual is between 1.0 to 3.0 ppm.

At end of the swimming season, or when water is to be drained from the pool, chlorine must be allowed to dissipate from treated pool water before discharge. Do not chlorinate the pool within 24 hours prior to discharge.

DISINFECTION OF WASTEWATER TREATMENT

The disinfection of sewage effluent must be evaluated by determining the total number of coliform bacteria and/or fecal coliform bacteria, as determined by the MPN procedure, of the chlorinated effluent has been reduced to or below the maximum permitted by the Controlling Regulatory Jurisdiction.

Successful disinfection is extremely dependent on response to fluctuating chlorine demand to maintain a predetermined, desirable chlorine level. Secondary effluent should contain 0.5 to 1.0 ppm Chlorine residual after a 15 to 30 minute contact time. A reasonable average of residual chlorine is 8.0 ppm after 15 minutes contact time.

DISINFECTION OF POTABLE WATER TREATMENT FACILITIES

Dilute this sodium hypochlorite solution in the ratio of one part sodium hypochlorite to 9 parts softened water. Mix sodium hypochlorite solution and water thoroughly and begin feeding of solution with hypochlorinator (metering pump). Maintain a free available chlorine residual of at least 0.2 ppm and no more than 0.6 ppm throughout the distribution system, as determined by a DPD chlorine test kit. Bacteriological sampling must be conducted at a frequency no less than that prescribed by the National Interim Primary Drinking Water Regulations. *Check water frequently with a DPD chlorine test kit. *Contact your local Health Department for further details.

SANITIZING FOOD PROCESSING OR DAIRY EQUIPMENT

Clean equipment in the normal manner. Just before using, rinse all surfaces thoroughly with this sodium hypochlorite solution containing 200 ppm available chlorine. Maintain contact with disinfectant for a minimum of two minutes. Allow to air dry. Do not rinse with water after treatment with sodium hypochlorite solution. Do not soak overnight. Addition of one fluid oz. (2 tbsps.) of this sodium hypochlorite solution per 4 gallons of water will provide approximately 200 ppm available chlorine by weight.

NOTE: This product degrades with age. Use a chlorine test kit and increase dosage, as necessary, to obtain the required level available chlorine.

STORAGE AND DISPOSAL

Store this product in a cool dry area, away from direct sunlight and heat to avoid deterioration. In case of spill, flood areas with large quantities of water. Product or rinsates that cannot be used should be diluted with water before disposal in a sanitary sewer. Do not reuse container but place in trash collection. Do not contaminate food or feed by storage, disposal or cleaning equipment.

Distributed by:

CUSTOM CONTROLS & PUMPS, INC.

1521 N. Magnolia Ave. • Ocala, FL 34475-9082

Ph. (352) 622-9244

1-800-537-9633

EPA Reg. No. 54679-1

EPA Est. No. 54679 -FL-001

NET CONTENTS: 2.5 GALLONS

