

PM 32

5-27-9

1754-12
1752-16
1554-30

OKAY COOLING TOWER ALGAECIDE is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove scale growth, microbiological slime and other deposits. An initial slug addition of 4.0 to 10.0 fluid ounces of **OKAY COOLING TOWER ALGAECIDE** per 1000 gallons of water to provide a concentration of 32 to 80 parts per million of **OKAY COOLING TOWER ALGAECIDE** based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 1.0 to 10.0 fluid ounces of **OKAY COOLING TOWER ALGAECIDE** per 1000 gallons of water (8 to 80 parts per million of **OKAY COOLING TOWER ALGAECIDE**) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bio-film and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling tower.

1407 HARNEY

COOLING TOWER ALGAECIDE

Active Ingredient:	Percent by Weight
Poly (oxyethylene)(dimethyliminio) ethylene (dimethyliminio) ethylene dichloride)	15.0%
Inert Ingredient:	85.0%

TOTAL 100.0%

Weight per gallon 8.58 pounds
Weight of active
ingredient per gallon 1.29 pounds

CAUTION:
KEEP OUT OF REACH OF CHILDREN
See back panel for additional cautions.

Manufactured For
Levenson CHEMICAL CO.

OMAHA, NEBRASKA

UNDER THE FEDERAL INSECTICIDE ACT
FUNGICIDE AND FUNGICIDE ACT
FOR ECONOMIC PEST CONTROL
EPA REG. NO. 12-954-30

Harmful if swallowed. **DO NOT** get in eyes. Avoid contact with skin. In case of contact, flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. **DO NOT** contaminate water by cleaning of equipment or disposal of wastes. Use only as directed on label.

DO NOT re-use empty drum.

Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place.

Contents 1 gallon

E. P. A. Registration 9554-30