

59026-1

PM32 . 1061

AQUA TREAT B-1

ACCEPTED

59026-1

MAR 14 1989

UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTERED
ED UNDER NO. _____ SUBJECT
TO ATTACHED COMMENTS.

ACTIVE INGREDIENT:

Poly(cxyethylene (dimethyliminio) ethylene-
(dimethyliminio) ethylene dichloride) 10.0 %

INERT INGREDIENT 90.0 %

This product contains 0.85 lb. of active ingredient per gallon and weighs
8.49 lb. per gallon.

KEEP OUT OF REACH OF CHILDREN

CAUTION

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

DIRECTIONS FOR USE
GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

AQUA TREAT B-1 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 6.13 to 15.32 fluid ounces of AQUA TREAT B-1 per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of AQUA TREAT B-1, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.53 to 15.32 fluid ounces of AQUA TREAT B-1 per 1000 gallons of water (12 to 120 parts per million of AQUA TREAT B-1) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

AQUA TREAT B-1 is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of AQUA TREAT B-1 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of AQUA TREAT B-1 per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

STORAGE AND DISPOSAL

Do not contaminate water, food, or feed by storage or disposal.

STORAGE: Do not stack more than four drums high. Leaking or damaged drums should be placed in separate drums for disposal. Spills should be absorbed in sawdust or sand and disposed of in a sanitary landfill. Keep container closed when not in use.

PESTICIDE DISPOSAL: Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

CONTAINER DISPOSAL:

PLASTIC: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, by incineration, or, if allowed by state and local authorities, by burning. If burned, stay out of smoke.

METAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

Manufactured by:

L.S. SOLUTIONS, INC.

8607 MOSLEY

HOUSTON, TX 77075

EPA REG. NO. _____

EPA EST. NO. _____

NET CONTENTS _____