

59074-20001

6/19/2012

1 of 4



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON D C 20460

June 19, 2012

OFFICE OF CHEMICAL SAFETY
AND POLLUTION PREVENTION

Mr Kenneth Birchenough, Chemical Engineer
Slack Chemical Company, Inc
465 S Clinton Street
Post Office Box 30
Carthage, NY 13619

Subject Notification per PR Notice 98-10
Product **Superchlor**
EPA Registration Number **59074-20001**
Application Date May 31, 2012
Application Receipt June 6, 2012

Dear Mr Birchenough

This acknowledges receipt of the above Notification application, submitted under the provision of PR notice 98-10, FIFRA 3(c) 9

Proposed Notification

Slack Chemical Company is initiating the following supplemental labeling for "Sanitation of Nonporous Food Contact Surfaces Clean-In-Place Method "

"CLEAN-IN-PLACE METHOD - Thoroughly clean equipment after use Prepare a volume of a 200 ppm available chlorine sanitizing solution equal to 110 % of volume capacity of the equipment by mixing the product in a ratio of 2 oz product with 10 gallons of water Pump solution through the system until full flow is obtained at all extremities, the system is completely filled with the sanitizer and all air is removed from the system Close drain valves and hold under pressure for at least 10 minutes to ensure contact with all internal surfaces Remove some cleaning solution from drain valve and test with a chlorine test kit Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine "

General Comments

Based on a review of the material submitted, the following comment applies


The Notification application is **acceptable** A copy of the **accepted** Notification has been inserted in your file (**EPA Reg No 59074-20001**) for future reference

2014

-2-

If you have any questions or comments concerning this letter, please contact Killian Swift via email at swift.killian@epa.gov or by telephone at 703-308-6346 during the hours of 5 00 AM until 12 00 PM Eastern Daylight Time

Sincerely,



Mohisha Harris,
Product Manager 32
Regulatory Management Branch II
Antimicrobials Division (7510P)

3094

Please read instructions on reverse before completing form

Form Approved

OMB No 2070-0060



United States
Environmental Protection Agency
Washington DC 20460

<input type="checkbox"/>	Registration
<input type="checkbox"/>	Amendment
<input checked="" type="checkbox"/>	Other

OPP Identifier Number

Application for Pesticide - Section I

1 Company/Product Number 59074 20001	2 EPA Product Manager Monisha Harris	3 Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4 Company/Product (Name) SUPERCHLOR	PM# 32	
5 Name and Address of Applicant (Include ZIP Code) Slack Chemical Co Inc 465 S Clinton St PO Box 30 Carthage NY 13619 <input type="checkbox"/> Check if this is a new address	6 Expedited Review In accordance with FIFRA Section 3(c)(3) (b)(i) my product is similar or identical in composition and labeling to EPA Reg No 72315 6 Product Name Sodium Hypochlorite 12.5 Bacticide	

Section - II

<input type="checkbox"/> Amendment Explain below	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> "Me Too" Application
<input checked="" type="checkbox"/> Notification Explain below	<input type="checkbox"/> Other Explain below

Explanation Use additional page(s) if necessary (For section I and Section II)
Supplemental labeling for Sanitation of Nonporous Food Contact Surfaces Clean In Place Method directions for use

Section - III

1 Material This Product Will Be Packaged In				2 Type of Container	
Child Resistant Packaging <input type="checkbox"/> Yes* <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Metal	<input type="checkbox"/> Plastic
* Certification must be submitted		If "Yes" Unit Packaging wgt	No per container	If "Yes" Package wgt	No per container
				<input type="checkbox"/> Glass	<input type="checkbox"/> Paper
				<input type="checkbox"/> Other (Specify) _____	
3 Location of Net Contents Information <input type="checkbox"/> Label <input type="checkbox"/> Container		4 Size(s) Retail Container		5 Location of Label Directions <input type="checkbox"/> On Label <input type="checkbox"/> On Labeling accompanying product	
6 Manner in Which Label is Affixed to Product		<input type="checkbox"/> Lithograph <input type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled		<input type="checkbox"/> Other _____	

Section - IV

1 Contact Point (Complete items directly below for identification of individual to be contacted if necessary to process this application)		
Name Kenneth Birchenough	Title Chemical Engineer	Telephone No (Include Area Code) (315) 493 0430
Certification I certify that the statements I have made on this form and all attachments thereto are true accurate and complete I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law		Date Application Received (Stamp)
2 Signature 	3 Title Chemical Engineer	
4 Typed Name Kenneth Birchenough	5 Date May 31 2012	

SUPPLEMENTAL LABEL ONLY

SUPERCHLOR

EPA Reg No 59074-20001

DIRECTIONS OF USE

It is a violation of federal law to use this product in a manner inconsistent with its labeling. This labeling must be in the possession of the user at the time of application. Follow all applicable directions, restrictions, and precautions on the product label.

SANITIZATION OF NONPOROUS FOOD CONTACT SURFACES

CLEAN-IN-PLACE METHOD – Thoroughly clean equipment after use. Prepare a volume of a 200 ppm available chlorine sanitizing solution equal to 110% of volume capacity of the equipment by mixing the product in a ratio of 2 oz. product with 10 gallons of water. Pump solution through the system until full flow is obtained at all extremities. The system is completely filled with the sanitizer and all air is removed from the system. Close drain valves and hold under pressure for at least 10 minutes to insure contact with all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine.

cc
cccc
cccc
cc
cccc
cccc
cccc
cccc
cccc
cccc
cccc
cccc
cccc