



U.S. ENVIRONMENTAL PROTECTION
AGENCY

Office of Pesticide Programs
Antimicrobials Division (7510P)
1200 Pennsylvania Avenue NW
Washington, D.C. 20460

NOTICE OF PESTICIDE:

Registration
 Reregistration

(under FIFRA, as amended)

EPA Reg.
Number:

59106-6

Date of
Issuance:

June 3, 2008

Term of Issuance:

UnConditional

Name of Pesticide Product:

BIO-CLEAR 2000

Name and Address of Registrant (include ZIP Code):

Clearwater International, LLC
515 Post Oak Blvd., Ste., 600
Houston, TX 77027

Note: Changes in labeling differing in substance from that accepted in connection with this registration must be submitted to and accepted by the Registration Division prior to use of the label in commerce. In any correspondence on this product always refer to the above EPA registration number.

On the basis of information furnished by the registrant, the above named pesticide is hereby registered/reregistered under the Federal Insecticide, Fungicide and Rodenticide Act.

Registration is in no way to be construed as an endorsement or recommendation of this product by the Agency. In order to protect health and the environment, the Administrator, on his motion, may at any time suspend or cancel the registration of a pesticide in accordance with the Act. The acceptance of any name in connection with the registration of a product under this Act is not to be construed as giving the registrant a right to exclusive use of the name or to its use if it has been covered by others.

This product [OPP Decision Number: D-388681] is unconditionally registered in accordance with FIFRA sec 3(c)(5) provided that you:

1. Submit and/or cite all data required for registration of your product under FIFRA sec. 3(c)(5) when the Agency requires all registrants of similar products to submit such data; and submit acceptable responses required for re-registration of your product under FIFRA section 4.
2. Make the labeling changes listed below before you release the product for shipment:
 - a. Revise the "EPA Registration Number to read, "EPA Reg. No. 59106-6".

Signature of Approving Official:


Adam Heyward
Product Manager Team-34
Regulatory Management Branch II
Antimicrobials Division (7510P)

Date:

June 3, 2008

b. The following statement must be added to the precautionary statement "This product may cause skin sensitization reactions in some people."

c. Change the other bacteria to read "bacteria."

d. Add the following inhalation statement to the first aid statement:

If inhaled:

- Move person to fresh air.
- If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to-mouth if possible.
- Call a poison control center or doctor for further treatment advice.

e. Revise the emergency information section of the first aid statement to read as follows:

- Have the product container or label with you when calling a poison control center or doctor or going for treatment.
- For emergency information, call the **National Pesticides Information Center** at 1-800-858-7378, 6:30 AM to 4:30 PM Pacific time (PT), seven days a week. During other times, call the poison control center 1-800-222-1222.

3. The OPPTS, 830.6317 (Storage and Stability) and OPPTS 830.6320 (Corrosion Characteristics) data must be submitted to EPA.

4. Submit three (3) copies of your final printed labeling before distributing or selling the product bearing the revised labeling.

If these conditions are not complied with, the registration will be subject to cancellation in accordance with FIFRA sec. 6(e). Your release for shipment of the product constitutes acceptance of these conditions.

The Agency is moving away from review of paper submitted registration applications to electronic review of applications. Therefore, we need your help to make this an efficient and convenient process for both you and the Antimicrobials Division. Accordingly, we are asking you to submit future labeling amendments for this product via the electronic labeling process. Refer to the following website for guidance on electronic submissions, including label: <http://www.epa.gov/pesticides/regulating/registering/submissions/index.htm>. If you have questions concerning electronic labeling, a list of contacts is available at the following site: <http://www.epa.gov/oppfead1/eds/edsgoals.htm#contacts>

A stamped copy of the label is enclosed for your records.

Sincerely,



Adam Heyward
Product Manager 34
Regulatory Branch II
Antimicrobials Division (7510P)

Enclosure: (Stamped approved label)

3 8 11

BIO-CLEAR 2000

Controls coliform and other bacteria in publicly-owned treatment works; controls bacteria, fungi and yeasts in paper mills, metalworking fluids containing water, and enhanced oil recovery systems; controls bacteria, fungi, and algae in industrial recirculating water cooling towers, once-through fresh and sea water industrial cooling water systems, and reverse osmosis systems; controls slime-forming bacteria and fungi in air-washer systems.

Reduces microbial contamination in process water, raw materials and formulated consumer, institutional and industrial products. Reduces microbial contamination in wastewater, recycled process water, recycled products, recycled wastewater and equipment cleaning operations.

FOR INDUSTRIAL USE ONLY

Active Ingredients:	
2-2-Dibromo-3-nitrilopropionamide	20%
Other Ingredients.....	80%
Total:	100%

KEEP OUT OF REACH OF CHILDREN

DANGER

Manufactured [by][for]:
Clearwater International, LLC
515 Post Oak Blvd., Ste. 600
Houston, TX 77027

EPA Reg. No.: 59106-__
EPA Est. No.:
NET WEIGHT: _____ POUND (S)

ACCEPTED
with COMMENTS
in EPA Letter Dated:
JUN - 3 2008

Under the Federal Insecticide,
Fungicide, and Rodenticide Act as
amended, for the pesticide,
registered under EPA Reg. No. 59106-6

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

Danger. Corrosive. Causes irreversible eye damage or skin burns. Do not get on eyes or on clothing. May cause loss of vision. Fatal if absorbed through skin. Harmful if swallowed or inhaled. Avoid breathing vapor. Wear goggles or face shield (safety glasses). Wear protective clothing (long sleeve shirt and long pants, socks plus shoes and chemical resistant gloves such as waterproof gloves). Wash thoroughly with soap and water after handling and before eating, drinking, or using tobacco. Remove contaminated clothing and wash before reuse.

FIRST AID

IF IN EYES:

- Hold eye open and rinse slowly and gently with water for 30 minutes.
- Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye.
- Call a poison control center or doctor for treatment advice.

IF ON SKIN OR CLOTHING:

- Take off contaminated clothing.
- Rinse skin immediately with plenty of water for 15 – 20 minutes.
- Call a poison control center or doctor for treatment advice.

IF SWALLOWED:

- Call a poison control center or doctor immediately for treatment advice.
- Have person sip a glass of water if able to swallow.
- Do not induce vomiting unless told to do so by the poison control center or doctor.
- Do not give anything by mouth to an unconscious person.

Have the product container or label with you when calling a poison control center or doctor or going for treatment.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage.

ENVIRONMENTAL HAZARDS

This pesticide is toxic to fish and aquatic organisms. Apply this product only as specified on this label. Do not contaminate water by cleaning of equipment, or disposal of wastes. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other water unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

PHYSICAL AND CHEMICAL HAZARDS

Incompatible with potassium permanganate and powdered iron.

PERSONAL PROTECTIVE EQUIPMENT

Applicators and other handlers must wear

- coveralls over, long-sleeved shirt and long pants
- socks and chemical resistant footwear
- goggles or face shields
- chemical-resistant gloves (such as barrier laminate, butyl rubber, polyvinyl chloride or Viton)
- For mixing/loading: wear a chemical resistant apron.

Follow manufacturers' instructions for cleaning and maintaining PPE. If no such instructions exist for washables, use detergent and hot water. Keep and wash PPE separately from other laundry

USER SAFETY RECOMMENDATIONS

Users must wash hands before eating, drinking, chewing gum or using the toilet. Users must remove clothing immediately if pesticide gets inside. Then wash thoroughly and put on clean clothing. Users must remove PPE immediately after handling this product. Wash the outside of the gloves before removing. As soon as possible wash thoroughly.

GENERAL PRECAUTIONS AND RESTRICTIONS

Do not apply this product directly in a way that will contact workers or other persons.

DIRECTIONS FOR USE

It is a violation of Federal Law to use this product in a manner inconsistent with the labeling.

NOTE: Add **BIO-CLEAR 2000** separately to the system. Do not mix it with other additives, in order to avoid decomposition of **BIO-CLEAR 2000** due to the high pH of many additive formulations.

PAPER MILLS

For the control of bacterial, fungal and yeast growths in pulp, paper and paperboard mills, add **BIO-CLEAR 2000** at the rate of 0.15-0.50 lb per ton of pulp or paper (dry basis). Addition may be continuous or intermittent, depending upon the type of system and the severity of contamination. It should be made with a metering pump at a location that will insure uniform distribution of **BIO-CLEAR 2000** in the mass fiber and water, such as the beaters, jordan inlet or discharge, broke chests, furnish chests, save-alls, and white-water tanks.

HEAVILY FOULED SYSTEMS should be boiled out, then treated with 0.15-0.35 lb of **BIO-CLEAR 2000** per ton of paper (dry basis), as necessary for control.

MODERATELY FOULED SYSTEMS should be treated continuously with 0.35-0.50 lb of **BIO-CLEAR 2000** per ton of paper (dry basis) until the slime accumulation is controlled. Addition rates can then be reduced to 0.15-0.35 lb of **BIO-CLEAR 2000** per ton of paper on a continuous or intermittent basis, as needed for control. Dislodged slime may cause breaks in the paper and a clean-up of the paper machine may be advisable.

SLIGHTLY FOULED SYSTEMS should be treated continuously with 0.15-0.35 lb of **BIO-CLEAR 2000** per ton of paper (dry basis) until the slime is controlled, then added on an intermittent basis to maintain control.

METALWORKING FLUIDS CONTAINING WATER

This product is effective in metalworking fluid concentrates which have been diluted in water at ratios 1:100-1:4. For controlling (or inhibiting) the growth of bacteria, fungi, and yeasts that may deteriorate metalworking fluids containing water, add **BIO-CLEAR 2000** to the fluid in the collection tank. Additions should be made with a metering pump.

INITIAL OR SLUG DOSE: When the system is just noticeably fouled, add 0.25 gal of **BIO-CLEAR 2000** per 1,000 gal of metalworking fluid to the system. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 0.1-0.2 gal of **BIO-CLEAR 2000** per 1,000 gal of metal working fluid per day, or as needed to maintain control. Additions can be made continuously or intermittently. Slug the system as required.

ENHANCED OIL RECOVERY SYSTEM

For controlling slime-forming bacteria, sulfide-producing bacteria, yeasts and fungi in oil field water, polymer or micellar floods, water-disposal systems, or other oil field water systems add 1-80 ppm **BIO-CLEAR 2000** (0.1-6.4 gal of **BIO-CLEAR 2000** per 2400 barrels of water) depending on the severity of contamination. Additions should be made with a metering pump either continuously or intermittently.

CONTINUOUS FEED METHOD

When the system is noticeably fouled, add 10-80 ppm **BIO-CLEAR 2000** (0.8-6.4 gal of **BIO-CLEAR 2000** per 2400 barrels of water) continuously until the desired degree of control is achieved. Subsequently, treat with 1-15 ppm **BIO-CLEAR 2000** (0.1-1.2 gal of **BIO-CLEAR 2000** per 2400 barrels of water) continuously or as needed to maintain control.

INTERMITTENT OR SLUG METHOD

When the system is noticeably fouled, or to maintain control of the system, add 10-80 ppm **BIO-CLEAR 2000** (0.8-6.4 gal of **BIO-CLEAR 2000** per 2400 barrels of water) intermittently for 4-8 hours per day, and from 1-4 times per week, or as needed depending on the severity of contamination.

Addition of **BIO-CLEAR 2000** may be made at the free water knockouts, before or after the injection pumps and injection well headers.

NOTE: FOR CONTROL OF BACTERIA, YEAST AND FUNGI IN AQUEOUS SOLUTIONS OF BIOPOLYMER USED IN FLOODING OPERATIONS, add 15-80 ppm **BIO-CLEAR 2000** (1.2-6.4 gal of **BIO-CLEAR 2000** per 2400 barrels of water). Additions of **BIO-CLEAR 2000** should be made with a metering pump immediately after preparation of the aqueous biopolymer solution to prevent loss of viscosity.

INDUSTRIAL RECIRCULATING WATER COOLING TOWERS

Add **BIO-CLEAR 2000** to the basin (or any other point of uniform mixing). Additions should be made with a metering pump; it may be continuous or intermittent, depending on the severity of the contamination when the treatment has begun, and the retention time of the system.

Optimum performance with this product is attained by continuous or intermittent treatment. If "shock" treatment is used, the blowdown should be discontinued for 24-48 hours.

Badly fouled systems must be cleaned before treatment has begun.

FOR CONTROL OF BACTERIA

Add 0.00095-0.0095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system, depending on the severity of contamination.

INTERMITTENT OR SLUG METHOD:

INITIAL DOSE: When the system is noticeably fouled, add 0.0048-0.0095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident add 0.0024-0.0095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system every 4 days, or as needed to maintain control.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 0.0048-0.0095 gal of **BIO-CLEAR 2000** per 1,000 gal of water to the system.

SUBSEQUENT DOSE: Maintain this level by pumping a continuous feed of 0.00095-0.0048 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system per day.

FOR CONTROL OF FUNGI AND ALGAE

Add 0.029-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system depending on the severity of contamination.

INTERMITTENT OR SLUG METHOD:

INITIAL DOSE: When the system is noticeably fouled, add 0.048-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident add 0.029-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system, or as needed to maintain control.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 0.048-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water to the system.

SUBSEQUENT DOSE: Maintain this level by pumping a continuous feed of 0.029-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system per day.

ONCE-THROUGH INDUSTRIAL COOLING WATER SYSTEMS

For controlling microbiological growth in the once-through and closed-cycle fresh and sea water cooling systems, cooling ponds, canals, and lagoons, add **BIO-CLEAR 2000** to the system inlet water or before any other contaminated area in the system. Intermittent addition should be made with a metering pump at a level dependent on the severity of the contamination in the system.

Badly fouled systems must be cleaned before treatment has begun.

INITIAL DOSE: When the system is noticeably fouled, add 6-12 ppm **BIO-CLEAR 2000** based on the flow-rate through the system. Additions should be for durations of at least 15 minutes, but with additions not being made for more than a total of 4 hours per day.

SUBSEQUENT DOSE: When microbial control is evident, add 3-12 ppm **BIO-CLEAR 2000** intermittently to maintain control. Addition intervals may vary but total time of additions should not exceed 4 hours per day.

REVERSE OSMOSIS SYSTEMS

BIO-CLEAR 2000 may be used to control bacteria and reduce biofouling in industrial membrane systems (reverse osmosis, ultrafiltration, microfiltration). Acceptable applications include reverse osmosis for the production of boiler makeup water, rinsing of electric components, and industrial wastewater treatment.

BIO-CLEAR 2000 may be fed continuously to the membrane system feed water at a rate of 10-100 ppm **BIO-CLEAR 2000** (1.3-13.0 fl. oz./1,000 gallons or 0.4 to 4.0 ml/min per 10 gpm of feed water) . For off-line system disinfection, add 50-170 ppm **BIO-CLEAR 2000** (6.5-22.0 fl. oz/ 1,000 gallons) to the off-line cleaning feed tank and re-circulate for 30 minutes to 3 hours. Frequency of addition should be every 5 days or as needed.

Note: For industrial systems in which **BIO-CLEAR 2000** residuals cannot be tolerated, **BIO-CLEAR 2000** must be slug fed. During and for 30 minutes to 1 hour following chemical addition, permeate and concentrate streams must be diverted to waste.

AIR-WASHING SYSTEMS

Add 0.0015-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system, depending upon the severity of contamination to control slime-forming bacteria and fungi in industrial air-washer systems.

Badly fouled systems must be cleaned before treatment has begun.

INTERMITTENT OR SLUG METHOD:

INITIAL DOSE: When the system is noticeably fouled, add 0.003-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident add 0.00015-0.047 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system every 2 days, or as needed to maintain control.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 0.003-0.095 gal of **BIO-CLEAR 2000** per 1,000 gal of water to the system.

SUBSEQUENT DOSE: Maintain this level by pumping a continuous feed of 0.0015-0.047 gal of **BIO-CLEAR 2000** per 1,000 gal of water in the system per day.

Note: For use only in industrial air-washer systems that maintain effective mist eliminating components.

HYDROTESTING

FOR CONTROL OF BACTERIA

Water used to hydrotest pipelines or vessels should contain 100 to 1,000 ppm of **BIO-CLEAR 2000** per 1,000 gallons of water (0.1 to 1 gallon of **BIO-CLEAR 2000** per 1000 gallons of water) depending on water quality and length of time the equipment will remain idle.

PUBLICLY-OWNED TREATMENT WORKS

TO CONTROL COLIFORM AND OTHER BACTERIA

Add **BIO-CLEAR 2000** at a concentration of 1.0 to 10.0 ppm by weight of water being treated, depending on the severity and contamination in the system.

Addition should be continuous and made with a metering pump at a point in the system where mixing will be rapid and thorough. Add **BIO-CLEAR 2000** to the system in a location where contact time will be 30 minutes or greater before reaching the outfall.

TO USE AS A CO-TREATMENT WITH CHLORINE

Add 0.4-1.5 ppm **BIO-CLEAR 2000** by weight of water treated.

Chlorination should result in a minimum detectable residual (i.e., greater than zero but less than the NPDES permit level). Addition should be continuous and made at a point just after initial chlorine mixing. Rapid mixing is necessary for maximum effectiveness. **BIO-CLEAR 2000** should be added at a location where a contact time of 10 minutes or longer will be provided before reaching the outfall.

9 8 11

PROCESS, PRODUCT, WASTEWATER & RECYCLE CLEAN UP

BIO-CLEAR 2000 may be used to reduce microbial contamination in process water and raw materials during the formulating phase or it can be added directly to the final formulation product to reduce microbial contamination prior to packaging. **BIO-CLEAR 2000** may also be used for treatment of wastewater. The required concentration will depend upon the material being treated and the contamination load. Organic load, pH exposure to load and time are matrix effects that impact efficacy of the biocide. You will need to determine the optimum level to use for your system or product within the guidelines given below. Do not use at greater than recommended levels.

CONSUMER, HOUSEHOLD & INSTITUTIONAL PROCESSES & PRODUCTS

BIO-CLEAR 2000 is not intended for use in personal care products.

Process Water & Raw Material Clean Up

To reduce microbial contamination in process water or raw materials used to make consumer, household, or institutional products, add **BIO-CLEAR 2000** directly to the water or raw material at concentration of 125-1,000 ppm by weight.

Direct Product Addition

To reduce microbial contamination in formulated products such as hard surface cleaners, laundry detergent, fabric softeners and other hard surface cleanser, laundry detergent, fabric softeners and other water based formulations, add 125-250 ppm by weight **BIO-CLEAR 2000** directly to the product prior to packaging. Thorough mixing is recommended.

CONSUMER, HOUSEHOLD & INSTITUTIONAL RECYCLE WATER, RECYCLE PRODUCT CLEANUP & RECYCLE WASTEWATER

BIO-CLEAR 2000 may be added to recycle process water, a recycle product stream or added to a recycle waste water stream to reduce microbial contamination. Add at a convenient point of uniform mixing, This can be either continuous feed directly into a transfer line or slug fed to the storage container for either wash water or product. Add 125 to 1,000 ppm by weight. This concentration is equivalent to 38 to 303 ml (1.28 to 10.2 fluid oz) **BIO-CLEAR 2000** per 100 gallons to be treated.

INDUSTRIAL PROCESSES & PRODUCTS

Process Water & Raw Material Clean Up

To reduce microbial contamination in process water or raw material used to make industrial products, add **BIO-CLEAR 2000** directly to the process water or raw material at a concentration of 125-2,000 ppm by weight. This includes raw materials and/or products such as aqueous paints and coatings, polymers, slurries, adhesives, latex and resin emulsions and surfactant.

Direct Product Addition

To clean up microbial contamination in a final formulated industrial product, add 125-500 ppm by weight **BIO-CLEAR 2000** directly to the product prior to packaging.

INDUSTRIAL RECYCLE WATER, RECYCLE PRODUCT CLEAN UP & RECYCLE WASTEWATER

BIO-CLEAR 2000 may be added to recycle process water, a recycle product stream or added to a recycle waste water stream to reduce microbial contamination. Add at a convenient point of uniform mixing. This can be either continuous feed directly into a transfer line or slug fed to the storage container for either wash water or product. Add 125 to 2000 ppm by weight. This concentration is equivalent to 38 to 606 ml (1.25 to 20.4 fluid oz) **BIO-CLEAR 2000** per 100 gallons to be treated.

INDUSTRIAL WASTEWATER SYSTEMS

WASTEWATER SYSTEMS, WASTEWATER SLUDGE AND WASTEWATER HOLDING TANKS

BIO-CLEAR 2000 may be added to a wastewater system or sludge at a convenient point of uniform mixing such as the digester. Add 125-2,000 ppm by weight. This concentration is equivalent to 378-6054 milliliters **BIO-CLEAR 2000** (12.8-204.7 fl. oz.) per 1,000 gallons of water.

TANKSIDE ADDITION TO ELECTRODEPOSITION SYSTEMS

BIO-CLEAR 2000 may be added as a tankside additive in recirculating electrodeposition systems and associated rinse systems to control microbial contamination. **BIO-CLEAR 2000** should be added into the recirculating rinse system at a point to insure uniform mixing. Add 125 to 2000 ppm by weight. This concentration is equivalent to 378-6054 milliliters of **BIO-CLEAR 2000** (12.8-204.7 fl oz.) per 1000 gallons of water.

EQUIPMENT CLEANING

BIO-CLEAR 2000 can be used to kill microorganisms present in solution or growing on the surfaces of process equipment such as reaction vessels, storage tanks and containers, piping and hoses. For standard cleaning of equipment, add 50 to 250 ppm by weight of **BIO-CLEAR 2000** in an aqueous solution, to process piping or equipment. Heavily fouled solutions or equipment may be treated with up to 2000 ppm of **BIO-CLEAR 2000** after treating process equipment with **BIO-CLEAR 2000**, allow the **BIO-CLEAR 2000** solution to be in contact with surfaces for up to four hours.

If bleach is being used for cleaning purposes at 50 to 250 available chlorine, **BIO-CLEAR 2000** can be used as part of a dual treatment program at 50 to 100 ppm by weight, in combination with sodium hypochlorite. Treat process equipment with chlorine first. Follow the treatment with **BIO-CLEAR 2000**. Do not combine concentrated sodium hypochlorite solution with **BIO-CLEAR 2000**.

PESTICIDE STORAGE AND DISPOSAL

Do not contaminate water, food or feed by storage or disposal.

Storage: To maintain product quality, store at temperatures below 60°C. Keep container tightly closed when not in use.

Pesticide Disposal: Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide, spray mixture or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

Container Disposal: Nonrefillable container. Do not reuse or refill this container. Triple rinse (or equivalent) promptly after emptying. Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

Reusable Portable Containers (Totes): Do not rinse containers. Do not put any other material(s) in containers. Seal all openings with proper fittings and clean outside of container. Then return container to Clearwater International.

Spills: When handling or dealing with spills, wear protective clothing as indicated in the Personal Protective Equipment section. Cover wet spills with 10% sodium bicarbonate solution, water and then an inert absorbent before sweeping up and disposing as described for pesticide disposal. If drum contents are contaminated or decomposing, isolate unsealed drum in the open or in a well-ventilated area. Flood with 10% sodium bicarbonate solution and large volume of water, if necessary.

NOTICE: Do not ship or store with food, feeds, drugs or clothing.

[Batch code]