### UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

FEB 2 | 1997

James A. Roszell, Ph.D. SuperTech Products, Inc. 4351 NE 12 Terrace Fort Lauderdale, FL 33334-4724

Subject: ZIP STRIP

EPA Registration No. 62896-1 Notification Per PR-Notice 95-2

Dear Mr. Roszell:

This will acknowledge receipt of your notification, to correct an omission of the application rate for this product, submitted under the provisions of FIFRA section 3 (c) 9. Based on a review of the submitted material, the following comments apply.

The application is acceptable and the notification has been made a part of the records for this file.

Sincerely,

Wanda Y. Mitchell Notification Coordinator Antimicrobial Program Branch Registration Division (7505)

CONCURRENCES			
SYMBOL 7505			
SURNAME   MITCHCIII			
DATE 2/21/97			

EPA Form 1320-1A (1/90)

Printed on Recycled Paper

OFFICIAL FILE COPY TUS. GPO: 1984-522-503/62665



## SuperTech Products, Inc.

4351 NE 12 Terrace Fort Lauderdale, FL 33334-4724 (954) 565-7080 In Florida: (800) 245-0468 FAX (954) 565-0230

Earth-Friendly Products

16 January 1997

# NOTIFICATION! Under CFR 40:152.42

Marion J. Johnson, Jr.
Product Manager (31)
Antimicrobial Program Branch
Registration Division (7505C)
United States Environmental Protection Agency
Washington, DC 20460

NOTIFICATION FEB-211997

Dear Mr. Johnson:

We have become aware of an omission from our label for the ZIP STRIP, EPA Reg. No. 62896-1, approved 1/6/97, concerning the application rate for the product. By this notification, we are correcting that omission with the addition of the following statement:

## Apply 1/6 to 1/3 ounce (1/2 to 1 inch) per ton of cooling capacity.

Enclosed, please find six (6) copies of the amended label for our product The ZIP STRIP, EPA Reg. No. 62896-1.

If there are any problems, you have any questions or require further information, please do not hesitate to call at (954) 565-7080 or fax to (954) 565-0309.

We appreciation your time and attention to our registration.

Respectfully.

James A. Roszell, Ph.D.

Chemist

encls.

Remove clear plastic wrapper. Place ZIP STRIP in condensation pan in contact with water at the end farthest from the drain opening. Wash hands thoroughly after handling ZIP STRIP. Apply 1/6 to 1/3 ounce (1/2 to 1 inch) per ton of cooling capacity.

NOT FOR USE IN ATOMIZING OR
HEAT VAPORIZERS
HUMIDIFIERS.
FOR COMMERCIAL AND
INDUSTRIAL USE ONLY.

STORAGE AND DISPOSAL:

Store in a cool, dry place. Do not contaminate water, food or feed by storage or disposal. Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

DO NOT REUSE EMPTY

CONTAINER: wrap in newspaper and place in trash.

Precautionary Statements

(continued on far panel)


Hazards to humans and domestic animals.

DANGER

#### ZIP STRIP

### Condensate Pan

Treatment
ZIP STRIP time releases
a controlled, low level of
quaternary microbiocide



effectively eliminating condensate pan fouling and maintaining free flowing drain lines in air conditioning and refrigeration

systems for 4 months.

#### **ACTIVE INGREDIENTS:**


didecyl dimethyl ammonium chloride—21.8% N-alkyl (C<sub>14</sub>-50%, C<sub>12</sub>-40%, C<sub>16</sub>-10%)-dimethyl benzyl ammonium chloride—14.6% INERT INGREDIENTS:—63.6%

NET WEIGHT: 24 ounces
(24-1 oz strips per box)
EPA REGISTRATION No: 62896-1
EPA ESTABLISHMENT No: 62896-FL-001
KEEP OUT OF REACH OF
CHILDREN.

DANGER

See side panels for additional precautionary statements. SUPERTECH

PRODUCTS, INC. Fort Lauderdale, FL (800) 245-0468



Statement of Practical Treatment:

If in eyes: Call a physician. Keep eye lids open and flush with a gentle steady stream of water for 15 minutes. If swallowed:

Drink promptly a large quantity of milk, egg white or gelatin mixture, or if these ar not available a large quantity of water.

Avoid alcohol.

ENVIRONMENTAL HAZARDS
Do not discharge effluent containing this
product into lakes, streams, ponds, estuaries, oceans or other waters unless in
accordance with the requirements of a
National Pollutant Discharge Elimination
System (NPDES) permit and the permitting authority has been notified in writing
prior to discharge. Do not discharge
effluent containing this product to sewer
systems without previously notifying the
local sewage treatment plant authority.
For guidance, contact your State Water
Board or Regional Office of the EPA.

re6 2 1 1997

NOTIFICATION