

PLEASE NOTE


**This image contains more than one label
approved for this product on this date.**

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

63761-2

1/9/2008

Page 1 of 4



Ms. Judy Cornman
Sterilex Corporation
11409 Cronhill Drive, Suite L
Owings Mills, MD 21117

SUBJECT: Ultra-Kleen CW-502
EPA Registration Number: 63761-2
Notification Date: December 13, 2007
EPA Receipt Date: December 12, 2007

Dear Ms. Cornman:

The following notification submitted in connection with the provisions of FIFRA section 3 (c) 9 and PR Notice 98-10 is acceptable.

- Add 10 lb container

General Comments

Based on the submitted materials, the notification to add 10 lb container, is acceptable and will be made a part of the records on file.


Should you have any questions concerning this letter, please contact Jacqueline McFarlane at (703) 308-6416.

Sincerely,

Velma Noble
Product Manager (31)
Regulatory Management Branch I
Antimicrobials Division (7510C)

CONCURRENCES

SYMBOL							
SURNAME							
DATE							



United States
Environmental Protection Agency
 Washington, DC 20460

- Registration
- Amendment
- Other

OPP Identifier Number

Application for Pesticide - Section I

1. Company/Product Number 63761-2	2. EPA Product Manager Velma Noble	3. Proposed Classification <input type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product (Name) Sterilex Ultra-Kleen CW502	PM# 31	
5. Name and Address of Applicant (Include ZIP Code) Sterilex Corporation 11409 Cronhill Drive, Suite L Owings Mills, MD 21117		6. Expedited Review. In accordance with FIFRA Section 3(c)(3) (b)(I), my product is similar or identical in composition and labeling to:

NOTE: PLEASE SEND ALL CORRESPONDENCE TO "CONTACT POINT" LISTED BELOW

Check if this is a new address

Section - II

<input type="checkbox"/> Amendment – Explain below. <input type="checkbox"/> Resubmission in response to Agency letter dated _____ <input checked="" type="checkbox"/> Notification - Explain below.	<input type="checkbox"/> Final printed labels in response to Agency letter dated _ <input type="checkbox"/> "Me Too" Application <input type="checkbox"/> Other - Explain below
--	---

Explanation: Use additional page(s) if necessary. (For section I and Section II.)
 We are submitting a Notification regarding one of our registered products, **Sterilex Ultra-Kleen CW502**. The purpose of this notification is to inform the agency per PR Notice 98-10 of an additional container size. That container is a ten pound bucket with a label insert.

Section - III

1. Material This Product Will Be Packaged In:				2. Type of Container	
Child-Resistant Packaging <input type="checkbox"/> Yes* <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify)	
*Certification must be submitted		If "Yes" Unit Packaging wgt.	No. per container	If "Yes" Package wgt	No. per container
3. Location of Net Contents Information <input type="checkbox"/> Label <input type="checkbox"/> Container		4. Size(s) Retail Container 5, 30 and 55 gallons		5. Location of Label Directions <input type="checkbox"/> On Label <input type="checkbox"/> On labeling accompanying product	
6. Manner in Which Label is Affixed to Product <input type="checkbox"/> Lithograph <input type="checkbox"/> Other _____ <input type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled					

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application)

Name Judy Cornman	Title Regulatory Specialist	Telephone No. (Include Area Code) 410.581.8860
-----------------------------	---------------------------------------	--

Certification

I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.

2. Signature	3. Title Regulatory Specialist	5. Date Application Received _____
4. Typed Name Judy Cornman	5. Date December 13, 2007	



STERILEX®

374

12/13/2007

Document Processing Desk
Office of Pesticide Programs (7504P)
US Environmental Protection Agency
Room S4900, One Potomac Yard
2777 S. Crystal Drive
Arlington, VA 22202

ATTENTION: Velma Noble
Product Manager, Team 31

SUBJECT: *Sterilex Corporation
Sterilex Ultra-Kleen CW502
EPA Registration Number 63761-2
Notification to add a Revised Label to New Ten (10) Pound Container*

Dear Ms. Noble:

Per PR Notice 98-10, we are submitting a notification for **Sterilex Ultra-Kleen CW502**; the sole purpose of this notification is to inform the agency of the addition of a new ten (10) pound container. Please find enclosed,

1. An EPA Application for Pesticide (8570-1)
2. A copy of the revised label for **Sterilex Ultra-Kleen CW502 (63761-2)**

If you have any questions, please contact me at 410-581-8860 or by email at judy@sterilex.com

Sincerely,

Judy Cornman
Regulatory Specialist
Sterilex Corporation



STERILEX ULTRA-KLEEN™ CW502 Package Insert

Penetrates and Removes Biofilm and Other Organic Contaminants. For use as a Bactericide, Slimicide, Mildewstat and Algicide in:

- Recirculating Cooling Water Systems
- Brewery Pasteurizing Systems
- Air Washers
- Dye Machines
- Water-Jet Looms
- Tanks and Piping used to store and convey Industrial Process Water or Aqueous Mixtures not related to food processing
- Deionized Water Supply Systems not used in food processing, for human drinking water or in dental lines.
- Drains
- Chair Side Evacuator Traps and Pump Filter Traps

Controls Mold and Mildew

KEEP OUT OF REACH OF CHILDREN

DANGER

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

DIRECTIONS FOR USE

RECIRCULATING COOLING WATER SYSTEMS, INCLUDING COOLING TOWERS, EVAPORATIVE CONDENSERS AND BREWERY PASTEURIZERS. Effectively removes and controls biofilm and other organic contaminants in commercial and industrial cooling towers; influent water systems such as flow-through fillers; and heat exchange water systems.

DOSAGE RATES. Initial Dose for badly fouled systems. Add 5 to 20 lbs. Ultra-Kleen CW-502 per 1000 gallons water contained in the system.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 to 5 lbs. Ultra-Kleen CW-502 per 1000 gallons of water should be employed every 2 to 5 days or as needed. The frequency of addition depends on the relative amount of biofilm, the quality of the makeup water and rate of inflow of airborne or other contaminants. Slug additions should be made in the sump of water cooling towers.

AIR WASHERS. For use only in industrial air washing systems that maintain effective mist eliminating components. Effectively removes and controls biofilm and other organic contaminants in Industrial Water Scrubbing Systems.

DOSAGE RATES. Initial Dose for badly fouled systems. Add 16 to 80 lbs. of Ultra-Kleen CW-502 per 1000 gallons of water contained in the system. If necessary, apply a solution containing 0.016 to 0.08 lbs. Ultra-Kleen CW-502 per gallon of water onto interior surfaces of the system that are not continuously submerged.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 to 5 lbs. Ultra-Kleen CW-502 per 1000 gallons of water should be employed every 1 to 5 days or as needed. The frequency of addition depends on the relative amount of biofilm, the quality of the makeup water and rate of inflow of airborne or other contaminants. Slug additions should be made in the sump of Industrial Water Scrubbing Systems.

DYE MACHINES. Effectively removes and controls biofilm and other organic contaminants in Textile Dyeing Machines.

DOSAGE RATES. Clean badly fouled systems by adding 80 to 200 lbs. of Ultra-Kleen CW-502 per 1000 gallons of water contained in a dye storage tank. Circulate the solution from the dye storage tank through the dye machine and all associated piping and other dye storage tanks. If necessary, apply a solution containing 0.08 to 0.2 lbs. Ultra-Kleen CW-502 per gallon of water onto surfaces of the system that are not continuously submerged.

WATER-JET LOOMS. Effectively removes and controls biofilm and other organic contaminants in Water-Jet Looms.

DOSAGE RATES. Initial Dose for badly fouled systems. Prepare a solution of 0.08 to 0.20 lbs. of Ultra-Kleen CW-502 per gallon of water and pump through the Water-Jet Loom and all associated piping. If necessary, apply a solution containing 0.08 to 0.2 lbs. Ultra-Kleen CW-502 per gallon of water onto surfaces of the system that are not continuously submerged.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 0.2 to 1.0 lbs. Ultra-Kleen CW-502 per 1000 gallons of daily water use should be employed every 1 to 5 days or as needed. The frequency of addition depends on the quality of the makeup water and rate of inflow of airborne or other contaminants.

TANKS AND PIPING USED TO STORE AND CONVEY INDUSTRIAL PROCESS WATER OR AQUEOUS MIXTURES: Do Not Use in equipment that will contact food. Effectively remove and controls biofilm and other organic contaminants in Tanks and Piping used to store and convey Industrial Process Water or Aqueous Mixtures.

DOSAGE RATES. Fill equipment as completely as possible with a solution of 40 to 400 lbs. of Ultra-Kleen CW-502 per 1000 gallons of system capacity. Circulate for at least 4 hours and then drain system. Rinse system with 6 volumes of water. If necessary, apply a solution containing 0.024 to 0.2 lbs. Ultra-Kleen CW-502 per gallon onto surfaces of the equipment that are not submerged.

DEIONIZED WATER SUPPLY SYSTEMS NOT USED IN FOOD PROCESS FOR HUMAN DRINKING WATER OR IN DENTAL LINES. Effectively removes and controls biofilm and other organic contaminants in Tanks, Filters and Piping used to store and convey Deionized Water. Do Not Use where deionized water will be used for food processing, for human drinking water or for medical/dental procedures.

DOSAGE RATES. Add 16 to 80 lbs. of Ultra-Kleen CW-502 per 1000 gallons of system capacity. Circulate for at least 4 hours and then drain system. Rinse system with 6 volumes of water. If necessary, apply a solution containing 0.016 to 0.08 lbs. Ultra-Kleen CW-502 per gallon onto surfaces of the equipment that are not submerged.

Penetrates and Removes Biofilm and Other Organic Contaminants. Use as a Bactericide, Slimicide, Mildewstat, and Algicide in:

DRAINS. Effectively removes and controls plugging and odors caused by accumulation of biofilm and other organic contaminants in drains. Prevents stoppage and odors.

DOSAGE RATES. Initial Dose for badly fouled systems. Pour from 6 oz Ultra-Kleen CW-502 around or into one-inch diameter or smaller drains up to 54 oz. Ultra-Kleen CW-502 around or into three-inch diameter drains. If the drain is not in use at the time, follow with one gallon of hot water for every 8 oz. of Ultra-Kleen CW-502 added. Allow to stand for 30 minutes. Repeat until control is evident.

Subsequent Dose: When microbial control is evident, subsequent additions of 1 oz. Ultra-Kleen CW-502 into one-inch diameter or smaller drains up to 9 oz. Ultra-Kleen CW-502 into three-inch diameter drains, followed by one gallon of hot water for every 1 oz. of Ultra-Kleen CW-502 added, should be employed every 7 days or as needed.

CHAIR SIDE EVACUATOR TRAPS AND PUMP FILTER TRAPS. Effectively removes and controls plugging and odors caused by accumulation of biofilm in chair side evacuator traps and pump filter traps. Prevents stoppage and odor.

DOSAGE RATES. Initial Dose for badly fouled systems. Dissolve 6 oz. of Ultra-Kleen CW-502 into one gallon of hot water at the end of the working day. Draw all of the solution into the trap and allow to stand overnight. Repeat until control is evident.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 oz. Ultra-Kleen CW-502 dissolved into one gallon of hot water should be employed every 7 days or as needed.

FOR PRE-CLEANING OF WHIRLPOOL BATHTUBS dissolve 0.5 oz. of Sterilex Ultra-Kleen CW-502 in 1 gal. tap water and circulate through tub and associated piping and filters at a temperature $\pm 90^{\circ}$ F.

EPA Reg. No. 63761-2
Reorder Number: CW502
Net Weight _____
Lot No. _____

11/07 AZW/JC

Call 1-800-511-1659 for Technical Information

Sterilex Corporation
Owings Mills, MD 21117

www.sterilex.com

EPA Est. No. 4875-NJ-001
 44636-CA-001
 21737-MN-01
 062788-AL-01

NOTIFICATION

Date Reviewed: 11/9/07
Reviewed By: J. H. [Signature]

474

NEXT

LABEL

63761-2

1/9/2008

1/5

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Washington, D.C. 20460

OFFICE OF
PREVENTION, PESTICIDES
AND TOXIC SUBSTANCES

JAN -9 2008

Judy Cornman
Regulatory Specialist
Sterilex Corporation
11409 Cronhill Drive Ste. L
Owings Mills, Md 21117

Subject: Sterilex Ultra-Kleen™ CW502
EPA Reg. No.63761-2
Application Dated: December 13, 2007
Receipt Date: December 13, 2007

Dear Ms. Cornman,

The following notification submitted in connection with registration under the provisions of PR Notice 98-10, Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA) section 3(c) 9 is acceptable.

Proposed Notification

- Add EPA Establishment Numbers.

Comments

Based on a review of the material submitted, the following comments apply:
This application for notification to add EPA Establishment Numbers is acceptable.
A copy has been placed in our records for future reference.


Should you have any questions or comments concerning this letter, please contact Velma Noble at (703) 308-6233.

Sincerely
Velma Noble

Velma Noble
Product Manager (31)
Regulatory Management Branch1
Antimicrobial Division (7510P)

CONCURRENCES

SYMBOL	7510P						
JRNAME							
DATE	1/9/08						



United States
Environmental Protection Agency
 Washington, DC 20460

- Registration
 Amendment
 Other

OPP Identifier Number

Application for Pesticide - Section I

1. Company/Product Number 63761-2	2. EPA Product Manager Velma Noble	3. Proposed Classification <input type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product (Name) Sterilex Ultra-Kleen CW502	PM# 31	
5. Name and Address of Applicant (Include ZIP Code) Sterilex Corporation 11409 Cronhill Drive, Suite L Owings Mills, MD 21117		6. Expedited Review. In accordance with FIFRA Section 3(c)(3) (b)(I), my product is similar or identical in composition and labeling to:

NOTE: PLEASE SEND ALL CORRESPONDENCE TO "CONTACT POINT" LISTED BELOW

Check if this is a new address

Section - II

Amendment - Explain below. Final printed labels in response to Agency letter dated __

Resubmission in response to Agency letter dated _____ "Me Too" Application

Notification - Explain below. Other - Explain below

Explanation: Use additional page(s) if necessary. (For section I and Section II.)
 We are submitting a Notification regarding one of our registered products, **Sterilex Ultra-Kleen CW502**. The purpose of this notification is to inform the agency of the addition of Multiple EPA Establishment Numbers to that product's label.

Section - III

1. Material This Product Will Be Packaged In:				2. Type of Container	
Child-Resistant Packaging <input type="checkbox"/> Yes* <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	If "Yes" Package wgt		No. per container
*Certification must be submitted		If "Yes" Unit Packaging wgt.			
3. Location of Net Contents Information <input type="checkbox"/> Label <input type="checkbox"/> Container		4. Size(s) Retail Container		5. Location of Label Directions <input type="checkbox"/> On Label <input type="checkbox"/> On labeling accompanying product	
6. Manner in Which Label is Affixed to Product <input type="checkbox"/> Lithograph <input type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled				<input type="checkbox"/> Other _____	

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application)

Name Judy Cornman	Title Regulatory Specialist	Telephone No. (Include Area Code) 410.531.8860
-----------------------------	---------------------------------------	--

Certification
 I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.

2. Signature	3. Title Regulatory Specialist	6. Date Application Received
4. Typed Name Judy Cornman	5. Date December 13, 2007	



STERILEX®

3/5

12/13/2007

Document Processing Desk
Office of Pesticide Programs (7504P)
US Environmental Protection Agency
Room S4900, One Potomac Yard
2777 S. Crystal Drive
Arlington, VA 22202

ATTENTION: Velma Noble
Product Manager, Team 31

SUBJECT: Sterilex Corporation
Sterilex Ultra-Kleen CW502
EPA Registration Number 63761-2
Notification to add Multiple EPA Establishment Numbers

Dear Ms. Noble:


We are submitting a notification for **Sterilex Ultra-Kleen CW502**; the sole purpose of this notification is to inform the agency of the addition of Multiple Environmental Protection Agency (EPA) Establishment Numbers to the above referenced product label. At each facility the appropriate establishment number will be clearly identified with a check mark. Please find enclosed,

1. An EPA Application for Pesticide (8570-1)
2. A copy of the revised label for **Sterilex Ultra-Kleen CW502 (63761-2)**

If you have any questions, please contact me at 410-581-8860 or by email at judy@sterilex.com

Sincerely,

Judy Cornman
Regulatory Specialist
Sterilex Corporation



STERILEX ULTRA-KLEEN™ CW502

Penetrates and Removes Biofilm and Other Organic Contaminants. For use as a Bactericide, Slimicide, Mildewstat and Algicide in:

- Recirculating Cooling Water Systems
- Brewery Pasteurizing Systems
- Air Washers
- Dye Machines
- Water-Jet Looms
- Tanks and Piping used to store and convey Industrial Process Water or Aqueous Mixtures not related to food processing
- Deionized Water Supply Systems not used in food processing, for human drinking water or in dental lines.
- Drains
- Chair Side Evacuator Traps and Pump Filter Traps

Controls Mold and Mildew

Active Ingredient:	
n-Alkyl (C ₁₄ -95%, C ₁₂ -3%, C ₁₆ -2%) dimethylbenzylammonium chloride.....	10.0%
Inert Ingredients.....	90.0%
TOTAL.....	100.0%

KEEP OUT OF REACH OF CHILDREN

DANGER

See Side Panel For Additional Precautionary Statements and First Aid

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

RECIRCULATING COOLING WATER SYSTEMS, INCLUDING COOLING TOWERS, EVAPORATIVE CONDENSERS AND BREWERY PASTEURIZERS.

Effectively removes and controls biofilm and other organic contaminants in commercial and industrial cooling towers, influent water systems such as flow-through filters, and heat exchange water systems.

DOSAGE RATES. Initial Dose for badly fouled systems. Add 5 to 20 lbs. Ultra-Kleen CW-502 per 1000 gallons water contained in the system. Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 to 5 lbs. Ultra-Kleen CW-502 per 1000 gallons of water should be employed every 2 to 5 days or as needed. The frequency of addition depends on the relative amount of bleed off, the quality of the makeup water and rate of inflow of airborne or other contaminants. Slug additions should be made in the sump of water cooling towers.

AIR WASHERS. For use only in industrial air washing systems that maintain effective mist eliminating components. Effectively removes and controls biofilm and other organic contaminants in Industrial Water Scrubbing Systems.

DOSAGE RATES. Initial Dose for badly fouled systems. Add 16 to 80 lbs. of Ultra-Kleen CW-502 per 1000 gallons of water contained in the system. If necessary, apply a solution containing 0.016 to 0.08 lbs. Ultra-Kleen CW-502 per gallon of water onto interior surfaces of the system that are not continuously submerged.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 to 5 lbs. Ultra-Kleen CW-502 per 1000 gallons of water should be employed every 1 to 5 days or as needed. The frequency of addition depends on the relative amount of bleed off, the quality of the makeup water and rate of inflow of airborne or other contaminants. Slug additions should be made in the sump of Industrial Water Scrubbing Systems.

DYE MACHINES. Effectively removes and controls biofilm and other organic contaminants in Textile Dyeing Machines.

DOSAGE RATES. Clean badly fouled systems by adding 80 to 200 lbs. of Ultra-Kleen CW-502 per 1000 gallons of water contained in a dye storage tank. Circulate the solution from the dye storage tank through the dye machine and all associated piping and other dye storage tanks. If necessary, apply a solution containing 0.08 to 0.2 lbs. Ultra-Kleen CW-502 per gallon of water onto surfaces of the system that are not continuously submerged.

WATER-JET LOOMS. Effectively removes and controls biofilm and other organic contaminants in Water-Jet Looms.

DOSAGE RATES. Initial Dose for badly fouled systems. Prepare a solution of 0.08 to 0.20 lbs. of Ultra-Kleen CW-502 per gallon of water and pump through the Water-Jet Loom and all associated piping. If necessary, apply a solution containing 0.08 to 0.2 lbs. Ultra-Kleen CW-502 per gallon surfaces of the system that are not continuously submerged.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 0.2 to 1.0 lbs. Ultra-Kleen CW-502 per 1000 gallons of daily water use should be employed every 1 to 5 days or as needed. The frequency of addition depends on the quality of the makeup water and rate of inflow of airborne or other contaminants.

TANKS AND PIPING USED TO STORE AND CONVEY INDUSTRIAL PROCESS WATER OR AQUEOUS MIXTURES. Do Not Use in equipment that will contact food. Effectively removes and controls biofilm and other organic contaminants in Tanks and Piping used to store and convey Industrial Process Water or Aqueous Mixtures.

DOSAGE RATES. Fill equipment as completely as possible with a solution of 40 to 400 lbs. of Ultra-Kleen CW-502 per 1000 gallons of system capacity. Circulate for at least 4 hours and then drain system. Rinse system with 6 volumes of water. If necessary, apply a solution containing 0.04 to 0.2 lbs. Ultra-Kleen CW-502 per gallon onto surfaces of the equipment that are not submerged.

DEIONIZED WATER SUPPLY SYSTEMS NOT USED IN FOOD PROCESSING, FOR HUMAN DRINKING WATER OR IN DENTAL LINES. Effectively removes and controls biofilm and other organic contaminants in Tanks, Filters and Piping used to store and convey Deionized Water. Do Not Use where deionized water will be used for food processing, for human drinking water or for medical/dental procedures.

DOSAGE RATES. Add 16 to 80 lbs. of Ultra-Kleen CW-502 per 1000 gallons of system capacity. Circulate for at least 4 hours and then drain system. Rinse system with 6 volumes of water. If necessary, apply a solution containing 0.016 to 0.08 lbs. Ultra-Kleen CW-502 per gallon onto surfaces of the equipment that are not submerged.

Penetrates and Removes Biofilm and Other Organic Contaminants. Use as a Bactericide, Slimicide, Mildewstat, and Algicide in:

DRAINS. Effectively removes and controls plugging and odors caused by accumulation of biofilm and other organic contaminants in drains. Prevents stoppage and odors.
DOSAGE RATES. Initial Dose for badly fouled systems. Pour from 6 oz. Ultra-Kleen CW-502 around or into one-inch diameter or smaller drains up to 54 oz. Ultra-Kleen CW-502 around or into three-inch diameter drains. If the drain is not in use at the time, follow with one gallon of hot water for every 6 oz. of Ultra-Kleen CW-502 added. Allow to stand for 30 minutes. Repeat until control is evident.

Subsequent Dose: When microbial control is evident, subsequent additions of 1 oz. Ultra-Kleen CW-502 into one-inch diameter or smaller drains up to 9 oz. Ultra-Kleen CW-502 into three-inch diameter drains, followed by one gallon of hot water for every 1 oz. of Ultra-Kleen CW-502 added should be employed every 7 days or as needed.

CHAIR SIDE EVACUATOR TRAPS AND PUMP FILTER TRAPS.

Effectively removes and controls plugging and odors caused by accumulation of biofilm in chair side evacuator traps and pump filter traps. Prevents stoppage and odor.
DOSAGE RATES. Initial Dose for badly fouled systems. Dissolve 6 oz. of Ultra-Kleen CW-502 into one gallon of hot water at the end of the working day. Draw all of the solution into the trap and allow to stand overnight. Repeat until control is evident.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 oz. Ultra-Kleen CW-502 dissolved into one gallon of hot water should be employed every 7 days or as needed.

FOR PRE-CLEANING OF WHIRLPOOL BATHTUBS dissolve 0.5 oz. of Sterilex Ultra-Kleen CW-502 in 1 gal. tap water and circulate through tub and associated piping and filters at a temperature $\geq 90^{\circ}\text{F}$.

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS
DANGER. Powder corrosive to skin and eyes. Powder causes irreversible eye damage and skin burns. Harmful if powder is swallowed or absorbed through skin. Wear goggles and/or face shield, protective clothing and rubber gloves. Wash thoroughly with soap and water after handling. Remove contaminated clothing and wash clothing before reuse.

ENVIRONMENTAL HAZARDS. This product is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, ocean or other waters unless in accordance with the requirements of a National Pollution Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not

not discha previously guidance, EPA.

PHYSICAL
Kleen CW

Have the l center of c

IF IN EYE
minutes. I continue r

IF ON SK
plenty of w treatment. I

IF POWDI
for medica unconscious gelatin, or alcohol.

NOTE TO
use of gas

NOTE: Se expressed other warn of merchar default, br purchase I

Do not cor

STORAGE
Store in a sunlight or

PESTICID
disposal of Federal La label instr. Agency, or Regional C

CONTAIN
application landfill, or

EPA Est. No. 415

Call 1-800-611-1659 for Technical Information
Sterilex Corporation
Owings Mills, MD 21117
www.sterilex.com

EPA Reg. No. 63761-2
Reorder Number: CW502
Net Weight _____
Lot No _____

11/07 AZW/JC

STERILEX ULTRA-KLEEN™ CW502

DOSAGE RATES. Initial Dose for badly fouled systems. Add 5 to 20 lbs. Ultra-Kleen CW-502 per 1000 gallons water contained in the system.
Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 to 5 lbs. Ultra-Kleen CW-502 per 1000 gallons of water should be employed every 2 to 5 days or as needed. The frequency of addition depends on the relative amount of bleed off, the quality of the makeup water and rate of inflow of airborne or other contaminants. Slug additions should be made in the sump of water cooling towers.

AIR WASHERS. For use only in industrial air washing systems that maintain effective mist eliminating components. Effectively removes and controls biofilm and other organic contaminants in Industrial Water Scrubbing Systems.
DOSAGE RATES. Initial Dose for badly fouled systems. Add 16 to 80 lbs. of Ultra-Kleen CW-502 per 1000 gallons of water contained in the system. If necessary, apply a solution containing 0.016 to 0.08 lbs. Ultra-Kleen CW-502 per gallon of water onto interior surfaces of the system that are not continuously submerged.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 to 5 lbs. Ultra-Kleen CW-502 per 1000 gallons of water should be employed every 1 to 5 days or as needed. The frequency of addition depends on the relative amount of bleed off, the quality of the makeup water and rate of inflow of airborne or other contaminants. Slug additions should be made in the sump of Industrial Water Scrubbing Systems.

DYE MACHINES. Effectively removes and controls biofilm and other organic contaminants in Textile Dyeing Machines.
DOSAGE RATES. Clean badly fouled systems by adding 80 to 200 lbs. of Ultra-Kleen CW-502 per 1000 gallons of water contained in a dye storage tank. Circulate the solution from the dye storage tank through the dye machine and all associated piping and other dye storage tanks. If necessary, apply a solution containing 0.08 to 0.2 lbs. Ultra-Kleen CW-502 per gallon of water onto surfaces of the system that are not continuously submerged.

WATER-JET LOOMS. Effectively removes and controls biofilm and other organic contaminants in Water-Jet Looms.
DOSAGE RATES. Initial Dose for badly fouled systems. Prepare a solution of 0.08 to 0.20 lbs. of Ultra-Kleen CW-502 per gallon of water and pump through the Water-Jet Loom and all associated piping. If necessary, apply a solution containing 0.08 to 0.2 lbs. Ultra-Kleen CW-502 per gallon surfaces of the system that are not continuously submerged.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 0.2 to 1.0 lbs. Ultra-Kleen CW-502 per 1000 gallons of daily water use should be employed every 1 to 5 days or as needed. The frequency of addition depends on the quality of the makeup water and rate of inflow of airborne or other contaminants.

TANKS AND PIPING USED TO STORE AND CONVEY INDUSTRIAL PROCESS WATER OR AQUEOUS MIXTURES. Do Not Use In equipment that will contact food. Effectively removes and controls biofilm and other organic contaminants in Tanks and Piping used to store and convey Industrial Process Water or Aqueous Mixtures.

DOSAGE RATES. Fill equipment as completely as possible with a solution of 40 to 400 lbs. of Ultra-Kleen CW-502 per 1000 gallons of system capacity. Circulate for at least 4 hours and then drain system. Rinse system with 6 volumes of water. If necessary, apply a solution containing 0.04 to 0.2 lbs. Ultra-Kleen CW-502 per gallon onto surfaces of the equipment that are not submerged.

DEIONIZED WATER SUPPLY SYSTEMS NOT USED IN FOOD PROCESSING, FOR HUMAN DRINKING WATER OR IN DENTAL LINES. Effectively removes and controls biofilm and other organic contaminants in Tanks, Filters and Piping used to store and convey Deionized Water. Do Not Use where deionized water will be used for food processing, for human drinking water or for medicinal/dental procedures.
DOSAGE RATES. Add 16 to 80 lbs. of Ultra-Kleen CW-502 per 1000 gallons of system capacity. Circulate for at least 4 hours and then drain system. Rinse system with 6 volumes of water. If necessary, apply a solution containing 0.016 to 0.08 lbs. Ultra-Kleen CW-502 per gallon onto surfaces of the equipment that are not submerged.

Penetrates and Removes Biofilm and Other Organic Contaminants. Use as a Bactericide, Slimicide, Mildewstat, and Algicide in:

DRAINS. Effectively removes and controls plugging and odors caused by accumulation of biofilm and other organic contaminants in drains. Prevents stoppage and odors.
DOSAGE RATES. Initial Dose for badly fouled systems. Pour from 6 oz. Ultra-Kleen CW-502 around or into one-inch diameter or smaller drains up to 54 oz. Ultra-Kleen CW-502 around or into three-inch diameter drains. If the drain is not in use at the time, follow with one gallon of hot water for every 6 oz. of Ultra-Kleen CW-502 added. Allow to stand for 30 minutes. Repeat until control is evident.

Subsequent Dose: When microbial control is evident, subsequent additions of 1 oz. Ultra-Kleen CW-502 into one-inch diameter or smaller drains up to 9 oz. Ultra-Kleen CW-502 into three-inch diameter drains, followed by one gallon of hot water for every 1 oz. of Ultra-Kleen CW-502 added should be employed every 7 days or as needed.

CHAIR SIDE EVACUATOR TRAPS AND PUMP FILTER TRAPS. Effectively removes and controls plugging and odors caused by accumulation of biofilm in chair side evacuator traps and pump filter traps. Prevents stoppage and odor.

DOSAGE RATES. Initial Dose for badly fouled systems. Dissolve 6 oz. of Ultra-Kleen CW-502 into one gallon of hot water at the end of the working day. Draw all of the solution into the trap and allow to stand overnight. Repeat until control is evident.

Subsequent Dose: When microbial control is evident, subsequent slug additions of 1 oz. Ultra-Kleen CW-502 dissolved into one gallon of hot water should be employed every 7 days or as needed.

FOR PRE-CLEANING OF WHIRLPOOL BATHTUBS dissolve 0.5 oz. of Sterilex Ultra-Kleen CW-502 in 1 gal. tap water and circulate through tub and associated piping and filters at a temperature $\geq 80^\circ\text{F}$.

PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS
DANGER. Powder corrosive to skin and eyes. Powder causes irreversible eye damage and skin burns. Harmful if powder is swallowed or absorbed through skin. Wear goggles and/or face shield, protective clothing and rubber gloves. Wash thoroughly with soap and water after handling. Remove contaminated clothing and wash clothing before reuse.

ENVIRONMENTAL HAZARDS. This product is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, ocean or other waters unless in accordance with the requirements of a National Pollution Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do

not discharge effluent containing this product to sewer systems without previously consulting the local sewage treatment plant authority. For guidance, contact your Local State Water Board or Regional Office of the EPA.

PHYSICAL AND CHEMICAL HAZARDS. When exposed to fire, Ultra-Kleen CW-502 may release oxygen and oxides of carbon and/or nitrogen.

FIRST AID

Have this product container on hand with you when calling a poison control center or doctor, or going for treatment.

IF IN EYES: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing. Call a poison control center or doctor for treatment advice.

IF ON SKIN: Remove contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.

IF POWDER IS SWALLOWED: Call a poison center or doctor immediately for medical advice. Do not induce vomiting or give anything by mouth to an unconscious person. Drink promptly a large quantity of milk, egg whites, gelatin, or if these are not available, drink large quantities of water. Avoid alcohol.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage.

NOTE: Seller warrants that this product complies with the specifications expressed in this label. Seller makes no other warranties, and disclaims all other warranties, express or implied, including but not limited to warranties of merchantability and fitness for the intended purpose. Seller's liability or default, breach or failure under this label shall be limited to the amount of the purchase price. Seller shall have no liability for consequential damages.

STORAGE AND PESTICIDE DISPOSAL

Do not contaminate water, food or feed by improper storage or disposal.

STORAGE: Keep product in closed original container when not in use. Store in a cool, dry area away from potential sources of heat, open flames, sunlight or other chemicals. Product should be stored below 100°F.

PESTICIDE DISPOSAL. Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide, spray mixture or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste Representative at the nearest EPA Regional Office for guidance.

CONTAINER DISPOSAL: Completely empty plastic liner bag into application equipment. Dispose of empty liner and drum in a sanitary landfill, or incinerate. Burn only if allowed by state and local authorities.



Call 1-800-611-1669 for Technical Information
 Sterilex Corporation
 Owings Mills, MD 21117
www.sterilex.com

EPA Est. No. 4876-NJ-001
 44636-CA-001
 21737-MN-01
 062788-AL-01

1 and use as at and

vey used in ater or

Filter

lrum 0% 0% 0%

:N

and First

resistant

COOLING

minants in such as

575