

64470-19 8/20/98 page 183
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

AUG 20 1998

Clearon Corporation
c/o Edward W. Lyle
1805 - 45th Street, N.W.
Washington, DC 20007-2070

Attention: Edward W. Lyle
Authorized Agent

Subject: CDB-90 Industrial Water Biocide 7 Ounce Tablets,
EPA Registration Number 69470-19
Your Amendment Dated July 1, 1998

The amendment referred to above, submitted in connection with registration under the Federal Insecticide, Fungicide, and Rodenticide Act, as amended, to add a swimming pool use to your label is acceptable provided that you make the labeling change listed below before you release the product for shipment bearing the amended labeling.

Under the Active Ingredient: "Trichloro-s-Triazinetrione" delete "& Related Compounds".

A stamped copy is enclosed for your records. Submit one copy of the final printed label before you release the product for shipment bearing the amended label.

If you have any questions concerning this letter, please contact Delores Williams at (703) 308-6372.

Sincerely,



Robert S. Brennis
Product Manager (32)
Regulatory Management Branch II
Antimicrobials Division (7504C)

CONCURRENCES							
SYMBOL							
SURNAME							
DATE							

Clearon Corp.

CDB®-90

INDUSTRIAL WATER BIOCIDES 7 OUNCE TABLETS

Active Ingredient:

Trichloro-s-Triazinetrione & Related Compounds	99%
Inert Ingredients	1%
Total	100%
Available Chlorine	90%

**KEEP OUT OF REACH OF CHILDREN
DANGER!**

SEE PRECAUTIONARY STATEMENTS
ON SIDE PANEL

STATEMENT OF PRACTICAL TREATMENT (First Aid):

If swallowed: Drink promptly large quantities of water. Do not induce vomiting. Avoid alcohol.

Never give anything by mouth to an unconscious person. Call a physician or poison control center immediately.

If in eyes: Hold eyelids open and flush with a steady, gentle stream of water for 15 minutes. Get medical attention.

If on skin: Wash with plenty of soap and water. Get medical attention.

If inhaled: Remove victim to fresh air. If not breathing, give artificial respiration, preferably mouth-to-mouth. Get medical attention.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage.

EPA REG. NO. 69470-19
EPA EST. NO. 69470-MI-1

ACCEPTED

with COMMENTS

Letter Dated:

• CLEARON CORP.
• 95 MacCORMIE AVENUE, SW
• SOUTH CHARLESTON, WV 25303-1411

NET WT.

Under the Federal Insecticide,
Fungicide, and Rodenticide Act as
amended, for the pesticide

Made in U.S.A. Printed in U.S.A. Registered under EPA Reg. No.
rev. 4/96

69470-19

PRECAUTIONARY STATEMENTS: HAZARD TO HUMANS AND DOMESTIC ANIMALS:

DANGER:

CORROSIVE: Causes irreversible eye damage and skin burns. May be fatal if absorbed through skin. May be fatal if inhaled. Do not breathe dust or spray mists. Irritating to nose and throat. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield, protective clothing and rubber gloves when handling this product. Wash thoroughly with soap and water after handling and before eating, drinking or using tobacco. Remove contaminated clothing and wash before reuse.

CHEMICAL HAZARDS. DANGER: Strong oxidizing agent. Use only clean dry utensils. Mix only into water. Contamination with moisture, dirt, organic matter or other chemicals (including other pool chemicals) or any other foreign matter may start a chemical reaction with generation of heat, liberation of hazardous gases and possible generation of fire and explosion. Avoid contact with flammable or burning material such as a lighted cigarette. Do not use this product in any chlorinating device which has been used with any inorganic or unstabilized chlorinating compounds (e.g., calcium hypochlorite). Such use may cause fire or explosion.

ENVIRONMENTAL HAZARD: This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, ponds, streams, estuaries, oceans or public waters unless this product is specifically identified and addressed in an NPDES permit. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

STORAGE AND DISPOSAL: Keep product dry in tightly closed container when not in use. Store in a cool, dry, well-ventilated area away from heat or open flame. Do not reuse empty container. Rinse empty container thoroughly with water to dissolve all material before discarding. Securely wrap container in several layers of newspaper and discard in trash.

DIRECTIONS FOR USE: It is a violation of federal law to use this product in a manner inconsistent with its labeling.

For Use in Industrial Recirculating Water Cooling Towers, Air Washers & Evaporative Condensers.

Treatment with this product is an effective way to control the growth of bacterial and algae in industrial recirculating water cooling towers, air washers and evaporative condensers. 1. Badly fouled systems should be cleaned prior to initiating treatment. 2. Initial Dosage - When the system is just noticeably fouled, add 8 oz. of this product per 10,000 gallons of water contained in the system. Repeat this dosage, if necessary, until free available chlorine level (FAC) of 0.5-1.0 ppm is obtained (as determined by use of a reliable test kit). 3. Maintenance Dosage - To obtain a FAC of 0.5-1.0 ppm, add 0.8-1.6 oz. of this product per 10,000 gallons of water daily or as needed. 4. This product should be added to the system at a point where adequate flow is maintained. Variations in water temperature, chlorine demand and flow rate will affect the dissolution rate. Warmer seasons may require an upward adjustment of the FAC. Air Washers For use only in industrial air washer systems that maintain effective mist eliminating components. Hypochlorite controls slime-forming bacteria and fungi in air washer systems. This product may be added to the system either continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend on the severity of the problem. **BADLY FOULED SYSTEMS** should be cleaned prior to initiating treatment. 1. Initial Dosage - When the system is just noticeably fouled, add 0.4-0.5 lbs. of this product per 10,000 gallons of water contained in the system. Repeat this dosage, if necessary, until a free available chlorine level (FAC) of 0.5-1.0 ppm is obtained (as determined by use of a reliable test kit). 2. Maintenance Dosage - To maintain a FAC of 0.5-1.0 ppm, add 0.8-1.6 oz. of this product per 10,000 gallons of water, daily or as needed. 3. This product should be added to the system at a point where adequate flow is maintained. Variations in water temperature, chlorine demand and flow rate will affect the dissolution rate. Warmer seasons may require an upward adjustment of the FAC.

CDB® is a registered trademark of Clearon Corp.

DIRECTIONS FOR USE

Swimming Pool Use

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

1. Adjust and maintain pool water pH in a range of 7.2-7.8 as indicated by available test kit. Use suitable agents to lower or increase pH. Follow instructions for use on the label of these products.
2. For maximum effectiveness it is recommended that the pool be first stabilized with 40-60 ppm Cyanuric Acid to reduce chlorine loss in sunlit pools. Follow instructions on the label of the product used. This product introduces chlorine and additional Cyanuric Acid into the pool to assure the stabilizing effect.
3. Place one (1) 3" tablet for each 10,000 gallons of pool water every 7-10 days into suitable tablet feeder like a floating dispenser or directly into a skimmer basket or automatic chlorinator.
4. A free available chlorine level of 1.0 - 1.5 ppm should be maintained. Check pool frequently with a test kit and maintain residual chlorine level between 1.0 and 1.5 ppm and pH of 7.2 - 7.8.

REENTRY: Reentry into treated swimming pools is prohibited above levels of 3 ppm of chlorine due to risk of bodily injury.

HOW TO CALCULATE POOL CAPACITY

SHAPE OF POOL

GAL. OF WATER (Dimensions in feet)

Rectangular	Average depth x average length x average width x 7.5
Circular	Diameter x diameter x average depth x 5.9
Oval with straight sides	Full width x full length x average depth x 6.7
Irregular	Consult pool builder

