

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

NOV - 8 2001

Robert Rosenwasser
Clearon Corporation
2115 Linwood Avenue
Fort Lee, NJ 07024

Subject: CBD-90 Industrial Water Biocide 7 Ounce Tablets
EPA Registration No. 69470-19
Amendment dated August 10, 2001

Dear Mr. Rosenwasser:

The amendment referred to above submitted in connection with registration under the Federal Insecticide, Fungicide and Rodenticide Act, as amended to update your Confidential Statement of Formula and revise your to label in comply with the provisions of PR Notice 2001-1, will be acceptable provided that you make the labeling changes listed below before you release the product for shipment bearing the amended label.

1. Under the For Use in Industrial Recirculating Water Cooling Towers, Air Washers & Evaporative Condensers.
 - a. The number 1 should precede "1. Badly fouled systems should . . ."
 - b. The number 2 should read "add 8 oz. of this product to 10,000 gallons of water" not "add 10 13 oz. of this product"
2. Under specific directions for use for Air Washer
 - a. Number 1 says to "... add 10-13 ounces of this product to 10,000 gallons of water. . ." the last accepted label say to "add 0.4-0.5 lbs of this product to 10,000 gallons of water. . ."
 - b. Number 2 states "add 1-3 oz." the current label states "add 0.8-1.6 oz. of this product per 10,000 gallons of water."

CONCURRENCES							
SYMBOL	7510C						
SURNAME	Mitchell						
DATE	11-8-01						

3. *Revise the label to add the enclosed Pesticide Disposal and Container Disposal language under Storage and Disposal.*

The Confidential Statement of Formula dated August 10, 2001, is acceptable. The requirements of PR Notice 91-2 were satisfied, the nominal concentration of the active ingredient given in the basic formulation agreed with the percentages declare on the label. The CSF has been made a part of the file for this product.

A stamped copy of your labeling is enclosed for your records. Submit one copy of the final printed label prior to release of the product for shipment.

If you have any questions concerning this letter, please contact Wanda Mitchell at (703) 308-6345.

Sincerely,



*Robert S. Brennis
Product Manager 32
Regulatory Management Branch II
Antimicrobials Division*

CDB®-90 INDUSTRIAL WATER BIOCIDES 7 OUNCE TABLETS

Active Ingredient:
Trichloro-s-triazinetriene: 99%
Inert Ingredients: 1%
Total: 100%
Available Chlorine: 90%

KEEP OUT OF REACH OF CHILDREN

DANGER

SEE PRECAUTIONARY STATEMENTS AND
 FIRST AID INFORMATION
 BELOW

DIRECTIONS FOR USE: It is a violation of Federal Law to use this product in a manner inconsistent with its labeling. Read entire label and use strictly in accordance with precautionary statements and directions.

FOR SWIMMING POOL DISINFECTANT

When used as directed, this product is effective as a swimming pool water disinfecting agent.

DIRECTIONS FOR USE

Ensure all pool equipment is working properly. Backwash the filter system following manufacturer's directions. Adjust pH to between 7.2-7.6. Add stabilizer to establish a minimum level of 40-60 ppm to reduce degradative effects of sunlight upon the chlorine residual. Check for metals. Before using this product, add stain and scale inhibitor to prevent staining of pool surface due to metals. When using other products as outlined in the directions for this product, always follow directions on those products.

With pump running, place one (1) tablet per 10,000 gallons pool water every week into a suitable feeder like a floating dispenser or directly into a skimmer basket or automatic chlorinator. Repeat additions until a residual of 1-3 ppm chlorine is established as determined by the use of a test kit. Regular use of a test kit is necessary to determine when it is necessary to add another dose of this product to maintain a residual of 1-3 ppm available chlorine in the pool water. After use of this product it is recommended that a preventative algae treatment be added on a weekly basis.

HOW TO CALCULATE POOL CAPACITY

SHAPE OF POOL	GAL. OF WATER (Dimensions in feet)
Rectangular	Average depth X average length X average width X 7.5
Circular	Diameter X diameter X average depth X 5.9
Oval with straight sides	Full width X full length X average depth X 6.7
Irregular	Consult pool builder

REENTRY

Reentry into treated swimming pools is prohibited above levels of 3 ppm of chlorine due to risk of bodily injury.

FOR USE IN INDUSTRIAL RECIRCULATING WATER, COOLING TOWERS, AIR WASHERS & EVAPORATIVE CONDENSERS:

Treatment with this product is an effective way to control the growth of bacteria and algae in industrial recirculating water cooling towers, air washers and evaporative condensers.

Badly fouled systems should be cleaned prior to initiating treatment. 2. Initial Dosage - When the system is just noticeably fouled, add 10-13 oz. of this product per 10,000 gallons of water contained in the system. Repeat this dosage, if necessary, until free available chlorine level (FAC) of 0.5-1.0 ppm is obtained (as determined by use of a reliable test kit). 3. Maintenance Dosage - To obtain a FAC of 0.5 - 1.0 ppm, add 1-3 oz. of this product per 10,000 gallons of water daily or as needed. 4. This product should be added to the system at a point where adequate flow is maintained. Variations in water temperature, chlorine demand and flow rate will affect the dissolution rate. Warmer seasons may require an upward adjustment of the FAC.

Air Washers For use only in industrial air washer systems that maintain effective mist eliminating components. Hypochlorite controls slime-forming bacteria and fungi in air washer systems. This product may be added to the system either continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend on the severity of the problem. **BADLY FOULED SYSTEM** should be cleaned prior to initiating treatment. 1. Initial Dosage - When the system is just noticeably fouled, add 10-13 oz. of this product per 10,000 gallons of water contained in the system. Repeat this dosage, if necessary, until a free available chlorine level (FAC) of 0.5-1.0 ppm is obtained (as determined by use of a reliable test kit). 2. Maintenance Dosage - To maintain a FAC of

0.5-1.0 ppm, add 1-3 oz. of this product per 10,000 gallons of water, daily or as needed. 3. This product should be added to the system at a point where adequate flow is maintained. Variations in water temperature, chlorine demand and flow rate will affect the dissolution rate. Warmer seasons may require an upward adjustment of the FAC.

EPA REG. NO. 69470-19
 EPA EST. NO. 69470-WV-2

CLEARON CORP.
95 MacCORKLE AVENUE, SOUTH CHARLESTON, WV 25303-4441

NOV - 8 2001

NET WT. Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the production, registered under EPA Reg. No. 69470-19

Made in U.S.A.

Printed in U.S.A.

CDB® is a registered trademark of Clearon Corp.



**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC
ANIMALS**

**DANGER
CORROSIVE
CAUSES IRREVERSIBLE EYE DAMAGE
AND SKIN BURNS
MAY BE FATAL IF INHALED OR
ABSORBED THROUGH SKIN**

Do not breathe dust or spray mists. Irritating to nose and throat. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield, protective clothing and rubber gloves when handling this product. Wash thoroughly with soap and water after handling and before eating, drinking or using tobacco. Remove contaminated clothing and wash before reuse.

PHYSICAL OR CHEMICAL HAZARDS

STRONG OXIDIZING AGENT: Use only clean dry utensils. Mix only into water. Contamination with moisture, dirt, organic matter or other chemicals (including other pool chemicals) or any other foreign matter may start a chemical reaction with generation of heat, liberation of hazardous gases and possible generation of fire and explosion. Avoid any contact with flaming or burning material such as a lighted cigarette. Do not use this product in any chlorinating device which has been used with any inorganic or unstabilized chlorinating compounds (e.g., calcium hypochlorite). Such use may cause fire or explosion.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, ponds, streams, estuaries, oceans, or public waters unless in accordance with the requirements of a National Pollution Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

EMERGENCY HANDLING: In case of contamination or decomposition do not reseal container. If possible, isolate container in open well-ventilated area. Flood with large volumes of water. Dispose of contaminated material in an approved landfill area.

STORAGE AND DISPOSAL: Keep product dry in tightly closed container when not in use. Store in a cool, dry, well-ventilated area away from heat or open flame. Do not reuse empty container. Rinse empty container thoroughly with water to dissolve all material before discarding. Discard in trash.

4
8
4