69470-28

12-9-2002

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

1/4

December 9, 2002

Robert Rosenwasser Manager, Regulatory Affairs Clearon Corporation 2115 Linwood Avenue Fort Lee, NJ 07024

Subject: Clearon Granular Trichlor EPA Registration Number 69470-28 Amendment Dated: September 24, 2002 EPA Receipt Date: September 25, 2002

Dear Mr. Rosenwasser:

The following amendment, submitted in connection with registration under the Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA), as amended, is acceptable with the conditions listed below:

- to add disinfection of drinking water
- to add aquatic food use pattern

Conditions

You must add the following re-entry language after the start-up of newly filled pools and maintenance treatment sections of the Swimming Pool directions for use.

Reentry into treated swimming pools is prohibited above levels of 3 ppm of chlorine due to risk of bodily harm.

General Comments

A stamped copy of the labeling accepted with conditions is enclosed. Submit a copy of your final printed labeling before distributing or selling the product bearing the revised labeling.

CONCURRENCES								
SYMBOL	7510C							
SURNAME	Lutchell							
DATE)	12-9-02							

Printed on Recycled Paper

OFFICIAL FILE COPY

Should you have any questions or comments concerning this letter, please contact Wanda Mitchell at (703) 308-6345.

,

Sincerely,

Robert S. Brennis Product Manager - Team 32 Regulatory Management Branch II Antimicrobials Division (7510C)



CLEARON GRANULAR TRICHLOR



PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER

CORROSIVE CAUSES IRREVERSIBLE EYE DAMAGE MAY BE FATAL IF INHALED HARMFUL IF SWALLOWED OR ABSORBED THROUGH SKIN

Do not get in eyes, on skin, or on clothing. Do not breathe dust, vapor or sprav mist. Wear goggles, face shield, or safety glasses. Wash thoroughly with soap and water after handling and before eating, drinking or using tobacco. Remove contaminated clothing and wash before reuse.

PHYSICAL OR CHEMICAL HAZARDS

STRONG OXIDIZING AGENT: Use only clean dry utensils. Mix only into water. Contamination with moisture, dirt, organic matter or other chemicals (including other pool chemicals) or any other foreign matter may start a chemical reaction with generation of heat, liberation of hazardous gases and possible generation of fire and explosion. Avoid any contact with flaming or burning material such as a lighted cigarette. Do not use this product in any chlorinating device which has been used with any inorganic or unstabilized chlorinating compounds (e.g., calcium hypochlorite). Such use may cause fire or explosion.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, ponds, streams, estuaries, oceans, or public waters unless in accordance with the requirements of a National Pollution Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

EMERGENCY HANDLING: In case of contamination or decomposition do not reseal container. If possible, isolate container in open well-ventilated area. Flood AGCERTHD volumes of water. Dispose of contaminated willer a Charles in TS approved landfill area.

CLEARON CORP. 95 MacCORKLE AVENUE, SW SOUTH CHARLESTON, WV 25303-1411

EPA REG. NO. 69470-28 EPA EST. NO. 69470-WV-2

Under the Federal Insecticide. NET WT. ____ Fungicide, and Rodenticide Act as amended, for the pesticide, registered under EPA Reg. No. 69470 -28

Гна

Active Ingredient:	
Trichloro-s-triazinetrione:	99%
Inert Ingredients:	1%
Total:	100%
Available Chlorine:	90%

KEEP OUT OF REACH OF CHILDREN DANGER

SEE PRECAUTIONARY STATEMENTS AND FIRST AID INFORMATION

BELOW						
FIRST AID						
lf in eyes	 Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control center or doctor for treatment advice. 					
lf inhaled	 Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control center or doctor for further treatment advice. 					
lf on skin clothing	 Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice. 					
if swallowed	 Call poison control center, or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by the poison control center or doctor. Do not give anything by mouth to an unconscious person. 					
Have the produc D poison contro	t container or label with you when calling a location of label with you when calling a					

NOTE TO PHYSICIAN EPA Letter Dated Note to Physician: Probable mucosal damage may DEC - 9 2007 contraindicate the use of gastric lavage."



in a sanitary landfill, or incineration, or if allowed by state and local authorities, by burning. If burned, stay out of smoke.

> DIRECTIONS FOR USE: It is a violation of Federal Law to use this product in a manner inconsistent with its labeling. Read entire label and use strictly in accordance with precautionary statements and directions.

Do not contaminate water, food or feed by storage or disposal.

Store in a dry, cool and well-ventilated area: Avoid moisture

getting into container. Keep off wet floors. In case of spillage,

container tightly closed. Oxidizing material. Keep away from

flames, sparks and all sources of heat. Avoid contact with

PESTICIDE DISPOSAL: Pesticide wastes are acutely

hazardous. Improper disposal of excess pesticide, spray mixture or rinsate is a violation of Federal law. If these wastes

cannot be disposed of by use according to label instructions,

or the Hazardous Waste representative at the nearest EPA

CONTAINER DISPOSAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of

contact your State Pesticide or Environmental Control Agency.

wash with large amounts of water. After each use, keep

FOR SWIMMING POOL DISINFECTANT

When used as directed, this product is effective as a swimming pool water disinfecting agent.

DIRECTIONS FOR USE:

STORAGE AND DISPOSAL

Regional Office for guidance.

organic material.

Ensure all pool equipment is working properly. Backwash the filter system following manufacturer's directions. Adjust pH between 7.2-7.6. Add stabilizer to establish a minimum level of 40-60 ppm to reduce the degradative effects of sunlight upon the chlorine residual. When using other products as outlined in the instructions for this product, always follow directions on those products.

FOR START UP OF NEWLY FILLED POOLS

Before using this product, make sure that the filtration system is clean and operating property. Adjust the pH of the water to the range of 7.2-7.6 using suitable products and a reliable test kit. Adjust the alkalinity of the water to a minimum of 125 ppm (mg/L), based on the test kit reading.

MAINTENANCE TREATMENT

Add this product to the granular feeder (or chlorinating device). Adjust the feeder to maintain the free available chlorine level in the water at 1-3 ppm (mg/L) as indicated by a reliable test kit. Periodically refill the feeding device with enough product to assure a constant treatment level of 1-3 ppm (mg/L) available chlorine. Weather and usage effect sanitizer levels. In addition,

some oils. I or sloudy+ y Maintain th ppm mg/L) To Initiatly product per oallons of w When the t or wheneve should be d

HOW TO

SHAPE O

Rectangul

Circular

Oval with

irregular

FOR SUF The pool seven da 0.5 ppm total and Add a suf to the sur level to combined the shock of 10 ou gallons (approxim combined water ha shock tre

REENTR Reentry i

levels of

FOR SW When us pool of u PLASTE lined, fiberglass or colored plaster surface pools as damage may occur to the pool surface. Read entire label and use strictly in accordance with precautionary statements and directions.

DIRECTIONS FOR USE

Before using this product, shut off pump and brush all surface clinging algae. Wait four hours for the water to become stationary before product application. At night or when the pool is not in use, broadcast this product directly into the water in the deep end of the pool. Use two pounds of this product per 10,000 gallons for medium to heavy algae growth and one pound per 10,000 gallons for light algae growth. Twelve to twenty-four hours after chemical treatment, turn pump on and vacuum dead algae through the filter. Brush any remaining algae and clean backwash filter. If algae is still visible, repeat treatment.

DISINFECTION OF DRINKING WATER (EMERGENCY/PUBLIC/INDIVIDUAL SYSTEMS)

DIRECTIONS FOR USE: It is a violation of Federal Law to use this product in a manner inconsistent with its labeling. Read entire label and use strictly in accordance with precautionary statements and directions.

PUBLIC SYSTEM: Feed 1 ounce of this product per 9000 gallons of water until a free available chlorine residual of at least 0.2 ppm is attained throughout the distribution system. Check water frequently prescribed by the National Interim primary Drinking Water Regulations. Contact your local Health Department for further details.

INDIVIDUAL SYSTEMS: DUG WELLS- Upon completion of the casing (lining) wash the interior of the casing (lining) with a 100 ppm available chlorine solution using a stiff brush. This solution can be made by dissolving 1 ounce of this product into 60 gallons of water. After covering the well. Pour the disinfectant solution into the well through both the pipe sleeve opening and the pipeline. Wash the exterior of the pump cylinder also with the disinfectant solution. Start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Contact your local Health Department for further details.

INDIVIDUAL WATER SYSTEMS: DRILLED, DRIVEN & BORED WELLS- Run pump until water is as free from turbidity as possible. Pour a 100 ppm available chlorine disinfecting solution into the well. This solution can be made by dissolving 1 ounce of this product into 60 gallons of water. Add 5 to 10 gallons of clean, chlorinated water to the well in order to force the disinfectant into the rock formation. Wash the exterior of pump cylinder with the disinfectant, drop pipeline into well, start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Deep w with high water levels may necessitate the use of special me. us for introduction of the disinfectant into the well. Consult your local Health Department for further details.

INDIVIDUAL WATER SYSTEMS: FLOWING ARTESIAN WELLS- Artesian wells generally do not require disinfection. If analyses indicate persistent contamination the well should be disinfected. Consult your local Health Department for further details.

EMERGENCY DISINFECTION:

This product is recommended for disinfecting raw or pretreated (settled, coagulated and/or filtered) water supplies intended for use as drinking water for humans and domestic animals.

The source of the water to be treated may be a river, lake, well, cistem or similar system. To obtain the desired disinfectant results, the water to be treated should be clear and free of dirt and organic debris. If the source of the water is cloudy and contains dirt and organic debris, the water should be held in holding tanks or ponds, treated with coagulating agents and filtered to remove the dirt and organic debris.

Dissolve 0.1 ounce of this product into 60 gallons of water (120 milligrams per 10 liters) to obtain a concentration of 10-ppm (mg/L) of available chlorine. Let the water stand for one hour before using. A residual of 1ppm (mg/L) of available chlorine, as measured by a reliable test kit, should be maintained in the water to insure disinfection.

PUBLIC WATER SYSTEMS:

RESERVOIRS: ALGAE CONTROL-Continuous chlorinated is the most effective method for destroying algae, however, slug treatment can also be effective. Suitable chlorine feeding points should be selected on each stream at least 50 yards upstream from the points of entry into the reservoir. Add this product at the following rates:

Initial Dose: When the system is noticeably fouled, add this product at the rate of 1 to 5 ounces per 10,000 gallons to achieve 0.5-1.5 ppm (mg/L) available chlorine, as measured by a suitable test kit. Repeat dosage until residual is achieved.

Subsequent Dose: When control is evident, add this product at the rate of 0.3 to 1.5 ounces per 10,000 gallons to maintain 0.2-0.5 ppm (mg/L) available chlorine, as measured by a suitable test kit.

MAINS- Thoroughly flush section to be disinfected by discharging from hydrants. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of chlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.

NEW TANKS, BASIN, ETC.- Remove all physical soil from surface. Places 6 ounces of this product for each 10 cubic feet of moving capacity (500 ppm available chlorine). Fill to working pacity and allow to stand for at least 4 hours. Urain and ush with potable water and return to service.

NEW_FILTER_SAND-Apply 12 ounces of this product for each 150 to 200 cubic feet of sand. The action of the product dissolving as the water passes through the bed will aid in disinfecting the new sand.

NEW WELLS-Flush the casing with à 50 ppm available chlorine solution of water containing 0.8 ounces of this product for each 100 gallons of water. The solution should be pumped or fed by gravity into the well after thorough mixing with agitation. After 24 hours flush well until all traces of chlorine have been removed from the water. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary. Contact you local Health Department for further details.

EXISTING EQUIPMENT- remove equipment from service, thoroughly clean surfaces of all physical soil. Sanitize by placing 6 ounces of this product for each 10 cubic feet capacity (approximately 500 ppm available chlorine) Fill to working capacity and let stand at least 4 hours. Drain and place in service. If the previous treatment is not practical, surfaces may be sprayed with a solution containing 0.8 ounces of this product for each 5 gallons of water (approximately 1000 ppm available chlorine). After drying, flush with water and return to service.

EMERGENCY DISINFECTION AFTER FLOODS:

WELLS- thoroughly flush contaminated casing with 500 ppm available chlorine solution. Prepare this solution by mixing 0.8 ounces of this product with 10 gallons of water. Backwash the well to increase yield and reduce turbidity, adding sufficient chlorinating solution to the backwash to produce a 10 ppm available chlorine residual, as determined by a chlorine test kit. After the turbidity has been reduced and the casing has been treated, add sufficient chlorinating solution to produce a 50-ppm available chlorine residual. After 24 hours, flush well until all traces of chlorine have been removed from the water. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary. Retreat well if water samples are biologically unacceptable. Contact your local Health Department for further details.

RESERVOIRS In case of contamination by overflowing streams, establish chlorinating stations upstream of the reservoir. Chlorinate the inlet water until the entire reservoir obtains a 0.2 ppm available chlorine residual, as determined by a suitable chlorine test kit. In case of contamination from surface drainage, apply sufficient product directly to the reservoir to obtain a 0.2 ppm available chlorine residual in all parts of the reservoir.

BASIN, TANKS, FLUMES, ETC.- Thoroughly clean all equipment, then apply 6 ounces of product per 10 cu. ft. of water to obtain 500 ppm available chlorine, as determined by a suitable test kit. After 24 hours drain flush and return service. If the previous method is not suitable, spray or flush the equipment with a solution containing 0.8 ounces of this product for each 5 gallon of water (1000 ppm available chlorine.) Allow to stand for 2 to 4 hours, flush and return to service.

FILTERS- When the sand filter needs replacement, apply 12 punces of this product for each 150 to 200 cubic feet of sand. Witten, the filter is severely contaminated, additional product should be distributed over the surface at the rate of 12 ounces per 20 sq. ft. Water should stand at a depth of 1 foot above the surface of the filter bed for 4 to 24 hours. When filter beds can be back-washed of mud and silt, apply 12 ounces of this product per each 50 sq. ft., allowing the water to stand at a depth of 1 foot above the filter sand. After 30 minutes, drain water to the level of the filter. After 4 to 6 hours drain, and proceed with normal back washing.

DISTRIBUTION SYSTEM-flush repaired or replaced section with water. Establish a chlorinating station and apply sufficient product until a consistent available chlorine residual of a least 10 ppm (as measured by a chlorine test kit) remains after a 24 retention time.

EMERGENCY DISINFECTION AFTER FIRES

CROSS CONNECTIONS OR EMERGENCY CONNECTIONS-Set up a chlorine feed system near in the intake of the untreated water supply. Add 0.75 ounces of this product per 1,000 gallons of water until a chlorine residual of at least 0.2 ppm (as measured by a chlorine test kit) at the point where the untreated supply enters the regular distribution system.

EMERGENCY DISINFECTION AFTER DROUGHT:

SUPPLEMENTARY WATER SUPPLIES A chlorine feed system should be set up on the supplementary water line. The product should be added at 0.45 ounces per 1,000 gallons until a minimum chlorine residual of 0.2 ppm (as measured by a chlorine test kit) is achieved. The water should be held for 20 minutes before use.

WATER SHIPPED IN BY TANKS, TANK CARS, ETC.-Thoroughly clean all containers and equipment. Spray a 500 ppm available chlorine solution and rinse with potable water after 5 minutes. This solution is made by mixing 0.8 ounces of this product for each 5 gallons of water. During the filling of the containers, dose with sufficient amounts of this product to provide at least a 0.2 ppm chlorine residual, as measured by a chlorine test kit.

EMERGENCY DISINFECTION AFTER MAIN BREAKS;

MAINS-Before assembly of the repair section, flush out mud and soil. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of chlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.