



U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Pesticide Programs
Antimicrobials Division (7510P)
1200 Pennsylvania Ave., N.W.
Washington, D.C. 20460

EPA Reg. Number:

95427-3

Date of Issuance:

10/11/22

NOTICE OF PESTICIDE:

Registration
 Reregistration
(under FIFRA, as amended)

Term of Issuance:

Conditional

Name of Pesticide Product:

Zebion 480SL

Name and Address of Registrant (include ZIP Code):

Cristina Griffin
Klenzoid, Inc.
Electronic Transmittal: [cgriffin@delta-ac.com]

Note: Changes in labeling differing in substance from that accepted in connection with this registration must be submitted to and accepted by the Antimicrobials Division prior to use of the label in commerce. In any correspondence on this product always refer to the above EPA registration number.

On the basis of information furnished by the registrant, the above named pesticide is hereby registered under the Federal Insecticide, Fungicide and Rodenticide Act (FIFRA).

Registration is in no way to be construed as an endorsement or recommendation of this product by the Agency. In order to protect health and the environment, the Administrator, on his motion, may at any time suspend or cancel the registration of a pesticide in accordance with the Act. The acceptance of any name in connection with the registration of a product under this Act is not to be construed as giving the registrant a right to exclusive use of the name or to its use if it has been covered by others.

This product is conditionally registered in accordance with FIFRA section 3(c)(7)(A). You must comply with the following conditions:

1. Submit and/or cite all data required for registration/reregistration/registration review of your product under FIFRA when the Agency requires all registrants of similar products to submit such data.

Signature of Approving Official:

Tara Flint, Acting Product Manager 31
RMBI, Antimicrobials Division (7510P)

Date:

10/11/22

2. You are required to comply with the data requirements described in the DCI or EDSP Order identified below:

a. Ammonium Sulfate GDCI-005601-1586

You must comply with all of the data requirements within the established deadlines. If you have questions about the Generic DCI or EDSP Order listed above, you may contact the Reevaluation Team Leader (Team 36): <http://www2.epa.gov/pesticide-contacts/contacts-office-pesticide-programs-antimicrobial-division>

3. Make the following label changes before you release the product for shipment:

- Revise the EPA Registration Number to read, “EPA Reg. No. 95427-3.”

4. Submit one copy of the final printed label for the record before you release the product for shipment.

Should you wish to add/retain a reference to the company’s website on your label, then please be aware that the website becomes labeling under FIFRA and is subject to review by the Agency. See FIFRA section 2(p)(2). If the website is false or misleading, the product would be misbranded and unlawful to sell or distribute under FIFRA section 12(a)(1)(E). 40 CFR 156.10(a)(5) lists examples of statements EPA may consider false or misleading. In addition, regardless of whether a website is referenced on your product’s label, claims made on the website may not substantially differ from those claims approved through the registration process, FIFRA section 12(a)(1)(B). Therefore, should the Agency find or if it is brought to our attention that a website contains false or misleading statements or claims substantially differing from the EPA approved registration, the website will be referred to the EPA’s Office of Enforcement and Assurance.


If you fail to satisfy these data requirements, EPA will consider appropriate regulatory action including, among other things, cancellation under FIFRA section 6(e). Your release for shipment of the product constitutes acceptance of these conditions. A stamped copy of the label is enclosed for your records. Please also note that the record for this product currently contains the following CSFs:

- Basic CSF dated 09/14/2022

If you have any questions, please contact Karen M. Leavy by phone at (202)-566-0668, or via email at Leavy.Karen@epa.gov.

Enclosure: Stamped Label

Zebion 480SL



ACTIVE INGREDIENT	
Ammonium Sulfate	40%
OTHER INGREDIENTS	60%
TOTAL	100%

KEEP OUT OF REACH OF CHILDREN CAUTION

[If First Aid is not on front panel add: See back [side] panel for first aid [and precautionary statements]]

[SEE SDS FOR ADDITIONAL INFORMATION]

Manufactured By [For]
Klenzoid, Inc.
912 Spring Mill Ave
Conshohocken, PA 19428
800-825-9495

EPA REG NO: 95427-
EPA EST NO: 95427-PA-1

NET CONTENTS:

PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed, inhaled, or absorbed through skin. Avoid breathing vapor. Avoid contact with skin, eyes, or clothing. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, using tobacco, or using the toilet. Remove and wash contaminated clothing before reuse.

{First Aid can be in bulleted or paragraph format; may be on any panel}

FIRST AID

If on skin or clothing:

- Take off contaminated clothing.
- Rinse skin immediately with plenty of water for 15-20 minutes.
- Call a poison control center or doctor for treatment advice.

If swallowed:

- Call a poison control center or doctor immediately for treatment advice.
- Have person sip a glass of water if able to swallow.
- Do not induce vomiting unless told to do so by a poison control center or doctor.
- Do not give anything by mouth to an unconscious person.

If inhaled:

- Move person to fresh air.
- If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth if possible.
- Call a poison control center or doctor for further treatment advice.

If in eyes:

- Hold eye open and rinse slowly and gently with water for 15-20 minutes.
- Remove contact lenses, if present, after the first 5 minutes, then continue rinsing.
- Call a poison control center or doctor for treatment advice.

Have the product container or label with you when calling a poison control center or doctor, or going for treatment. In Case of Emergency Call CHEMTREC at 800-424-9300.

ENVIRONMENTAL HAZARDS

The pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

PHYSICAL AND CHEMICAL HAZARDS

Direct mixing of this product with sodium hypochlorite solutions and other strong oxidizing and alkali chemicals will release hazardous gases. Only mix with other chemicals or materials as specified in the Directions for Use of this product.

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

This product must be used in conjunction with: 1) EPA registered sodium hypochlorite (12.5%) to produce monochloramine and 2) the Zebion 480SL feeder/delivery system, at a pH of >8.5, is programmed to automatically and optimally produce a dilute solution of monochloramine. The installation, calibration and operation of the feeder/delivery system must be conducted only by Sanipur authorized and trained personnel.

To achieve a minimum molar ratio of 1:2, Zebion 480SL to sodium hypochlorite, combine 1.0 liter (0.264 gallons) of Zebion 480SL to 3.7 liters (0.977 gallons) of sodium hypochlorite (12.5%). To ensure both handling safety and effectiveness, the monochloramine solution must be generated and fed into the treatment water systems through a proper chemical feed skid only by a trained Sanipur representative. Use of this product for any other purpose or contrary to the use directions specified below is prohibited.

PULP AND PAPER MILLS WATER SYSTEMS AND PRODUCTION OF FIBERGLASS: This product is used as a microbiocide in the manufacture of paper and paperboard that contacts food. This product is also used for the control of algal, bacterial and fungal slimes, in pulp and paper mill fresh and sea water influent systems, pulp and paper mill process water systems and paper mill starch slurries. This product is applied in conjunction with sodium hypochlorite, using a closed delivery system, to form monochloramine, a slower acting less aggressive oxidizing microbiocide.

Dosage Rates: When noticeably fouled, apply sufficient product and sodium hypochlorite to achieve a total chlorine residual of at least 1 ppm in excess of the system oxidant demand. Once control is achieved, treatment rates can be reduced to sub-demand rates from 50% to 80% of system demand. The product may be added to the system continuously or intermittently as needed to any area of the system where uniform mixing can be obtained.

For intermittent treatment, mix 1.0 liter (0.264 gallons) of Zebion 480SL to 3.7 liters (0.977 gallons) of sodium hypochlorite (12.5%). Apply the solution at a rate to obtain 1 to 2 ppm in excess of the system oxidant demand (maximum of 10 ppm measured) as total chlorine in the water being treated for 5 to 60 minutes every 1 to 6 hours. The frequency of feeding and the duration of treatment will depend on the severity of the problem. Badly fouled systems must be cleaned before initial treatment.

For continuous treatment, mix 1.0 liter (0.264 gallons) of Zebion 480SL to 3.7 liters (0.977 gallons) of sodium hypochlorite (12.5%). Apply the solution at a rate to obtain 0.5 to 1 ppm in excess of system oxidant demand (maximum of 10 ppm measured) as total chlorine in the water being treated on a continuous basis. The frequency of feeding and the duration of treatment will depend on the severity of the problem. Badly fouled systems should be cleaned before initial treatment.

If chloramine is detected in the effluent, it can be neutralized by the addition of sodium metabisulfite until the chloramine is no longer detected.

INDUSTRIAL WATER SYSTEMS: Zebion 480SL is used for the control of algal, bacterial and fungal deposits in industrial cooling towers, recirculating cooling water systems, evaporative condensers, influent water systems* such as flow through filters and industrial water scrubbing systems, brewery and food pasteurizers* including industrial microbial and biofuel fermentation processes, industrial fresh water systems, source water for potable water treatment facilities, air washers, papermill starch slurries, reverse osmosis systems*, paint spray booth sumps, non-fish containing decorative fountains*, and ponds used for cooling purposes, sewage and wastewater systems. This product is also used for the control of algae, bacteria, fungi and mollusks in both seawater and freshwater influent systems.

When this product is used to treat sewage and wastewater systems, seawater, and freshwater influent systems for once-through industrial water systems and seawater desalination and reverse osmosis

systems, and the system water is not sent to a POTW; residual levels of chloramine in the effluent must be monitored and neutralized using on-line monitoring and control equipment.

When this product is used to treat recirculating cooling water systems, evaporative condensers, influent water systems (not part of once-through industrial water systems), brewery and food pasteurizers, air washers, paint spray booth sumps, and non-fish containing decorative fountains and ponds used for cooling purposes; effluent detection of chloramine should be conducted at least once per shift. If chloramine is detected in the effluent, it can be neutralized by the addition of sodium metabisulfite until the chloramine is no longer detected.

Dosage Rates: When noticeably fouled, apply sufficient product and sodium hypochlorite to achieve a total chlorine residual of at least 1 ppm in excess of the system oxidant demand. Once control is achieved, treatment rates can be reduced to sub-demand rates from 50% to 80% of system demand. The product may be added to the system continuously or intermittently as needed to any area of the system where uniform mixing can be obtained.

For intermittent treatment, mix 1.0 liter (0.264 gallons) of Zebion 480SL to 3.7 liters (0.977 gallons) of sodium hypochlorite (12.5%). Apply the solution at a rate to obtain 1 to 2 ppm in excess of the system oxidant demand (maximum of 5 ppm measured) as total chlorine in the water being treated for 5 to 60 minutes every 1 to 6 hours. The frequency of feeding and the duration of treatment will depend on the severity of the problem. Badly fouled systems must be cleaned before initial treatment.

For continuous treatment, mix 1.0 liter (0.264 gallons) of Zebion 480SL to 3.7 liters (0.977 gallons) of sodium hypochlorite (12.5%). Apply the solution at a rate to obtain 0.5 to 1 ppm in excess of the system oxidant demand (maximum of 5 ppm measured) as total chlorine in the water being treated on a continuous basis. The frequency of feeding and the duration of treatment will depend on the severity of the problem. Badly fouled systems must be cleaned before initial treatment.

This product can be used to generate a mixed chloramine solution (monochloramine and dichloramine). This product must be used in conjunction with: 1) EPA registered sodium hypochlorite (12.5%) and 2) Zebion 480SL feeder/delivery system and 3) In-line acid addition to optimize the generation of the mixed chloramine solution.

The Zebion 480SL feeder/delivery system automatically and optimally generates a dilute mixed chloramine solution. This solution is automatically and optimally fed using the Zebion 480SL feeder/delivery system. The installation, calibration and operation of the feeder/delivery system must be conducted only by Sanipur authorized and trained personnel.

To achieve a minimum molar ratio of 1:2, Zebion 480SL to sodium hypochlorite, combine 1.0 liter (0.264 gallons) of Zebion 480SL to 3.7 liters (0.977 gallons) of sodium hypochlorite (12.5%). In-line acid addition optimizes the generation of the chloramine solution. To ensure both handling safety and effectiveness, the mixed chloramine solution must be generated and fed into the treatment water systems through a proper chemical feed skid only by a trained Sanipur representative. Use of this product for any other purpose or contrary to the use directions specified below is prohibited.

Note: If chloramine is detected in the effluent, it can be deactivated by the addition of sodium bisulfite until chloramine is no longer detected. Deactivate by adding 5 ppm of a 38 wt% solution of sodium bisulfite per 1 ppm of measured total chlorine (2:1 ratio of sodium bisulfite to chlorine)

* Not approved for use in the State of California

STORAGE AND DISPOSAL

Do not contaminate water, food or feed by storage, disposal, or cleaning of equipment.

Pesticide Storage: Keep container tightly closed. Store in a dry place. Leaking or damaged drums should be placed in overpack drums for disposal. Spills should be absorbed in sawdust or sand and disposed of in a sanitary landfill. Keep container closed when not in use.

Pesticide Disposal: Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide or rinsate is a violation of Federal law. If these wastes cannot be disposed of by use according to label directions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

Container Handling: Nonrefillable Containers: Do not reuse or refill this container. Offer for recycling if available. Clean container promptly after emptying. Triple rinse as follows: Empty the remaining contents into application equipment or a mix tank. Fill the container ¼ full with water. Replace and tighten closures. Tip container on its side and roll it back and forth, ensuring at least one complete revolution, for 30 seconds. Stand the container on its end and tip it back and forth several times. Turn the container over onto its other end and tip it back and forth several times. Empty the rinsate into application equipment or a mix tank or store rinsate for later use or disposal. Repeat this procedure two more times.

{Optional Graphics}



Scan to access a Klenzoid SDS

