

UNITED STATES  
ENVIRONMENTAL PROTECTION AGENCY  
REGION II  
290 Broadway  
New York, New York 10007

**STATEMENT OF BASIS  
DRAFT NPDES PERMIT TO DISCHARGE  
INTO THE WATERS OF THE UNITED STATES**

NPDES Application No. **PR0026018**

Name and Address of Applicant:

**PRASA San Salvador Water Treatment Plant**  
P.O. Box 7066  
Barrio Obrero Station  
San Juan, Puerto Rico 00916

Name and Address of Facility where Discharge Occurs:

State Road No. 765, Km. 8.5  
Caguas, Puerto Rico 00725

Receiving Water: Morena Creek

Classification: SD

Name of Preparer: Normando Colón

**I. LOCATION OF DISCHARGE**

The above named applicant has applied for a National Pollutant Discharge Elimination System (NPDES) permit, to the U.S. Environmental Protection Agency (EPA) to discharge into the designated receiving water. The location of the discharge, Outfall 001, is described by the following U.S.G.S. coordinates are:

**Latitude 18° 08' 08"**  
**Longitude 66°02' 08"**

**II. DESCRIPTION OF APPLICANT'S FACILITY AND DISCHARGE**

The applicant is a water filtration plant which treats raw water for potable uses. This activity has a Standard Industrial Classification (SIC) code of 4941. The applicant proposes to discharge 109.78 m<sup>3</sup>/day (0.029 MGD) as a daily maximum of wastewater consisting of filters and settling tanks washwaters from outfall serial number 001 to an

intermittent creek tributary to Quebrada Morena. The receiving water has been classified SD by the Environmental Quality Board (EQB) of Puerto Rico.

### III. DESCRIPTION OF LIMITATIONS AND CONDITIONS

A brief summary of the basis of each effluent limitation and other conditions in the draft permit is provided in Attachment I.

### IV. STATE CERTIFICATION REQUIREMENTS

State Certification requirements, based upon a Water Quality Certificate (WQC) issued by the Environmental Quality Board (EQB) of the Commonwealth of Puerto Rico, are described in the draft permit. Review and appeals of limitations and conditions attributable to this certification shall be made through the applicable Commonwealth procedures and may not be through EPA procedures.

### V. PROCEDURES FOR REACHING A FINAL DECISION ON THE DRAFT PERMIT

These procedures, which are set forth in 40 CFR 124, are described in the public notice of preparation of this draft permit. Included in the public notice are requirements for the submission of comments by a specified date, procedures for requesting a hearing and the nature of the hearing, and other procedures for participation in the final agency decision.

### VI. EPA CONTACT

Additional information concerning the draft permit may be obtained between the hours of 8:00 A.M. and 4:30 P.M., Monday through Friday from:

Mr. Jaime Geliga, Chief  
Municipal Water Program Branch  
U.S. Environmental Protection Agency-Region II  
City View Plaza II – Suite 7000  
48 RD. 165 Km. 1.2  
Guaynabo, P.R. 00968-8069  
787- 977-5870

Mr. José C. Font, Acting Director  
Caribbean Environmental Protection Division  
U.S. Environmental Protection Agency - Region II  
City View Plaza II – Suite 7000  
48 RD. 165 Km. 1.2  
Guaynabo, P.R. 00968-8069  
787- 977-5870

## ATTACHMENT II

### DESCRIPTION OF DISCHARGE / DRAFT PERMIT CONDITIONS

#### Discharge 001

The treatment plant effluent is discharged through outfall No. 001 into the **Morena Creek (SD)**.

The following are the proposed effluent limitations / permit conditions:

1. The effluent limitations, monitoring requirements, and other conditions of this permit are described in the draft permit. The effluent limitations in the permit are equivalent to the most stringent values specified in the applicable technology-based guidelines or water quality-based limitations. All anti-backsliding decisions are made in accordance with EPA Region II Antibacksliding Policy.
2. Maximum daily discharge: **0.029** MGD
3. The effluent limitation for **Arsenic; BOD; Cadmium; Color; Copper; Cyanide; Dissolved Oxygen; Flow; Lead; pH; Residual Chlorine; Solids and Other Matter; Sulfide; Suspended, Colloidal or Settleable Solids; Taste and Odor Producing Substances; Temperature; Total Ammonia; Total Dissolved Solids; Turbidity; and Zinc** are based on EQB's Water Quality Certificate.
4. The water quality-based effluent limitation from the previous permit for for **2-Methyl-4,6 –Dinitrophenol, 2,4,-6 Trichlorophenol; Fecal Coliform; Fluoride; Mercury; Pentachlorophenol; and Sulfide** are not included in the Final WQC issued by EQB. EPA has determined that it is appropriate to remove the effluent limitation for this parameter without violating the anti-backsliding provisions of the CWA, in accordance with section 402(o), since one of the exceptions to the provisions has been satisfied. Information submitted in the NPDES application and the Discharge Monitoring Reports submitted during the previous permit indicate that the discharge from outfall 001 cannot reasonably be expected to contribute to a water quality exceedance for this parameter. Therefore, a water quality-based effluent limitation is not necessary for this parameter. Antidegradation requirements are not violated by removing the limits for this parameter. Since the permittee will be discharging the pollutant at the same level, the discharge would not contribute to further degradation of the receiving water and existing uses would be maintained.
5. The water quality-based numerical limitation from the existing permit for **Cadmium, and Lead** have been replaced with a less stringent water quality-based limitation in the Final WQC issued by the EQB. EPA has determined that it is appropriate to relax these limitations without violating the anti-backsliding provisions of the CWA, in accordance with Section 402 (o), since the exceptions to the provisions has been satisfied. The EQB water quality certificate constitutes a determination that the limit is sufficient to assure that the water quality standards are or will be attained.