

UNITED STATES
ENVIRONMENTAL PROTECTION AGENCY
REGION II
290 Broadway
New York, New York 10007

**STATEMENT OF BASIS
DRAFT NPDES PERMIT TO DISCHARGE
INTO THE WATERS OF THE UNITED STATES**

NPDES Application No. **PR0026743**

Name and Address of Applicant:

PRASA Gurabo Water Treatment Plant
P.O. Box 7066
Barrio Obrero Station
San Juan, Puerto Rico 00916

Name and Address of Facility where Discharge Occurs:

#1 Street, Jardines de Gurabo
Gurabo, Puerto Rico 00778

Receiving Water: Gurabo River

Classification: SD

Name of Preparer: Cristina I. Maldonado

I. LOCATION OF DISCHARGE

The above named applicant has applied for a National Pollutant Discharge Elimination System (NPDES) permit, to the U.S. Environmental Protection Agency (EPA) to discharge into the designated receiving water. The location of the discharge, Outfall 001, is described by the following U.S.G.S. coordinates are:

Latitude 18° 15' 21.58"
Longitude 65° 57' 53.94"

II. DESCRIPTION OF APPLICANT'S FACILITY AND DISCHARGE

The applicant is a water filtration plant which treats raw water for potable uses. This activity has a Standard Industrial Classification (SIC) code of 4941. The applicant proposes to discharge 1,090.2 m³/day (0.288 MGD) as a daily maximum of wastewater consisting of filters and settling tanks washwaters from outfall serial number 001 to a

drainage channel tributary to Gurabo River. The receiving water has been classified SD by the Environmental Quality Board (EQB) of Puerto Rico.

III. DESCRIPTION OF LIMITATIONS AND CONDITIONS

A brief summary of the basis of each effluent limitation and other conditions in the draft permit is provided in Attachment I.

IV. STATE CERTIFICATION REQUIREMENTS

State Certification requirements, based upon a Water Quality Certificate (IWQC) issued by the Environmental Quality Board (EQB) of the Commonwealth of Puerto Rico, are described in the draft permit. Review and appeals of limitations and conditions attributable to this certification shall be made through the applicable Commonwealth procedures and may not be through EPA procedures.

V. PROCEDURES FOR REACHING A FINAL DECISION ON THE DRAFT PERMIT

These procedures, which are set forth in 40 CFR 124, are described in the public notice of preparation of this draft permit. Included in the public notice are requirements for the submission of comments by a specified date, procedures for requesting a hearing and the nature of the hearing, and other procedures for participation in the final agency decision.

VI. EPA CONTACT

Additional information concerning the draft permit may be obtained between the hours of 8:00 A.M. and 4:30 P.M., Monday through Friday from:

Mr. Jaime Geliga, Chief
Municipal Water Program Branch
U.S. Environmental Protection Agency-Region II
City View Plaza II – Suite 7000
48 RD. 165 Km. 1.2
Guaynabo, P.R. 00968-8069
787- 977-5870

Mr. José C. Font, Director
Caribbean Environmental Protection Division
U.S. Environmental Protection Agency - Region II
City View Plaza II – Suite 7000
48 RD. 165 Km. 1.2
Guaynabo, P.R. 00968-8069
787- 977-5870

ATTACHMENT II

DESCRIPTION OF DISCHARGE / DRAFT PERMIT CONDITIONS

Discharge 001

The treatment plant effluent is discharged through outfall No. 001 into the **Gurabo River (SD)**.

The following are the proposed effluent limitations / permit conditions:

1. The effluent limitations, monitoring requirements, and other conditions of this permit are described in the draft permit. The effluent limitations in the permit are equivalent to the most stringent values specified in the applicable technology-based guidelines or water quality-based limitations. All anti-backsliding decisions are made in accordance with EPA Region II Antibacksliding Policy.
2. Maximum daily discharge: **0.288** MGD
3. The effluent limitation for **BOD; Chlorides; Color; Copper; Cyanide; Dissolved Oxygen; Fecal Coliforms; Flow; Fluoride; Lead; Nitrate plus Nitrite; pH; Residual Chlorine; Solids and Other Matter; Sulfates; Sulfide; Surfactants; Suspended, Colloidal or Settleable Solids; Taste and Odor Producing Substances; Temperature; Total Ammonia; Total Coliforms; Total Dissolved Solids; Total Phosphorus; Turbidity; and Zinc** are based on EQB's Water Quality Certificate.