

LEGEND

- - - - - - Intermittent flow

———— Continuous flow during normal station on line operation

MGD = MILLION GALLONS PER DAY

GPD = GALLONS PER DAY

NOTES:

STORMWATER FLOWS BASED ON ANNUAL RAINFALL OF 36.53" WITH A RUNOFF COEFFICIENT OF 80% (EXCEPT ROOF DRAINS, SWAMP AND SLAG POND WHICH HAVE 100% RUNOFF COEFFICIENT).

T6

DATE	DRWN.	CHKD.	APPR.
2/97	WT	AP	AP
4/90	W.T.		
3/90	AMB		
3/90	LMN	EO	

SCHEMATIC OF WATER FLOW
PUBLIC SERVICE CO. of N. H.
MERRIMACK STATION
BOW - MERRIMACK COUNTY, NEW HAMPSHIRE

CHKD. J B Lander

APPR.

PUBLIC SERVICE CO. OF NEW HAMPSHIRE
ENGINEERING DIVISION

SCALE - None DATE - 10-06-80

Mk-M-1235

AR-1280