

NH0001465_Shortrecord

	1	2	3	4	5	6
1	FACILITY NAME					
2	Outfall Serial Number 001 - 1 - A					
3						
4	Parameter	Flow, in conc	Flow, in conc	Oxidants, total residual		
5	Units	MGD	MGD	mg/L		
6		DAILY MX	MO AVG	DAILY MX		
7	Effluent Limit	69.1	Mon	.2		
8	2015-01-31	68.5	67.1	.04		
9	2015-02-28	68.5	68.5	.03		
10	2015-03-31	68.5	56.5	.05		
11	2015-04-30	31.9	1.1	.04		
12	2015-05-31	NODI: C	NODI: C	NODI: C		
13	2015-06-30	59.4	11.8	NODI: 2		
14	2015-07-31	65.3	9.4	0		
15	2015-08-31	68.5	5.3	.01		
16	2015-09-30	68.5	6.7	0		
17	2015-10-31	68.5	16.3	0		
18	2015-11-30	65.4	7.3	0		
19	2015-12-31	20.4	.7	NODI: 2		
20	2016-01-31	68.5	36.1	.02		
21	2016-02-29	68.5	29.2	0		
22	2016-03-31	NODI: C	NODI: C	NODI: C		
23	2016-04-30	11.9	.5	NODI: 2		
24	2016-05-31	25.3	.8	NODI: 2		
25	2016-06-30	NODI: C	NODI: C	NODI: C		
26	2016-07-31	68.5	25.7	0		
27	2016-08-31	68.5	16.7	0		
28	2016-09-30	68.2	5.7	0		
29	2016-10-31	24.4	3.8	NODI: 2		
30	2016-11-30	67.1	3	NODI: 2		

31	2016-12-31	68.5	59	0	
32	2017-01-31	68.5	11.9	NODI: 2	
33	2017-02-28	68.5	16	NODI: 9	
34	2017-03-31	68.5	11.6	NODI: 9	
35	2017-04-30	NODI: C	NODI: C	NODI: C	
36	2017-05-31	68.5	14.2	NODI: 2	
37	2017-06-30	68.5	21.4	0	
38	2017-07-31	68.5	30.6	0	
39	2017-08-31	37.2	20.9	NODI: 2	
40	2017-09-30	19.2	.6	NODI: 2	
41	2017-10-31	NODI: C	NODI: C	NODI: C	
42	2017-11-30	NODI: C	NODI: C	NODI: C	
43	2017-12-31	68.5	45.3	.02	
44	2018-01-31	68.5	63.9	.02	
45	2018-02-28	68.5	22.3	0	
46	2018-03-31	68.5	17.9	0	
47	2018-04-30	68.5	26.8	NODI: 2	
48	2018-05-31	NODI: C	NODI: C	NODI: C	
49	2018-06-30	68.5	12.4	0	
50	2018-07-31	68.5	7.1	0	
51	2018-08-31	68.5	8.6	NODI: 2	
52	2018-09-30	68.5	7.6	0	
53	2018-10-31	35.2	1.1	NODI: 9	
54	2018-11-30	68.5	42.9	.02	
55	2018-12-31	68.5	26.7	0	
56	2019-01-31	68.5	36.4	0	
57	2019-02-28	68.5	13.6	0	
58	2019-03-31	68.5	20.7	0	
59	2019-04-30	NODI: C	NODI: C	NODI: C	
60	2019-05-31	NODI: C	NODI: C	NODI: C	
61	2019-06-30	69.1	8	0	
62	2019-07-31	68.5	11.7	0	
63	2019-08-31	18.3	.7	0	
64	2019-09-30	37.2	3.6	NODI: 9	
65	2019-10-31	59.2	4.5	.02	
66	2019-11-30	NODI: C	NODI: C	NODI: C	
67	2019-12-31	NODI: C	NODI: C	NODI: C	
68	2020-01-31	59.4	7.3	NODI: 9	

	1	2	3	4	5	6
1	FACILITY NAME					
2	Outfall Serial Number 002 - 1 - A					
3						
4	Parameter	Flow, in conc	Flow, in conc	Oxidants, total residual		
5	Units	MGD	MGD	mg/L		
6		DAILY MX	MO AVG	DAILY MX		
7	Effluent Limit	187.2	Mon	.2		
8	2015-01-31	183.5	163.7	.03		
9	2015-02-28	183.5	183.5	.02		
10	2015-03-31	183.6	117	.04		
11	2015-04-30	149	5.7	.03		
12	2015-05-31	NODI: C	NODI: C	NODI: C		
13	2015-06-30	14.3	.5	NODI: 2		
14	2015-07-31	144.1	16.1	0		
15	2015-08-31	28.5	.9	NODI: 2		
16	2015-09-30	183.5	17.3	0		
17	2015-10-31	NODI: C	NODI: C	NODI: C		
18	2015-11-30	96.5	9	NODI: 2		
19	2015-12-31	183.5	26	.02		
20	2016-01-31	183.5	46.3	NODI: 2		
21	2016-02-29	183.5	44.3	.03		
22	2016-03-31	NODI: C	NODI: C	NODI: C		
23	2016-04-30	28.4	.9	NODI: 2		
24	2016-05-31	37.4	1.6	NODI: 2		
25	2016-06-30	NODI: C	NODI: C	NODI: C		
26	2016-07-31	183.5	72.6	0		
27	2016-08-31	183.5	45.3	0		
28	2016-09-30	NODI: C	NODI: C	NODI: C		
29	2016-10-31	NODI: C	NODI: C	NODI: C		
30	2016-11-30	96.5	14.1	NODI: 2		
31	2016-12-31	183.7	83.1	0		
32	2017-01-31	183.7	53.4	0		
33	2017-02-28	183.5	57.9	0		

34	2017-03-31	23.2	.7	NODI: 9	
35	2017-04-30	NODI: C	NODI: C	NODI: C	
36	2017-05-31	45.1	1.5	NODI: 2	
37	2017-06-30	186.8	63.6	0	
38	2017-07-31	183.5	27.2	0	
39	2017-08-31	NODI: C	NODI: C	NODI: C	
40	2017-09-30	NODI: C	NODI: C	NODI: C	
41	2017-10-31	NODI: C	NODI: C	NODI: C	
42	2017-11-30	171.3	11.1	0	
43	2017-12-31	183.5	35.8	0	
44	2018-01-31	183.7	147.8	.01	
45	2018-02-28	183.5	71.1	0	
46	2018-03-31	183.5	33	NODI: 2	
47	2018-04-30	184	59.3	NODI: 2	
48	2018-05-31	NODI: C	NODI: C	NODI: C	
49	2018-06-30	183.5	11.3	NODI: 2	
50	2018-07-31	183.5	27.6	0	
51	2018-08-31	183.5	44.9	0	
52	2018-09-30	183.5	16.7	0	
53	2018-10-31	62.5	4	NODI: 9	
54	2018-11-30	183.5	65.5	0	
55	2018-12-31	183.5	43.9	0	
56	2019-01-31	183.5	77.8	0	
57	2019-02-28	182.8	28	0	
58	2019-03-31	160.8	31.1	0	
59	2019-04-30	NODI: C	NODI: C	NODI: C	
60	2019-05-31	34	1.1	NODI: 9	
61	2019-06-30	183.5	48	0	
62	2019-07-31	183.5	39.8	NODI: 9	
63	2019-08-31	183.5	23.2	0	
64	2019-09-30	183.5	30	0	

34	2017-03-31	23.2	.7	NODI: 9	
35	2017-04-30	NODI: C	NODI: C	NODI: C	
36	2017-05-31	45.1	1.5	NODI: 2	
37	2017-06-30	186.8	63.6	0	
38	2017-07-31	183.5	27.2	0	
39	2017-08-31	NODI: C	NODI: C	NODI: C	
40	2017-09-30	NODI: C	NODI: C	NODI: C	
41	2017-10-31	NODI: C	NODI: C	NODI: C	
42	2017-11-30	171.3	11.1	0	
43	2017-12-31	183.5	35.8	0	
44	2018-01-31	183.7	147.8	.01	
45	2018-02-28	183.5	71.1	0	
46	2018-03-31	183.5	33	NODI: 2	
47	2018-04-30	184	59.3	NODI: 2	
48	2018-05-31	NODI: C	NODI: C	NODI: C	
49	2018-06-30	183.5	11.3	NODI: 2	
50	2018-07-31	183.5	27.6	0	
51	2018-08-31	183.5	44.9	0	
52	2018-09-30	183.5	16.7	0	
53	2018-10-31	62.5	4	NODI: 9	
54	2018-11-30	183.5	65.5	0	
55	2018-12-31	183.5	43.9	0	
56	2019-01-31	183.5	77.8	0	
57	2019-02-28	182.8	28	0	
58	2019-03-31	160.8	31.1	0	
59	2019-04-30	NODI: C	NODI: C	NODI: C	
60	2019-05-31	34	1.1	NODI: 9	
61	2019-06-30	183.5	48	0	
62	2019-07-31	183.5	39.8	NODI: 9	
63	2019-08-31	183.5	23.2	0	
64	2019-09-30	183.5	30	0	
65	2019-10-31	89.1	4.2	NODI: 9	
66	2019-11-30	183.5	28.3	0	
67	2019-12-31	183.5	39.3	0	
68	2020-01-31	183.5	31.6	0	

	1	2	3	4	5	6	7	8
1	FACILITY NAME							
2	Outfall Serial Number 003 - 1 - 1							
3								
4	Parameter	Flow, in conc	Flow, in conc	Oil & grease	Oxidants, tot	Oxygen, diss	pH	pH
5	Units	MGD	MGD	mg/L	mg/L	%	SU	SU
6		MO AVG	DAILY MX	DAILY MX	DAILY MX	MO MIN	MINIMUM	MAXIMUM
7	Effluent Limit	265.3	275.4	Mon	.026	75	6.5	8
8	2015-01-31	234.8	256.8	NODI: 9	0	92	5.9	6.9
9	2015-02-28	256.6	256.9	NODI: 9	0	123	6.5	7
10	2015-03-31	177.1	257.1	NODI: 9	0	134	6.5	7.4
11	2015-04-30	7.2	185.4	NODI: 9	0	81	6.5	7.2
12	2015-05-31	.1	.3	NODI: 9	0	84	6.3	7.1
13	2015-06-30	12.8	61.6	NODI: 9	0	82	6.2	7
14	2015-07-31	26.1	213.6	NODI: 9	0	107	6.2	7.2
15	2015-08-31	6.3	69	NODI: 9	0	95	6.2	7.1
16	2015-09-30	24.4	254.9	NODI: 9	0	84	6.3	7.5
17	2015-10-31	16.6	69.6	NODI: 9	0	81	6.2	6.9
18	2015-11-30	16.8	98.6	NODI: 9	0	90	6.3	6.8
19	2015-12-31	27.6	185.6	NODI: 9	0	102	6.2	6.84
20	2016-01-31	84.6	255.4	NODI: 9	0	100	6.1	7.2
21	2016-02-29	75.3	255.1	NODI: 9	0	94	6.3	7.18
22	2016-03-31	.3	.8	NODI: 9	0	90	6.2	7.4
23	2016-04-30	1.6	28.6	NODI: 9	0	NODI: H	6.3	6.9
24	2016-05-31	2.5	63.7	NODI: 9	0	78	6.3	6.9
25	2016-06-30	0	.1	NODI: 9	0	100	6.32	6.93
26	2016-07-31	99.4	254.8	NODI: 9	0	90	6.1	7.3
27	2016-08-31	62.9	254.5	NODI: 9	0	80	6.2	7.8
28	2016-09-30	5.9	68.8	NODI: 9	0	75	6.3	7.5
29	2016-10-31	3.9	25	NODI: 9	0	81	6.5	7.5
30	2016-11-30	17.6	166.6	9	0	107	6.3	6.8
31	2016-12-31	145	256.4	NODI: 9	0	111	6.31	7.18
32	2017-01-31	67.1	256.3	NODI: 9	0	107	5.9	7.2
33	2017-02-28	76.6	257.8	NODI: 9	0	105	6	7.1
34	2017-03-31	13.9	71.7	NODI: 9	0	97	6	7.6
35	2017-04-30	.2	.3	NODI: 9	0	105	5.7	7.2
36	2017-05-31	16.2	71.3	NODI: 9	0	100	6.3	7.1
37	2017-06-30	86.5	227	NODI: 9	0	102	6.2	7.4
38	2017-07-31	59	256.3	NODI: 9	0	101	6.3	7.4
39	2017-08-31	21	37.4	NODI: 9	0	80	6.6	7.4
40	2017-09-30	.8	19.2	NODI: 9	0	89	6.7	7.5
41	2017-10-31	.1	.7	NODI: 9	0	96	6.6	7.6
42	2017-11-30	11.8	174.4	9	0	92	6.6	7.7
43	2017-12-31	83.2	256.4	NODI: 9	0	NODI: 9	6.9	7.7
44	2018-01-31	216.3	257.5	NODI: 9	0	NODI: 9	6.3	7.2
45	2018-02-28	95.4	256.7	NODI: 9	0	NODI: 9	6.3	6.8
46	2018-03-31	52.5	257.2	NODI: 9	0	NODI: 9	6.3	7
47	2018-04-30	88.1	257.1	NODI: 9	0	NODI: 9	6.6	7.8
48	2018-05-31	.2	.5	NODI: 9	0	95	6.5	7.7
49	2018-06-30	24.3	256.1	NODI: 9	0	99	6.4	7.6
50	2018-07-31	35.9	256.7	NODI: 9	0	93	6.2	7.7
51	2018-08-31	56.5	259	NODI: 9	0	88	6.2	7.3
52	2018-09-30	25.5	257.6	NODI: 9	0	86	6.5	7.4
53	2018-10-31	5.5	64	NODI: 9	0	86	6.7	7
54	2018-11-30	111.5	258.1	NODI: 9	0	82	6.4	7.2
55	2018-12-31	72.7	257	NODI: 9	0	104	6.6	7.1
56	2019-01-31	117.4	257.6	NODI: 9	0	105	6.6	7.4
57	2019-02-28	43.6	256.1	NODI: 9	0	99	6.6	7.5
58	2019-03-31	53.8	209.4	NODI: 9	0	98	6.8	7.7
59	2019-04-30	.2	.4	NODI: 9	0	100	6.2	7.7
60	2019-05-31	1.3	34.2	NODI: 9	0	97	6.1	7.2
61	2019-06-30	57.4	258.4	NODI: 9	0	94	6.4	7.2
62	2019-07-31	52.9	257.7	NODI: 9	0	93	6.2	7.6
63	2019-08-31	24.5	186.8	NODI: 9	0	90	6.3	7.9
64	2019-09-30	34.6	187	NODI: 9	0	88	6.4	7.3
65	2019-10-31	9	90.7	NODI: 9	0	89	6.4	7.1
66	2019-11-30	29.3	186.7	NODI: 9	0	92	6.3	6.8
67	2019-12-31	40.4	186.6	NODI: 9	0	101	6.3	6.8
68	2020-01-31	40.2	227.3	NODI: 9	0	99	6.6	7

	1	2	3	4	5	6	7	8	9	10	11	12
1	FACILITY NAME											
2	Outfall Serial Number 003 - 1 - A											
3												
4	Parameter	Flow, in conc	Flow, in conc	Oil & grease	Oil & grease	Solids, total	Solids, total	pH	pH	Copper, total	Iron, total (as Fe)	
5	Units	MGD	MGD	mg/L	mg/L	mg/L	mg/L	SU	SU	mg/L	mg/L	
6		DAILY MX	MO AVG	MO AVG	DAILY MX	DAILY MX	MO AVG	MAXIMUM	MINIMUM	DAILY MX	DAILY MX	
7	Effluent Limit	19.1	9	15	20	100	30	Mon	Mon	.2	1	
8	2015-01-31	4.7	4	0	0	4.9	4.9	5.4	3.8			
9	2015-02-28	4.9	4.6	0	0	11.4	11.4	6.1	4.2			
10	2015-03-31	5.4	3.6	0	0	3.7	3.7	6.6	4.1	0	.45	
11	2015-04-30	4.4	.4	0	0	2.3	2.3	9	4.4			
12	2015-05-31	.3	.1	0	0	2.8	2.8	8.1	6.2			
13	2015-06-30	2.4	.5	0	0	1.1	1.1	6.6	5.5	0	.35	
14	2015-07-31	4.2	.5	0	0	1.3	1.3	8.7	4.7			
15	2015-08-31	.9	.1	0	0	1.7	1.7	7.3	5.8			
16	2015-09-30	3.6	.4	0	0	3	3	7.6	4.1	.01	.28	
17	2015-10-31	1.7	.3	0	0	0	0	6.7	5.4			
18	2015-11-30	2.2	.4	0	0	0	0	6.4	4.9			
19	2015-12-31	2.2	.9	0	0	0	0	6.4	3.5	0	.47	
20	2016-01-31	4.2	2.3	0	0	2.6	2.6	6.3	3.6			
21	2016-02-29	4.2	1.9	0	0	3.5	3.5	7.4	3.1			
22	2016-03-31	.8	.3	1.4	1.4	3.2	3.2	7.1	5.7	.01	.5	
23	2016-04-30	.2	.1	0	0	0	0	7.1	6.3			
24	2016-05-31	1.1	.1	0	0	0	0	6.7	6			
25	2016-06-30	.1	0	0	0	2.9	2.9	6.6	6	.01	.18	
26	2016-07-31	3.7	1.1	0	0	2.9	2.9	7	4			
27	2016-08-31	4.2	1	0	0	3.6	3.6	7.1	4.9			
28	2016-09-30	1.8	.2	0	0	0	0	8.1	5.8	.01	.3	
29	2016-10-31	.6	.1	0	0	0	0	6.8	5.9			
30	2016-11-30	3.7	.6	0	0	0	0	6.8	5.2			
31	2016-12-31	4.8	2.9	0	0	2.9	2.9	5.8	3	.01	.32	
32	2017-01-31	5	1.9	0	0	3.7	3.7	8.4	4.2			
33	2017-02-28	5.9	2.7	0	0	0	0	6.5	4.3			
34	2017-03-31	4	1.6	0	0	0	0	7	4.7	0	.31	
35	2017-04-30	.3	.2	0	0	0	0	7	6.1			
36	2017-05-31	2.8	.5	0	0	4.4	4.4	8.2	5.6			
37	2017-06-30	4.2	1.5	0	0	3	3	7.5	4.8	0	.46	
38	2017-07-31	5.6	1.3	0	0	0	0	7.2	5.5			
39	2017-08-31	.3	.1	0	0	0	0	7.4	6.4			
40	2017-09-30	.4	.1	0	0	0	0	7.3	6.4	.01	.19	
41	2017-10-31	.7	.1	0	0	0	0	7.8	6.1			
42	2017-11-30	3.3	.7	0	0	0	0	7.3	5			
43	2017-12-31	4.9	2.1	0	0	2.5	2.5	7.1	3.8	.01	.47	
44	2018-01-31	5.5	4.6	0	0	0	0	6.2	3.7			
45	2018-02-28	4.7	2	0	0	0	0	7.6	4.4			
46	2018-03-31	6.1	1.6	0	0	0	0	7.5	3.9	.002	.56	
47	2018-04-30	5.5	2	0	0	12	12	8.4	4			
48	2018-05-31	.5	.2	0	0	0	0	7.4	6.3			
49	2018-06-30	4.1	.7	0	0	0	0	7.3	5.4	.002	.51	
50	2018-07-31	5.7	1.2	0	0	0	0	6.8	4.9			
51	2018-08-31	7.1	3	0	0	0	0	6.8	4.2			
52	2018-09-30	6.7	1.2	0	0	0	0	7.8	5.5	.004	.64	
53	2018-10-31	2.1	.3	NODI: E	NODI: E	NODI: E	NODI: E	6.5	6.1			
54	2018-11-30	6.1	3.1	0	0	8	8	6.4	3.3			
55	2018-12-31	5.3	2	0	0	5	5	6.9	3.4	.004	.77	
56	2019-01-31	6.2	3.3	0	0	0	0	8.7	3.3			
57	2019-02-28	4.9	1.9	0	0	0	0	8.5	3.2			
58	2019-03-31	6.3	2	0	0	0	0	7	3.3	.002	.44	
59	2019-04-30	.4	.2	0	0	0	0	7.6	6.1			
60	2019-05-31	1	.2	0	0	0	0	7.2	6.2			
61	2019-06-30	6.3	1.3	0	0	0	0	6.7	3.6	.002	1	
62	2019-07-31	5.7	1.4	0	0	0	0	8.4	4			
63	2019-08-31	4.7	.7	0	0	0	0	8.4	3.8			
64	2019-09-30	3.5	1	0	0	0	0	9.5	4.9	.002	.28	
65	2019-10-31	3.1	.4	0	0	0	0	9	5.1			
66	2019-11-30	3.3	.9	0	0	0	0	8.7	4.2			
67	2019-12-31	3.3	1.1	0	0	0	0	6.6	3.2	.004	.35	
68	2020-01-31	4.3	1.3	0	0	9.5	9.5	6.9	3.5			

	1	2	3	4
1	FACILITY NAME			
2	Outfall Serial Number 003 - G - 1			
3				
4	Parameter	pH	pH	
5	Units	SU	SU	
6		MAXIMUM	MINIMUM	
7	Effluent Limit	Mon	Mon	
8	2015-01-31	6.8	6.1	
9	2015-02-28	6.7	6.6	
10	2015-03-31	7.9	6.6	
11	2015-04-30	6.8	6.5	
12	2015-05-31	7.1	6.5	
13	2015-06-30	6.9	6.6	
14	2015-07-31	6.9	6.4	
15	2015-08-31	7.1	6.6	
16	2015-09-30	7.4	6.6	
17	2015-10-31	6.8	6.4	
18	2015-11-30	6.8	6.6	
19	2015-12-31	6.8	6.5	
20	2016-01-31	6.8	6.5	
21	2016-02-29	6.79	6.42	
22	2016-03-31	6.8	6.5	
23	2016-04-30	6.8	6.5	
24	2016-05-31	7	6.4	
25	2016-06-30	7.16	6.56	
26	2016-07-31	6.9	6.5	
27	2016-08-31	7.9	6.4	
28	2016-09-30	7.2	6.5	
29	2016-10-31	6.9	6.3	

30	2016-11-30	6.8	6.6	
31	2016-12-31	6.8	6.39	
32	2017-01-31	6.8	6.3	
33	2017-02-28	6.9	6.5	
34	2017-03-31	7.1	6.3	
35	2017-04-30	6.9	6.2	
36	2017-05-31	7.2	6.6	
37	2017-06-30	7.3	6.7	
38	2017-07-31	7.1	6.3	
39	2017-08-31	7.5	6.9	
40	2017-09-30	7.7	7	
41	2017-10-31	7.8	6.5	
42	2017-11-30	8	6.6	
43	2017-12-31	7.6	6.4	
44	2018-01-31	6.9	6.4	
45	2018-02-28	7.2	6.6	
46	2018-03-31	7.2	6.7	
47	2018-04-30	7.6	6.8	
48	2018-05-31	7.4	6.2	
49	2018-06-30	7.2	6.7	
50	2018-07-31	6.9	6.5	
51	2018-08-31	6.9	6.6	
52	2018-09-30	7	6.7	
53	2018-10-31	7.5	6.6	
54	2018-11-30	7.8	6.4	
55	2018-12-31	6.9	6.6	
56	2019-01-31	7.3	6.7	
57	2019-02-28	7.2	6.2	
58	2019-03-31	7.4	6.2	

59	2019-04-30	6.9	6.5	
60	2019-05-31	7.2	6.4	
61	2019-06-30	7.1	6.6	
62	2019-07-31	6.9	6.5	
63	2019-08-31	7.3	6.7	
64	2019-09-30	7.2	6.7	
65	2019-10-31	7.3	6.6	
66	2019-11-30	7.1	6.5	
67	2019-12-31	6.8	6.5	
68	2020-01-31	6.9	6.6	

	1	2	3	4	5
1	FACILITY NAME				
2	Outfall Serial Number 004 - 1 - A				
3					
4	Parameter	Flow, in cond	Oil & grease	pH	pH
5	Units	gal/d	mg/L	SU	SU
6		DAILY MX	DAILY MX	MINIMUM	MAXIMUM
7	Effluent Limit	Mon	Mon	6.5	8
8	2015-12-31	2440000	NODI: 9	5.5	6.7
9	2016-12-31	2440000	NODI: 9	6	6.8
10	2017-12-31	2440000	NODI: 9	5.6	7.2
11	2018-12-31	2440585	NODI: 9	6.4	6.7
12	2019-12-31	2440000	NODI: 9	5.9	6.7

	1	2	3	4	5	6
1	FACILITY NAME					
2	Outfall Serial Number 005 - 1 - A					
3						
4	Parameter	Flow, in cond	Oil & grease	pH	pH	
5	Units	gal/d	mg/L	SU	SU	
6		DAILY MX	DAILY MX	MINIMUM	MAXIMUM	
7	Effluent Limit	Mon	Mon	6.5	8	
8	2015-12-31	48000	NODI: 9	6.5	6.7	
9	2016-12-31	156000	NODI: 9	6.5	6.6	
10	2017-12-31	142000	NODI: 9	6.8	7.2	
11	2018-12-31	NODI: C	NODI: C	NODI: C	NODI: C	
12	2019-12-31	NODI: C	NODI: C	NODI: C	NODI: C	

	1	2	3	4	5	6	7
1	FACILITY NAME						
2	Outfall Serial Number 006 - 1 - A						
3							
4	Parameter	Flow, in cond	Oil & grease	Solids, total s	pH	pH	
5	Units	gal/d	mg/L	mg/L	SU	SU	
6		DAILY MX	DAILY MX	DAILY MX	MAXIMUM	MINIMUM	
7	Effluent Limit	Mon	Mon	Mon	Mon	Mon	
8	2015-12-31	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	
9	2016-12-31	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	
10	2017-12-31	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	
11	2018-12-31	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	
12	2019-12-31	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	