

→ Steam - Electric

- Assumng delay review in place -
- skill gap for VCI ? FGD
- Bottom ash

→ QWLS -

- welymin or screen improvements - if

→ Thermal

- Limit by units (2) by amount of discharge + withdrawal

→

- Stephen Gidern
- Tom DeLeonius
- Tom Armas
- Lynn Tillotson (env. mgr.)

Tel 5 Gidern 9/6/18

Options

- 1) Capacity Factor - Cap - Bowlin - (Seasonal ; averaging ?)
- 2) Fuel Temp Limit - Daily Max ; 7-Dg rolling average
Temp Number - mixing zone ?
- 3) A-T - change in temp - River average
→ change in river temp ambient
- or A-T - intake vs Discharge
- 4) Heat Load - (BTU) - focus
- 5) Flow - based -
Daily Max : Rolling average -