

State	Facility Name	Facility ID	Unit	Associate	Year	Program	SO2 (tons)	Avg. NOx I	NOx (tons)	CO2 (tons)	Heat Input (M	Operating Tir	Gross Load (MW
NH	Merrimack	2364	1	MS001, C	2011	ARP, NF	8129.706	0.3032	1018.582	692673.059	6751198.046	6016.84	637009.25
NH	Merrimack	2364	1	MS001, C	2012	ARP, NF	390.496	0.2955	593.956	421548.931	4108662.547	3703.92	394722.05
NH	Merrimack	2364	1	MS001, C	2013	ARP, NF	364.092	0.2962	584.545	418425.6	4078239.667	3791.84	404936.68
NH	Merrimack	2364	2	CS001	2011	ARP, NF	14289.84	0.2728	1978.796	1523636.424	1.49E+07	5073.2	1478888.28
NH	Merrimack	2364	2	CS001	2012	ARP, NF	613.737	0.2744	1239.66	974093.308	9494092.339	3036.45	899035.01
NH	Merrimack	2364	2	CS001	2013	ARP, NF	1036.442	0.2761	1359.044	1086049.468	1.06E+07	3384.37	1032003.16

Unit Type Fuel Type Fuel Type (Secondary)

Cyclone bc Coal

Cyclone bc Coal

Cyclone bc Coal

Cyclone bc Coal

Cyclone bc Coal

Cyclone bc Coal