

Parameter	Flow	Flow	Flow	Flow	CBOD5/NH 3-N	CBOD5/NH 3-N	CBOD5/NH 3-N
	Monthly Ave	Daily Max	Monthly Ave	ANNL AVG	Monthly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	MGD	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	436	25	40	Report
Minimum	201.7	235.7	195.4	246.5	3.5	4.6	7.5
Maximum	568.2	1002.8	483.9	319.6	10.9	13.9	39.4
Median	322.1	488.65	298.1	283.55	6.2	7.8	13.45
No. of Violations	N/A	N/A	N/A	0	0	0	N/A
1/31/2018	353.9	723.1	305.1	277.1	8.8	11.9	16.5
2/28/2018	378.1	521.8	365.6	279.8	8.2	9.6	14.2
3/31/2018	493.3	950.4	405.5	282.9	6.5	8.5	18.7
4/30/2018	425	808.4	370.2	279.9	6.6	8.5	22.3
5/31/2018	323.2	442.5	316	278.3	7.6	10.4	20.2
6/30/2018	266.7	424.3	250.6	272.7	6.1	6.2	8.1
7/31/2018	256.5	490.5	240.6	271.2	7.2	12.1	39.4
8/31/2018	273	432.6	248.8	274.2	4.7	5	9.6
9/30/2018	296.3	491.8	247.6	277.2	4.7	5.7	12.4
10/31/2018	321	564.9	291.6	284.2	4.9	7.4	23.3
11/30/2018	568.2	795.8	483.9	296	5.2	6.4	15.7
12/31/2018	382.9	617	359	307.9	6.3	8.4	11.3
1/31/2019	372.5	792.4	343.3	311.2	9.5	12.2	19.4
2/28/2019	368.7	488.5	329.8	309.5	10.9	10.4	19.6
3/31/2019	375.4	500	370.1	312	9.6	13.9	17.2
4/30/2019	420.3	754.7	346.5	309	5.7	7	12.2
5/31/2019	361.7	460.5	355.2	312.3	6.4	6.5	13.3
6/30/2019	303.7	401.1	284.2	316.4	6.7	8.1	10.6
7/31/2019	304.7	471.4	274.5	319.6	4.4	6	12.8
8/31/2019	271	477.8	250.9	318.8	5.5	7	13.3
9/30/2019	243.6	355.7	233.1	315	5.7	7	14.4
10/31/2019	276.3	512.1	244.4	310.8	5.5	6.4	13
11/30/2019	294.2	560.3	268.5	300.4	6.1	7.3	13
12/31/2019	420.8	724.6	415.9	294.5	5.6	6	14.3
1/31/2020	333.9	468.9	332.7	294	6.2	8.8	13.5
2/29/2020	320.9	416.3	300.3	292.8	6.9	8.8	11.8

Parameter	Flow	Flow	Flow	Flow	CBOD5/NH 3-N	CBOD5/NH 3-N	CBOD5/NH 3-N
	Monthly Ave	Daily Max	Monthly Ave	ANNL AVG	Monthly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	MGD	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	436	25	40	Report
Minimum	201.7	235.7	195.4	246.5	3.5	4.6	7.5
Maximum	568.2	1002.8	483.9	319.6	10.9	13.9	39.4
Median	322.1	488.65	298.1	283.55	6.2	7.8	13.45
No. of Violations	N/A	N/A	N/A	0	0	0	N/A
3/31/2020	325.3	536.7	299.2	286.6	7.4	8.7	13.5
4/30/2020	432.2	638.9	401.3	290.5	6.3	7.3	11
5/31/2020	331.4	552.7	309.7	288	7.2	9.8	11.8
6/30/2020	251.9	382.6	236.3	282.9	6.8	9.3	12.7
7/31/2020	234.9	297.6	229.8	277.9	5.1	6.9	16.5
8/31/2020	213.3	298.7	206.8	273.2	5.4	6.8	18.8
9/30/2020	204.1	253.6	199.8	268.6	5	5.9	14.6
10/31/2020	237	412.2	202	264.8	5.5	6.8	13.4
11/30/2020	278.4	568.3	242.8	262.8	5.4	6.2	15.5
12/31/2020	428.2	908.7	387.2	267.3	5.9	10.2	29.9
1/31/2021	331.6	544.5	314.9	266.7	5.9	9.5	16.5
2/28/2021	329.4	438.6	289.3	265	7.3	9.5	13.1
3/31/2021	306.9	394.5	297.8	265	6.8	7.9	10.6
4/30/2021	346.2	677.4	309.6	260.4	6.4	8.2	18.3
5/31/2021	333	488.8	291.2	257.8	5.1	8.5	17.7
6/30/2021	290.9	411	280.2	262	4.8	5.6	10.5
7/31/2021	490.6	1002.8	378.7	269.9	4.7	7.4	15.6
8/31/2021	347.1	564.6	300.1	279.6	3.5	4.8	10.3
9/30/2021	404.4	969.1	344.6	294.7	3.9	4.6	9.5
10/31/2021	358.1	626.4	305.7	304.9	5.1	8.1	13.4
11/30/2021	340	498.9	328.5	313.6	5.1	5.9	9
12/31/2021	280.8	385	270.5	305	7.8	8.7	17.4
1/31/2022	292.8	466	282.9	302.4	8.3	10.5	19.5
2/28/2022	396.4	555	368.9	304.8	7.4	11.3	17.3
3/31/2022	359	456.1	339.8	308.3	8.5	9.5	13
4/30/2022	319.1	420.1	305.5	308	6.5	7.4	9.3

Parameter	Flow	Flow	Flow	Flow	CBOD5/NH 3-N	CBOD5/NH 3-N	CBOD5/NH 3-N
	Monthly Ave	Daily Max	Monthly Ave	ANNL AVG	Monthly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	MGD	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	436	25	40	Report
Minimum	201.7	235.7	195.4	246.5	3.5	4.6	7.5
Maximum	568.2	1002.8	483.9	319.6	10.9	13.9	39.4
Median	322.1	488.65	298.1	283.55	6.2	7.8	13.45
No. of Violations	N/A	N/A	N/A	0	0	0	N/A
5/31/2022	256	303.6	253.6	302.5	6.4	7	10.2
6/30/2022	233.6	338.3	224.7	297	7.9	7.7	38.1
7/31/2022	205.6	235.7	202.2	282.7	6.2	11.4	8.7
8/31/2022	201.7	272	195.4	272	5.8	6.4	9.6
9/30/2022	223.3	324.9	208.9	262.8	5.3	5.7	7.5
10/31/2022	252.1	423.3	227.2	256.6	5.2	6.8	10.2
11/30/2022	241	358.7	224.5	246.5	8.9	9	16.1
12/31/2022	339.2	638.3	298.4	248.3	6.7	10	15.1

Parameter	CBOD5/NH3-N % Removal	TSS	TSS	TSS	TSS % Removal	Solids, settleable
	Monthly Ave	Monthly Ave	Weekly Ave	Daily Max	Monthly Ave	Weekly Ave
Units	%	mg/L	mg/L	mg/L	%	mL/L
Effluent Limit	Report	30	45	Report	Report	Report
Minimum	89.2	6.1	7	14.6	85.7	0
Maximum	97	20.7	24.8	66.3	97.3	0.1
Median	94.7	9.8	13.15	25.9	94.85	0.01
No. of Violations	N/A	0	0	N/A	N/A	N/A
1/31/2018	92.1	16.2	23	38.5	92.3	0.01
2/28/2018	91.9	15	18.3	23	91.8	0.01
3/31/2018	91.1	16	21.1	35.5	88.8	0
4/30/2018	93.1	17.1	24.8	54.4	91.3	0.01
5/31/2018	93.9	11.7	15.9	29.2	94.9	0.01
6/30/2018	95.9	8.9	9.9	19.2	96.7	0.04
7/31/2018	95.1	9.2	11.5	33.6	95.9	0
8/31/2018	97.0	7.9	9.4	18.3	97.1	0
9/30/2018	97.0	8.9	11	30.8	97.3	0.01
10/31/2018	96.1	8.6	12.2	38	96.8	0
11/30/2018	94.6	9.2	10.5	16.5	95.4	0.07
12/31/2018	95.0	10.7	14.3	18.8	94.7	0
1/31/2019	90.7	16.5	23.5	36.6	88.5	0
2/28/2019	89.2	20.7	24.2	39.2	85.7	0
3/31/2019	90.3	18.6	24.2	26.8	86	0.01
4/30/2019	94.3	11.4	15.6	28	92.7	0.01
5/31/2019	94.2	10.9	13	21.4	93.8	0
6/30/2019	95.0	11.2	13.8	22.8	94.2	0.01
7/31/2019	95.7	7.4	9	23.1	96	0.01
8/31/2019	95.8	9.6	12.5	34.4	95.5	0.04
9/30/2019	96.6	10.6	13.7	24.7	95.8	0.01
10/31/2019	96.0	8.5	11	28.5	96	0.01
11/30/2019	95.8	9.6	12.4	33.7	96.1	0
12/31/2019	94.9	9.3	10.8	24.1	94.8	0
1/31/2020	95.1	9.6	17.4	21.7	95	0
2/29/2020	95.1	14.4	15.9	24.4	94.7	0.01

Parameter	CBOD5/NH3-N %	TSS	TSS	TSS	TSS %	Solids,
	Removal				Removal	settleable
	Monthly Ave	Monthly Ave	Weekly Ave	Daily Max	Monthly Ave	Weekly Ave
Units	%	mg/L	mg/L	mg/L	%	mL/L
Effluent Limit	Report	30	45	Report	Report	Report
Minimum	89.2	6.1	7	14.6	85.7	0
Maximum	97	20.7	24.8	66.3	97.3	0.1
Median	94.7	9.8	13.15	25.9	94.85	0.01
No. of Violations	N/A	0	0	N/A	N/A	N/A
3/31/2020	94.0	14.5	17.3	33.2	92.8	0
4/30/2020	92.6	8.2	10.8	16.4	94	0.06
5/31/2020	93.1	9.4	12.2	18.2	94.1	0.01
6/30/2020	94.7	9.9	13.2	26.4	95.3	0.03
7/31/2020	96.0	6.1	8.9	14.8	97.1	0
8/31/2020	96.3	6.6	9.3	26.2	96.9	0
9/30/2020	96.9	7.1	7	24.2	96.1	0
10/31/2020	96.4	7.4	10.8	28.7	96.5	0.1
11/30/2020	95.7	7.6	9.2	27	96	0.03
12/31/2020	91.9	9.9	13.8	34.5	91.8	0.04
1/31/2021	94.2	6.4	7.9	17.8	96.1	0.03
2/28/2021	93.4	12.2	14.1	40	92.4	0
3/31/2021	93.4	10.4	11.7	16	94.2	0.01
4/30/2021	93.8	12.7	15.2	20.5	92.8	0.07
5/31/2021	95	9.5	15.4	28	95	0.01
6/30/2021	95.7	7.8	9.7	24.8	96.2	0.01
7/31/2021	93.6	8.5	14.2	30.8	93.6	0.01
8/31/2021	96.3	6.8	7.5	20	96.1	0.01
9/30/2021	95.3	6.7	10.7	22.6	95.3	0.1
10/31/2021	94.8	11.7	18.5	29	93.3	0.04
11/30/2021	94.6	7	7.8	14.6	95.4	0.01
12/31/2021	94.6	11.6	13.7	25.8	95.4	0.01
1/31/2022	92.6	13.9	19.3	28	92.6	0.07
2/28/2022	91.4	15	22.3	31	90	0
3/31/2022	91.2	16.6	19.7	24.4	90.9	0.01
4/30/2022	93.6	13.9	18.3	26	92.4	0.01

Parameter	CBOD5/NH3-N % Removal	TSS	TSS	TSS	TSS % Removal	Solids, settleable
	Monthly Ave	Monthly Ave	Weekly Ave	Daily Max	Monthly Ave	Weekly Ave
Units	%	mg/L	mg/L	mg/L	%	mL/L
Effluent Limit	Report	30	45	Report	Report	Report
Minimum	89.2	6.1	7	14.6	85.7	0
Maximum	97	20.7	24.8	66.3	97.3	0.1
Median	94.7	9.8	13.15	25.9	94.85	0.01
No. of Violations	N/A	0	0	N/A	N/A	N/A
5/31/2022	94.5	12.3	16.9	21.8	94.4	0.01
6/30/2022	94.1	12.7	13.1	66.3	94	0
7/31/2022	95.5	10.2	19.7	23.2	95.1	0
8/31/2022	96	8.9	11	15.4	96.1	0
9/30/2022	96.3	8.3	10.4	15.8	96.5	0
10/31/2022	96.3	7.9	12.1	26	96.5	0
11/30/2022	94.7	11	13.6	20.7	94.8	0
12/31/2022	93.9	9.7	11.7	26	94.5	0

Parameter	Solids, settleable	pH	pH	Fecal Coliform	Fecal Coliform	Coliform, fecal - % sample exceeds limit
	Daily Max	Minimum	Maximum	WKLY GEO	Daily Max	Maximum
Units	mL/L	SU	SU	#/100mL	#/100mL	%
Effluent Limit	Report	6	9	14000	14000	10
Minimum	0	6.2	6.8	5	8	0
Maximum	0.6	6.6	7.2	26	341	2.2
Median	0.1	6.5	6.9	8	27.5	0
No. of Violations	N/A	0	0	0	0	0
1/31/2018	0.1	6.5	7	8	44	0
2/28/2018	0.1	6.5	7	6	10	0
3/31/2018	0	6.5	7	9	23	0
4/30/2018	0.1	6.5	6.9	9	15	0
5/31/2018	0.1	6.3	6.9	7	11	0
6/30/2018	0.3	6.6	6.9	6	8	0
7/31/2018	0	6.6	7.1	6	11	0
8/31/2018	0.1	6.6	7	6	15	0
9/30/2018	0.1	6.6	7	7	29	0
10/31/2018	0	6.5	7	7	43	0
11/30/2018	0.5	6.5	7	16	63	0
12/31/2018	0	6.4	7.2	12	70	0
1/31/2019	0	6.4	7.1	13	103	0
2/28/2019	0	6.4	6.9	9	85	0
3/31/2019	0.1	6.3	6.9	9	36	0
4/30/2019	0.1	6.4	6.9	9	19	0
5/31/2019	0.1	6.5	6.9	7	18	0
6/30/2019	0.1	6.4	6.9	10	57	0
7/31/2019	0.1	6.4	6.9	8	25	0
8/31/2019	0.3	6.5	7	7	12	0
9/30/2019	0.1	6.5	7.1	6	10	0
10/31/2019	0.1	6.5	7.1	8	54	0
11/30/2019	0	6.6	7.1	9	23	0
12/31/2019	0	6.5	7	9	45	0
1/31/2020	0	6.5	7	9	54	1
2/29/2020	0.1	6.5	6.9	8	31	0

Parameter	Solids, settleable	pH	pH	Fecal Coliform	Fecal Coliform	Coliform, fecal - % sample exceeds limit
	Daily Max	Minimum	Maximum	WKLY GEO	Daily Max	Maximum
Units	mL/L	SU	SU	#/100mL	#/100mL	%
Effluent Limit	Report	6	9	14000	14000	10
Minimum	0	6.2	6.8	5	8	0
Maximum	0.6	6.6	7.2	26	341	2.2
Median	0.1	6.5	6.9	8	27.5	0
No. of Violations	N/A	0	0	0	0	0
3/31/2020	0	6.4	6.9	6	9	0
4/30/2020	0.2	6.3	6.9	7	20	0
5/31/2020	0	6.4	6.9	10	124	1
6/30/2020	0.1	6.3	6.9	7	28	0
7/31/2020	0	6.3	6.9	5	9	0
8/31/2020	0	6.4	6.9	5	9	0
9/30/2020	0.3	6.6	6.9	5	45	0
10/31/2020	0.1	6.4	7.1	8	102	1.1
11/30/2020	0.1	6.5	6.9	6	8	0
12/31/2020	0.3	6.4	6.9	7	18	0
1/31/2021	0.1	6.4	6.9	7	16	0
2/28/2021	0	6.5	7	7	46	0
3/31/2021	0.1	6.3	6.8	6	8	0
4/30/2021	0.5	6.4	6.9	7	13	0
5/31/2021	0	6.5	6.9	6	15	0
6/30/2021	0.1	6.5	7	7	41	0
7/31/2021	0.1	6.2	6.9	14	126	0
8/31/2021	0.1	6.5	6.9	26	320	2.2
9/30/2021	0.6	6.5	6.9	25	260	0
10/31/2021	0.1	6.5	6.9	14	29	0
11/30/2021	0.1	6.4	6.9	8	24	0
12/31/2021	0.5	6.4	7.1	6	9	0
1/31/2022	0	6.5	7	8	91	0
2/28/2022	0.1	6.5	7	10	84	0
3/31/2022	0	6.5	7	11	35	0
4/30/2022	0.1	6.5	6.9	8	22	0

Parameter	Solids, settleable	pH	pH	Fecal Coliform	Fecal Coliform	Coliform, fecal - % sample exceeds limit
	Daily Max	Minimum	Maximum	WKLY GEO	Daily Max	Maximum
Units	mL/L	SU	SU	#/100mL	#/100mL	%
Effluent Limit	Report	6	9	14000	14000	10
Minimum	0	6.2	6.8	5	8	0
Maximum	0.6	6.6	7.2	26	341	2.2
Median	0.1	6.5	6.9	8	27.5	0
No. of Violations	N/A	0	0	0	0	0
5/31/2022	0.1	6.6	6.9	8	11	0
6/30/2022	0	6.5	6.9	10	53	0
7/31/2022	0	6.5	7	7	13	0
8/31/2022	0	6.5	6.9	6	14	0
9/30/2022	0	6.5	6.9	8	33	0
10/31/2022	0	6.4	6.9	7	31	0
11/30/2022	0	6.4	6.9	7	27	0
12/31/2022	0	6.5	6.9	12	341	0

Parameter	TRC	TRC	Ammonia	Nitrate	Nitrite	TKN	Arsenic, total (as As)
	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave
Units	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	ug/L
Effluent Limit	456	631	Report	Report	Report	Report	Report
Minimum	0	0	12.82	0	0.03	13.68	0
Maximum	2.15	53.33	39.31	1.17	1.53	41.25	0.849
Median	0	0	24.89	0.155	0.44	26.3	0
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A
1/31/2018	0	0	28.08	0.12	0.2	28.7	0
2/28/2018	0	0	21.74	0.08	0.17	23.86	0
3/31/2018	0.86	13.33	16.9	0.43	0.68	18.36	0
4/30/2018	0	0	21.66	0.27	0.44	21.58	0
5/31/2018	0	0	25.29	0.15	0.35	25.42	0
6/30/2018	0	0	32.84	0.06	0.04	33.66	0
7/31/2018	0	0	29.6	0.11	0.22	28.22	0
8/31/2018	0	0	29.88	0.11	0.99	28.97	0
9/30/2018	0	0	28.59	0.05	0.17	26.28	0
10/31/2018	0	0	26.33	0.08	0.35	26.32	0
11/30/2018	0	0	12.91	0.27	1.47	13.68	0
12/31/2018	0	0	18.43	0.19	0.83	19.56	0
1/31/2019	0	0	22.55	0.16	0.95	26.5	0
2/28/2019	0	0	22.89	0.16	1.04	25.4	0
3/31/2019	0	0	24.27	0.11	0.57	25.32	0
4/30/2019	1.78	53.33	22.17	0.39	1.41	21.98	0
5/31/2019	0	0	21.91	0.26	1.08	23.73	0
6/30/2019	0	0	30.29	0.06	0.33	34.14	0
7/31/2019	0	0	25.66	0.13	0.75	25.55	0
8/31/2019	0.54	16.67	27.53	0.06	0.51	32.66	0
9/30/2019	0	0	33.93	0.07	0.44	37.46	0
10/31/2019	0	0	33.44	0.13	0.66	36.35	0
11/30/2019	0	0	26.59	0.1	0.17	27.82	0
12/31/2019	0.54	16.67	19.9	0.21	1.44	19.96	0.65
1/31/2020	2.15	43.33	22.56	0.17	1	24.58	0
2/29/2020	0	0	24.46	0.13	0.21	27.7	0

Parameter	TRC	TRC	Ammonia	Nitrate	Nitrite	TKN	Arsenic, total (as As)
	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave
Units	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	ug/L
Effluent Limit	456	631	Report	Report	Report	Report	Report
Minimum	0	0	12.82	0	0.03	13.68	0
Maximum	2.15	53.33	39.31	1.17	1.53	41.25	0.849
Median	0	0	24.89	0.155	0.44	26.3	0
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A
3/31/2020	0	0	24.97	0.15	0.44	26.54	0
4/30/2020	0	0	16.51	0.46	1.31	18.14	0
5/31/2020	0	0	22.69	0.21	0.44	26.56	0
6/30/2020	0	0	30.99	0.17	0.21	34.1	0
7/31/2020	0	0	31.04	0.03	0.12	31.42	0
8/31/2020	0	0	34.56	0.01	0.12	34.74	0
9/30/2020	0	0	34.7	0	0.03	38.72	0
10/31/2020	0	0	33.66	0	0.42	35.14	0
11/30/2020	0	0	28.45	0.03	0.17	34.34	0
12/31/2020	1.08	33.33	17.27	0.42	1.38	19.4	0.695
1/31/2021	0.54	16.67	22.47	1.17	0.78	22.74	0
2/28/2021	0	0	21.54	0.03	0.46	23.52	0
3/31/2021	0	0	25.03	0.02	0.43	24.83	0
4/30/2021	0	0	22.83	0.15	0.61	23.28	0
5/31/2021	0	0	20.46	1.1	0.61	23.42	0
6/30/2021	0	0	22.59	0.41	0.26	23.95	0
7/31/2021	0	0	12.82	0.53	1.53	15.43	0
8/31/2021	0	0	20.77	0.23	0.5	22.32	0
9/30/2021	0	0	19.61	0.23	0.4	22.23	0.403
10/31/2021	0	0	21.59	0.4	0.48	24.22	0.401
11/30/2021	0	0	19.04	0.83	0.33	20.52	0
12/31/2021	0	0	29.5	0.57	0.11	29.7	0
1/31/2022	0	0	26.89	0.27	0.35	29.06	0
2/28/2022	0	0	21.79	0.27	0.57	23.9	0
3/31/2022	0.43	13.33	23.16	0.62	0.64	26.02	0
4/30/2022	0	0	24.16	0.34	0.54	27	0

Parameter	TRC	TRC	Ammonia	Nitrate	Nitrite	TKN	Arsenic, total (as As)
	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave
Units	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	ug/L
Effluent Limit	456	631	Report	Report	Report	Report	Report
Minimum	0	0	12.82	0	0.03	13.68	0
Maximum	2.15	53.33	39.31	1.17	1.53	41.25	0.849
Median	0	0	24.89	0.155	0.44	26.3	0
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A
5/31/2022	0	0	28.59	0.86	0.36	31.78	0.473
6/30/2022	0	0	33.38	0.92	0.1	36.5	0.439
7/31/2022	0.43	13.33	34.77	0.05	0.16	41.25	0
8/31/2022	0	0	39.31	0.01	0.33	38.7	0.451
9/30/2022	0	0	31.13	0.14	1.5	36.6	0.849
10/31/2022	0	0	33.31	0.06	0.26	33.74	0
11/30/2022	0	0	35.63	0.12	0.58	32.32	0
12/31/2022	1.51	23.33	24.81	0.32	0.44	23.34	0

Parameter	Arsenic, total (as As)	Copper	Copper	Mercury, total (as Hg)	Mercury, total (as Hg)
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	2.09	2.51	0.00205	0.00223
Maximum	1.39	13.15	36.2	0.01143	0.0317
Median	0	5.22	6.32	0.003595	0.004415
No. of Violations	N/A	N/A	N/A	N/A	N/A
1/31/2018	0	6.85	7.42	0.00381	0.00472
2/28/2018	0	6.96	8.72	0.00571	0.00952
3/31/2018	0	7.97	11.4	0.00534	0.00662
4/30/2018	0	6.83	8.02	0.00558	0.00617
5/31/2018	0	6.65	6.81	0.006	0.00717
6/30/2018	0	3.78	4.76	0.00346	0.00426
7/31/2018	0	4.05	9.18	0.00413	0.0111
8/31/2018	0	3.84	4.61	0.0027	0.00315
9/30/2018	0	4.57	6.24	0.00279	0.00309
10/31/2018	0	4.12	4.67	0.00301	0.00344
11/30/2018	0	4.86	6.25	0.00398	0.00527
12/31/2018	0	4.24	5.26	0.00377	0.00484
1/31/2019	0	7.35	9.58	0.00444	0.00492
2/28/2019	0	7.78	8.99	0.00555	0.00613
3/31/2019	0	7.69	8.38	0.00623	0.00638
4/30/2019	0	6.6	7.35	0.00512	0.00587
5/31/2019	0	5.2	5.63	0.0033	0.0035
6/30/2019	0	6.12	7.06	0.00639	0.00837
7/31/2019	0	3.55	3.91	0.00228	0.00246
8/31/2019	0	5	10.2	0.00754	0.013
9/30/2019	0	4.32	5.12	0.00281	0.0032
10/31/2019	0	5.24	6.51	0.0026	0.00279
11/30/2019	0	4.25	4.77	0.00293	0.00344
12/31/2019	1.3	4.48	5.33	0.00381	0.00617
1/31/2020	0	4.06	5.57	0.00286	0.00368
2/29/2020	0	5.93	8.83	0.00414	0.00489

Parameter	Arsenic, total (as As)	Copper	Copper	Mercury, total (as Hg)	Mercury, total (as Hg)
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	2.09	2.51	0.00205	0.00223
Maximum	1.39	13.15	36.2	0.01143	0.0317
Median	0	5.22	6.32	0.003595	0.004415
No. of Violations	N/A	N/A	N/A	N/A	N/A
3/31/2020	0	6.82	7.94	0.00391	0.00439
4/30/2020	0	4.71	5.85	0.00341	0.00394
5/31/2020	0	5.75	6.94	0.00302	0.00326
6/30/2020	0	5.4	5.99	0.00464	0.00556
7/31/2020	0	2.09	2.51	0.00205	0.00223
8/31/2020	0	5.11	5.62	0.00305	0.00367
9/30/2020	0	4.56	4.84	0.00276	0.00322
10/31/2020	0	4.67	5.37	0.003	0.00392
11/30/2020	0	4.85	6.08	0.0035	0.00414
12/31/2020	1.39	13.15	36.2	0.01143	0.0317
1/31/2021	0	4.11	4.58	0.00256	0.00292
2/28/2021	0	6.05	7.43	0.00369	0.00434
3/31/2021	0	5.63	5.89	0.0042	0.00487
4/30/2021	0	5.64	6.8	0.00495	0.00616
5/31/2021	0	5.29	5.65	0.00379	0.00444
6/30/2021	0	2.99	3.44	0.00395	0.00534
7/31/2021	0	4.88	5.74	0.00349	0.00453
8/31/2021	0	3.99	5.02	0.00348	0.00397
9/30/2021	0.806	5.2	7.58	0.00299	0.00368
10/31/2021	0.802	4.67	5.3	0.00309	0.00378
11/30/2021	0	4.38	4.92	0.00259	0.00292
12/31/2021	0	6.08	7.66	0.00309	0.00337
1/31/2022	0	5.28	5.49	0.00336	0.00402
2/28/2022	0	6.21	7.01	0.0042	0.00496
3/31/2022	0	8	8.37	0.0087	0.0104
4/30/2022	0	7.09	7.88	0.00611	0.00683

Parameter	Arsenic, total (as As)	Copper	Copper	Mercury, total (as Hg)	Mercury, total (as Hg)
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	2.09	2.51	0.00205	0.00223
Maximum	1.39	13.15	36.2	0.01143	0.0317
Median	0	5.22	6.32	0.003595	0.004415
No. of Violations	N/A	N/A	N/A	N/A	N/A
5/31/2022	0.946	7.64	8.13	0.00599	0.00738
6/30/2022	0.877	6.02	6.44	0.00302	0.00333
7/31/2022	0	6.32	7.84	0.00398	0.00546
8/31/2022	0.902	5.33	6.39	0.00399	0.00457
9/30/2022	0.874	4.87	6.77	0.00335	0.00431
10/31/2022	0	4.79	6.09	0.00299	0.00326
11/30/2022	0	4.65	5.51	0.00291	0.00349
12/31/2022	0	5.75	6.46	0.00339	0.0053

Parameter	Cyanide, total recoverable	Cyanide, total recoverable	.gamma.-Chlordane, whole water	.gamma.-Chlordane, whole water
	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report
Minimum	0	0	0	0
Maximum	37	37	0	0
Median	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A
1/31/2018	0	0	0	0
2/28/2018	13	26	0	0
3/31/2018	0	0	0	0
4/30/2018	0	0	0	0
5/31/2018	0	0	0	0
6/30/2018	0	0	0	0
7/31/2018	0	0	0	0
8/31/2018	0	0	0	0
9/30/2018	0	0	0	0
10/31/2018	0	0	0	0
11/30/2018	0	0	0	0
12/31/2018	0	0	0	0
1/31/2019	0	0	0	0
2/28/2019	0	0	0	0
3/31/2019	10	20	0	0
4/30/2019	0	0	0	0
5/31/2019	0	0	0	0
6/30/2019	0	0	0	0
7/31/2019	0	0	0	0
8/31/2019	0	0	0	0
9/30/2019	0	0	0	0
10/31/2019	0	0	0	0
11/30/2019	0	0	0	0
12/31/2019	0	0	0	0
1/31/2020	0	0	0	0
2/29/2020	0	0	0	0

Parameter	Cyanide, total recoverable	Cyanide, total recoverable	.gamma.-Chlordane, whole water	.gamma.-Chlordane, whole water
	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report
Minimum	0	0	0	0
Maximum	37	37	0	0
Median	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A
3/31/2020	0	0	0	0
4/30/2020	0	0	0	0
5/31/2020	0	0	0	0
6/30/2020	0	0	0	0
7/31/2020	0	0	0	0
8/31/2020	0	0	0	0
9/30/2020	0	0	0	0
10/31/2020	0	0	0	0
11/30/2020	0	0	0	0
12/31/2020	0	0	0	0
1/31/2021	0	0	0	0
2/28/2021	0	0	0	0
3/31/2021	0	0	0	0
4/30/2021	0	0	0	0
5/31/2021	0	0	0	0
6/30/2021	0	0	0	0
7/31/2021	0	0	0	0
8/31/2021	0	0	0	0
9/30/2021	0	0	0	0
10/31/2021	0	0	0	0
11/30/2021	0	0	0	0
12/31/2021	0	0	0	0
1/31/2022	37	37	0	0
2/28/2022	0	0	0	0
3/31/2022	0	0	0	0
4/30/2022	0	0	0	0

Parameter	Cyanide, total recoverable	Cyanide, total recoverable	.gamma.-Chlordane, whole water	.gamma.-Chlordane, whole water
	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report
Minimum	0	0	0	0
Maximum	37	37	0	0
Median	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A
5/31/2022	0	0	0	0
6/30/2022	0	0	0	0
7/31/2022	0	0	0	0
8/31/2022	0	0	0	0
9/30/2022	0	0	0	0
10/31/2022	0	0	0	0
11/30/2022	0	0	0	0
12/31/2022	0	0	0	0

Parameter	4,4'-DDT	4,4'-DDT	Aldrin	Aldrin	Chlordane (tech mix. and metabolites)
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0	0	0	0
Maximum	0	0	0	0	0
Median	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A
1/31/2018	0	0	0	0	0
2/28/2018	0	0	0	0	0
3/31/2018	0	0	0	0	0
4/30/2018	0	0	0	0	0
5/31/2018	0	0	0	0	0
6/30/2018	0	0	0	0	0
7/31/2018	0	0	0	0	0
8/31/2018	0	0	0	0	0
9/30/2018	0	0	0	0	0
10/31/2018	0	0	0	0	0
11/30/2018	0	0	0	0	0
12/31/2018	0	0	0	0	0
1/31/2019	0	0	0	0	0
2/28/2019	0	0	0	0	0
3/31/2019	0	0	0	0	0
4/30/2019	0	0	0	0	0
5/31/2019	0	0	0	0	0
6/30/2019	0	0	0	0	0
7/31/2019	0	0	0	0	0
8/31/2019	0	0	0	0	0
9/30/2019	0	0	0	0	0
10/31/2019	0	0	0	0	0
11/30/2019	0	0	0	0	0
12/31/2019	0	0	0	0	0
1/31/2020	0	0	0	0	0
2/29/2020	0	0	0	0	0

Parameter	4,4'-DDT	4,4'-DDT	Aldrin	Aldrin	Chlordane (tech mix. and metabolites)
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0	0	0	0
Maximum	0	0	0	0	0
Median	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A
3/31/2020	0	0	0	0	0
4/30/2020	0	0	0	0	0
5/31/2020	0	0	0	0	0
6/30/2020	0	0	0	0	0
7/31/2020	0	0	0	0	0
8/31/2020	0	0	0	0	0
9/30/2020	0	0	0	0	0
10/31/2020	0	0	0	0	0
11/30/2020	0	0	0	0	0
12/31/2020	0	0	0	0	0
1/31/2021	0	0	0	0	0
2/28/2021	0	0	0	0	0
3/31/2021	0	0	0	0	0
4/30/2021	0	0	0	0	0
5/31/2021	0	0	0	0	0
6/30/2021	0	0	0	0	0
7/31/2021	0	0	0	0	0
8/31/2021	0	0	0	0	0
9/30/2021	0	0	0	0	0
10/31/2021	0	0	0	0	0
11/30/2021	0	0	0	0	0
12/31/2021	0	0	0	0	0
1/31/2022	0	0	0	0	0
2/28/2022	0	0	0	0	0
3/31/2022	0	0	0	0	0
4/30/2022	0	0	0	0	0

Parameter	4,4'-DDT	4,4'-DDT	Aldrin	Aldrin	Chlordane (tech mix. and metabolites)
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0	0	0	0
Maximum	0	0	0	0	0
Median	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A
5/31/2022	0	0	0	0	0
6/30/2022	0	0	0	0	0
7/31/2022	0	0	0	0	0
8/31/2022	0	0	0	0	0
9/30/2022	0	0	0	0	0
10/31/2022	0	0	0	0	0
11/30/2022	0	0	0	0	0
12/31/2022	0	0	0	0	0

Parameter	Chlordane (tech mix. and metabolites)	Chlordane, .alpha.-, whole water	Chlordane, .alpha.-, whole water	Dieldrin	Dieldrin
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0	0	0	0
Maximum	0	0	0	0	0
Median	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A
1/31/2018	0	0	0	0	0
2/28/2018	0	0	0	0	0
3/31/2018	0	0	0	0	0
4/30/2018	0	0	0	0	0
5/31/2018	0	0	0	0	0
6/30/2018	0	0	0	0	0
7/31/2018	0	0	0	0	0
8/31/2018	0	0	0	0	0
9/30/2018	0	0	0	0	0
10/31/2018	0	0	0	0	0
11/30/2018	0	0	0	0	0
12/31/2018	0	0	0	0	0
1/31/2019	0	0	0	0	0
2/28/2019	0	0	0	0	0
3/31/2019	0	0	0	0	0
4/30/2019	0	0	0	0	0
5/31/2019	0	0	0	0	0
6/30/2019	0	0	0	0	0
7/31/2019	0	0	0	0	0
8/31/2019	0	0	0	0	0
9/30/2019	0	0	0	0	0
10/31/2019	0	0	0	0	0
11/30/2019	0	0	0	0	0
12/31/2019	0	0	0	0	0
1/31/2020	0	0	0	0	0
2/29/2020	0	0	0	0	0

Parameter	Chlordane (tech mix. and metabolites)	Chlordane, .alpha.-, whole water	Chlordane, .alpha.-, whole water	Dieldrin	Dieldrin
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0	0	0	0
Maximum	0	0	0	0	0
Median	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A
3/31/2020	0	0	0	0	0
4/30/2020	0	0	0	0	0
5/31/2020	0	0	0	0	0
6/30/2020	0	0	0	0	0
7/31/2020	0	0	0	0	0
8/31/2020	0	0	0	0	0
9/30/2020	0	0	0	0	0
10/31/2020	0	0	0	0	0
11/30/2020	0	0	0	0	0
12/31/2020	0	0	0	0	0
1/31/2021	0	0	0	0	0
2/28/2021	0	0	0	0	0
3/31/2021	0	0	0	0	0
4/30/2021	0	0	0	0	0
5/31/2021	0	0	0	0	0
6/30/2021	0	0	0	0	0
7/31/2021	0	0	0	0	0
8/31/2021	0	0	0	0	0
9/30/2021	0	0	0	0	0
10/31/2021	0	0	0	0	0
11/30/2021	0	0	0	0	0
12/31/2021	0	0	0	0	0
1/31/2022	0	0	0	0	0
2/28/2022	0	0	0	0	0
3/31/2022	0	0	0	0	0
4/30/2022	0	0	0	0	0

Parameter	Chlordane (tech mix. and metabolites)	Chlordane, .alpha.-, whole water	Chlordane, .alpha.-, whole water	Dieldrin	Dieldrin
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0	0	0	0
Maximum	0	0	0	0	0
Median	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A
5/31/2022	0	0	0	0	0
6/30/2022	0	0	0	0	0
7/31/2022	0	0	0	0	0
8/31/2022	0	0	0	0	0
9/30/2022	0	0	0	0	0
10/31/2022	0	0	0	0	0
11/30/2022	0	0	0	0	0
12/31/2022	0	0	0	0	0

Parameter	Heptachlor	Heptachlor	Heptachlor epoxide	Heptachlor epoxide	Hexachloro benzene	Hexachloro benzene	PCB-1016
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report	Report	0.000045
Minimum	0	0	0	0	0	0	0
Maximum	0	0	0	0	0	0	0
Median	0	0	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	0
1/31/2018	0	0	0	0	0	0	0
2/28/2018	0	0	0	0	0	0	0
3/31/2018	0	0	0	0	0	0	0
4/30/2018	0	0	0	0	0	0	0
5/31/2018	0	0	0	0	0	0	0
6/30/2018	0	0	0	0	0	0	0
7/31/2018	0	0	0	0	0	0	0
8/31/2018	0	0	0	0	0	0	0
9/30/2018	0	0	0	0	0	0	0
10/31/2018	0	0	0	0	0	0	0
11/30/2018	0	0	0	0	0	0	0
12/31/2018	0	0	0	0	0	0	0
1/31/2019	0	0	0	0	0	0	0
2/28/2019	0	0	0	0	0	0	0
3/31/2019	0	0	0	0	0	0	0
4/30/2019	0	0	0	0	0	0	0
5/31/2019	0	0	0	0	0	0	0
6/30/2019	0	0	0	0	0	0	0
7/31/2019	0	0	0	0	0	0	0
8/31/2019	0	0	0	0	0	0	0
9/30/2019	0	0	0	0	0	0	0
10/31/2019	0	0	0	0	0	0	0
11/30/2019	0	0	0	0	0	0	0
12/31/2019	0	0	0	0	0	0	0
1/31/2020	0	0	0	0	0	0	0
2/29/2020	0	0	0	0	0	0	0

Parameter	Heptachlor	Heptachlor	Heptachlor epoxide	Heptachlor epoxide	Hexachloro benzene	Hexachloro benzene	PCB-1016
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report	Report	0.000045
Minimum	0	0	0	0	0	0	0
Maximum	0	0	0	0	0	0	0
Median	0	0	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	0
3/31/2020	0	0	0	0	0	0	0
4/30/2020	0	0	0	0	0	0	0
5/31/2020	0	0	0	0	0	0	0
6/30/2020	0	0	0	0	0	0	0
7/31/2020	0	0	0	0	0	0	0
8/31/2020	0	0	0	0	0	0	0
9/30/2020	0	0	0	0	0	0	0
10/31/2020	0	0	0	0	0	0	0
11/30/2020	0	0	0	0	0	0	0
12/31/2020	0	0	0	0	0	0	0
1/31/2021	0	0	0	0	0	0	0
2/28/2021	0	0	0	0	0	0	0
3/31/2021	0	0	0	0	0	0	0
4/30/2021	0	0	0	0	0	0	0
5/31/2021	0	0	0	0	0	0	0
6/30/2021	0	0	0	0	0	0	0
7/31/2021	0	0	0	0	0	0	0
8/31/2021	0	0	0	0	0	0	0
9/30/2021	0	0	0	0	0	0	0
10/31/2021	0	0	0	0	0	0	0
11/30/2021	0	0	0	0	0	0	0
12/31/2021	0	0	0	0	0	0	0
1/31/2022	0	0	0	0	0	0	0
2/28/2022	0	0	0	0	0	0	0
3/31/2022	0	0	0	0	0	0	0
4/30/2022	0	0	0	0	0	0	0

Parameter	Heptachlor	Heptachlor	Heptachlor epoxide	Heptachlor epoxide	Hexachloro benzene	Hexachloro benzene	PCB-1016
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report	Report	0.000045
Minimum	0	0	0	0	0	0	0
Maximum	0	0	0	0	0	0	0
Median	0	0	0	0	0	0	0
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	0
5/31/2022	0	0	0	0	0	0	0
6/30/2022	0	0	0	0	0	0	0
7/31/2022	0	0	0	0	0	0	0
8/31/2022	0	0	0	0	0	0	0
9/30/2022	0	0	0	0	0	0	0
10/31/2022	0	0	0	0	0	0	0
11/30/2022	0	0	0	0	0	0	0
12/31/2022	0	0	0	0	0	0	0

Parameter	PCB-1016	PCB-1221	PCB-1221	PCB-1232	PCB-1232	PCB-1242	PCB-1242
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	0.000045	Report	0.000045	Report	0.000045	Report
Minimum	0	0	0	0	0	0	0
Maximum	0	0	0	0	0	0	0
Median	0	0	0	0	0	0	0
No. of Violations	N/A	0	N/A	0	N/A	0	N/A
1/31/2018	0	0	0	0	0	0	0
2/28/2018	0	0	0	0	0	0	0
3/31/2018	0	0	0	0	0	0	0
4/30/2018	0	0	0	0	0	0	0
5/31/2018	0	0	0	0	0	0	0
6/30/2018	0	0	0	0	0	0	0
7/31/2018	0	0	0	0	0	0	0
8/31/2018	0	0	0	0	0	0	0
9/30/2018	0	0	0	0	0	0	0
10/31/2018	0	0	0	0	0	0	0
11/30/2018	0	0	0	0	0	0	0
12/31/2018	0	0	0	0	0	0	0
1/31/2019	0	0	0	0	0	0	0
2/28/2019	0	0	0	0	0	0	0
3/31/2019	0	0	0	0	0	0	0
4/30/2019	0	0	0	0	0	0	0
5/31/2019	0	0	0	0	0	0	0
6/30/2019	0	0	0	0	0	0	0
7/31/2019	0	0	0	0	0	0	0
8/31/2019	0	0	0	0	0	0	0
9/30/2019	0	0	0	0	0	0	0
10/31/2019	0	0	0	0	0	0	0
11/30/2019	0	0	0	0	0	0	0
12/31/2019	0	0	0	0	0	0	0
1/31/2020	0	0	0	0	0	0	0
2/29/2020	0	0	0	0	0	0	0

Parameter	PCB-1016	PCB-1221	PCB-1221	PCB-1232	PCB-1232	PCB-1242	PCB-1242
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	0.000045	Report	0.000045	Report	0.000045	Report
Minimum	0	0	0	0	0	0	0
Maximum	0	0	0	0	0	0	0
Median	0	0	0	0	0	0	0
No. of Violations	N/A	0	N/A	0	N/A	0	N/A
3/31/2020	0	0	0	0	0	0	0
4/30/2020	0	0	0	0	0	0	0
5/31/2020	0	0	0	0	0	0	0
6/30/2020	0	0	0	0	0	0	0
7/31/2020	0	0	0	0	0	0	0
8/31/2020	0	0	0	0	0	0	0
9/30/2020	0	0	0	0	0	0	0
10/31/2020	0	0	0	0	0	0	0
11/30/2020	0	0	0	0	0	0	0
12/31/2020	0	0	0	0	0	0	0
1/31/2021	0	0	0	0	0	0	0
2/28/2021	0	0	0	0	0	0	0
3/31/2021	0	0	0	0	0	0	0
4/30/2021	0	0	0	0	0	0	0
5/31/2021	0	0	0	0	0	0	0
6/30/2021	0	0	0	0	0	0	0
7/31/2021	0	0	0	0	0	0	0
8/31/2021	0	0	0	0	0	0	0
9/30/2021	0	0	0	0	0	0	0
10/31/2021	0	0	0	0	0	0	0
11/30/2021	0	0	0	0	0	0	0
12/31/2021	0	0	0	0	0	0	0
1/31/2022	0	0	0	0	0	0	0
2/28/2022	0	0	0	0	0	0	0
3/31/2022	0	0	0	0	0	0	0
4/30/2022	0	0	0	0	0	0	0

Parameter	PCB-1016	PCB-1221	PCB-1221	PCB-1232	PCB-1232	PCB-1242	PCB-1242
	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	0.000045	Report	0.000045	Report	0.000045	Report
Minimum	0	0	0	0	0	0	0
Maximum	0	0	0	0	0	0	0
Median	0	0	0	0	0	0	0
No. of Violations	N/A	0	N/A	0	N/A	0	N/A
5/31/2022	0	0	0	0	0	0	0
6/30/2022	0	0	0	0	0	0	0
7/31/2022	0	0	0	0	0	0	0
8/31/2022	0	0	0	0	0	0	0
9/30/2022	0	0	0	0	0	0	0
10/31/2022	0	0	0	0	0	0	0
11/30/2022	0	0	0	0	0	0	0
12/31/2022	0	0	0	0	0	0	0

Parameter	PCB-1248	PCB-1248	PCB-1254	PCB-1254	PCB-1260	PCB-1260	Polychlorinated biphenyls (PCBs)
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	0.000045	Report	0.000045	Report	0.000045	Report	Report
Minimum	0	0	0	0	0	0	0.00026
Maximum	0	0	0	0	0	0	0.0058
Median	0	0	0	0	0	0	0.000985
No. of Violations	0	N/A	0	N/A	0	N/A	N/A
1/31/2018	0	0	0	0	0	0	0.0003
2/28/2018	0	0	0	0	0	0	0.00041
3/31/2018	0	0	0	0	0	0	0.00029
4/30/2018	0	0	0	0	0	0	0.00074
5/31/2018	0	0	0	0	0	0	0.00097
6/30/2018	0	0	0	0	0	0	0.00122
7/31/2018	0	0	0	0	0	0	0.00084
8/31/2018	0	0	0	0	0	0	0.00052
9/30/2018	0	0	0	0	0	0	0.00074
10/31/2018	0	0	0	0	0	0	0.00076
11/30/2018	0	0	0	0	0	0	0.00045
12/31/2018	0	0	0	0	0	0	0.00026
1/31/2019	0	0	0	0	0	0	0.00035
2/28/2019	0	0	0	0	0	0	0.00068
3/31/2019	0	0	0	0	0	0	0.00038
4/30/2019	0	0	0	0	0	0	0.0003
5/31/2019	0	0	0	0	0	0	0.00032
6/30/2019	0	0	0	0	0	0	0.00103
7/31/2019	0	0	0	0	0	0	0.00107
8/31/2019	0	0	0	0	0	0	0.00147
9/30/2019	0	0	0	0	0	0	0.00101
10/31/2019	0	0	0	0	0	0	0.00078
11/30/2019	0	0	0	0	0	0	0.00087
12/31/2019	0	0	0	0	0	0	0.00082
1/31/2020	0	0	0	0	0	0	0.00086
2/29/2020	0	0	0	0	0	0	0.00099

Parameter	PCB-1248	PCB-1248	PCB-1254	PCB-1254	PCB-1260	PCB-1260	Polychlorinated biphenyls (PCBs)
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	0.000045	Report	0.000045	Report	0.000045	Report	Report
Minimum	0	0	0	0	0	0	0.00026
Maximum	0	0	0	0	0	0	0.0058
Median	0	0	0	0	0	0	0.000985
No. of Violations	0	N/A	0	N/A	0	N/A	N/A
3/31/2020	0	0	0	0	0	0	0.00449
4/30/2020	0	0	0	0	0	0	0.00337
5/31/2020	0	0	0	0	0	0	0.0016
6/30/2020	0	0	0	0	0	0	0.00097
7/31/2020	0	0	0	0	0	0	0.00081
8/31/2020	0	0	0	0	0	0	0.00079
9/30/2020	0	0	0	0	0	0	0.00093
10/31/2020	0	0	0	0	0	0	0.00079
11/30/2020	0	0	0	0	0	0	0.00082
12/31/2020	0	0	0	0	0	0	0.0011
1/31/2021	0	0	0	0	0	0	0.00047
2/28/2021	0	0	0	0	0	0	0.00146
3/31/2021	0	0	0	0	0	0	0.00141
4/30/2021	0	0	0	0	0	0	0.00111
5/31/2021	0	0	0	0	0	0	0.00057
6/30/2021	0	0	0	0	0	0	0.00101
7/31/2021	0	0	0	0	0	0	0.00132
8/31/2021	0	0	0	0	0	0	0.00116
9/30/2021	0	0	0	0	0	0	0.00145
10/31/2021	0	0	0	0	0	0	0.00125
11/30/2021	0	0	0	0	0	0	0.00118
12/31/2021	0	0	0	0	0	0	0.00199
1/31/2022	0	0	0	0	0	0	0.00194
2/28/2022	0	0	0	0	0	0	0.00352
3/31/2022	0	0	0	0	0	0	0.00571
4/30/2022	0	0	0	0	0	0	0.00441

Parameter	PCB-1248	PCB-1248	PCB-1254	PCB-1254	PCB-1260	PCB-1260	Polychlorinated biphenyls (PCBs)
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	0.000045	Report	0.000045	Report	0.000045	Report	Report
Minimum	0	0	0	0	0	0	0.00026
Maximum	0	0	0	0	0	0	0.0058
Median	0	0	0	0	0	0	0.000985
No. of Violations	0	N/A	0	N/A	0	N/A	N/A
5/31/2022	0	0	0	0	0	0	0.00107
6/30/2022	0	0	0	0	0	0	0.00098
7/31/2022	0	0	0	0	0	0	0.00148
8/31/2022	0	0	0	0	0	0	0.0015
9/30/2022	0	0	0	0	0	0	0.00129
10/31/2022	0	0	0	0	0	0	0.00084
11/30/2022	0	0	0	0	0	0	0.0058
12/31/2022	0	0	0	0	0	0	0.00159

Parameter	Polychlorinated biphenyls (PCBs)	Volatile fraction organics (EPA 624)	Volatile fraction organics (EPA 624)	LC50 Acute Menidia	LC50 Static 48Hr Acute Mysid. Bahia	Noael Statre 7Day Chronic Menidia
	Daily Max	Monthly Ave	Daily Max	Daily Min	Daily Min	Daily Min
Units	ug/L	ug/L	ug/L	%	%	%
Effluent Limit	Report	Report	Report	50	50	1.5
Minimum	0.00032	0	0	77.7	72.9	6.25
Maximum	0.00854	41.8	51.6	100	100	100
Median	0.001205	0	0	100	100	100
No. of Violations	N/A	N/A	N/A	0	0	0
1/31/2018	0.00039	0	0	100	100	100
2/28/2018	0.00071	0	0	100	100	100
3/31/2018	0.00059	0	0	100	100	100
4/30/2018	0.00089	0	0	100	100	100
5/31/2018	0.00106	6.6	13.2	100	100	100
6/30/2018	0.00164	0	0	100	100	50
7/31/2018	0.00292	0	0	100	100	50
8/31/2018	0.00084	0	0	100	100	100
9/30/2018	0.0008	0	0	100	100	50
10/31/2018	0.00089	0	0	100	100	100
11/30/2018	0.00058	0	0	100	100	100
12/31/2018	0.00032	0	0	100	100	100
1/31/2019	0.00045	5.25	10.5	100	100	100
2/28/2019	0.0009	41.8	51.6	100	100	50
3/31/2019	0.00043	0	0	100	100	50
4/30/2019	0.00039	0	0	100	100	100
5/31/2019	0.00044	0	0	100	100	100
6/30/2019	0.00183	6.7	13.4	100	100	25
7/31/2019	0.00115	0	0	100	100	100
8/31/2019	0.00268	0	0	100	85.4	100
9/30/2019	0.00115	0	0	100	92.6	100
10/31/2019	0.0009	0	0	100	100	100
11/30/2019	0.00101	0	0	100	100	100
12/31/2019	0.00114	0	0	100	100	100
1/31/2020	0.00115	0	0	100	100	100
2/29/2020	0.00118	0	0	100	100	100

Parameter	Polychlorinated biphenyls (PCBs)	Volatile fraction organics (EPA 624)	Volatile fraction organics (EPA 624)	LC50 Acute Menidia	LC50 Static 48Hr Acute Mysid. Bahia	Noael Statre 7Day Chronic Menidia
	Daily Max	Monthly Ave	Daily Max	Daily Min	Daily Min	Daily Min
Units	ug/L	ug/L	ug/L	%	%	%
Effluent Limit	Report	Report	Report	50	50	1.5
Minimum	0.00032	0	0	77.7	72.9	6.25
Maximum	0.00854	41.8	51.6	100	100	100
Median	0.001205	0	0	100	100	100
No. of Violations	N/A	N/A	N/A	0	0	0
3/31/2020	0.00514	0	0	100	100	100
4/30/2020	0.00365	0	0	100	100	100
5/31/2020	0.00325	0	0	100	100	100
6/30/2020	0.00129	0	0	100	100	50
7/31/2020	0.00089	0	0	100	100	50
8/31/2020	0.00116	0	0	100	100	50
9/30/2020	0.00104	0	0	100	100	50
10/31/2020	0.00097	0	0	100	73.3	50
11/30/2020	0.00094	0	0	100	100	6.25
12/31/2020	0.00193	5.4	10.8	100	100	100
1/31/2021	0.00053	0	0	100	100	100
2/28/2021	0.00308	17.47	29.6	100	100	100
3/31/2021	0.00154	0	0	100	100	100
4/30/2021	0.00142	0	0	100	100	100
5/31/2021	0.00075	3.89	7.77	100	100	100
6/30/2021	0.00123	0	0	100	100	100
7/31/2021	0.00153	13.5	27	100	100	100
8/31/2021	0.00152	0	0	100	100	100
9/30/2021	0.0017	0	0	100	100	100
10/31/2021	0.00315	0	0	100	100	100
11/30/2021	0.00156	0	0	100	100	50
12/31/2021	0.00243	0	0	100	100	50
1/31/2022	0.00224	0	0	100	100	100
2/28/2022	0.00404	0	0	100	100	50
3/31/2022	0.00601	0	0	100	100	50
4/30/2022	0.00469	0	0	100	100	50

Parameter	Polychlorinated biphenyls (PCBs)	Volatile fraction organics (EPA 624)	Volatile fraction organics (EPA 624)	LC50 Acute Menidia	LC50 Static 48Hr Acute Mysid. Bahia	Noael Statre 7Day Chronic Menidia
	Daily Max	Monthly Ave	Daily Max	Daily Min	Daily Min	Daily Min
Units	ug/L	ug/L	ug/L	%	%	%
Effluent Limit	Report	Report	Report	50	50	1.5
Minimum	0.00032	0	0	77.7	72.9	6.25
Maximum	0.00854	41.8	51.6	100	100	100
Median	0.001205	0	0	100	100	100
No. of Violations	N/A	N/A	N/A	0	0	0
5/31/2022	0.00233	0	0	100	100	100
6/30/2022	0.00172	0	0	100	100	50
7/31/2022	0.00173	5.05	10.1	100	100	50
8/31/2022	0.00181	0	0	100	100	25
9/30/2022	0.00162	0	0	100	100	50
10/31/2022	0.00094	0	0	77.7	72.9	25
11/30/2022	0.00854	0	0	92.6	91.4	25
12/31/2022	0.00202	5.25	10.5			

Parameter	Noel Static 1Hr Fert. Chronic Arbacia	TSS	TSS	TSS	CBOD5/N H3-N	CBOD5/N H3-N	CBOD5/N H3-N
	Daily Min	Monthly Ave	Weekly Ave	Daily Max	Monthly Ave	Weekly Ave	Daily Max
Units	%	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	1.5	Report	Report	Report	Report	Report	Report
Minimum	25	120.1	143.7	185.1	72.4	83.1	105.9
Maximum	100	331.6	368.2	624.7	169.1	205	252.3
Median	100	191.65	227	328.45	112.25	137.9	170.8
No. of Violations	0	N/A	N/A	N/A	N/A	N/A	N/A
1/31/2018	100	209.3	281.4	352.9	111.6	135.4	165.5
2/28/2018	100	182.1	227	277.8	100.9	110.2	143.4
3/31/2018	100	142.9	194	307.8	73.2	91.9	124.3
4/30/2018	100	197.5	223.2	286.7	95.9	108.5	132.8
5/31/2018	100	227.4	232.4	387.2	124.8	131.2	165.5
6/30/2018	100	267.2	291.4	360.3	147	163.9	194.2
7/31/2018	100	226.4	260.7	328.7	146.1	176.7	229.9
8/31/2018	100	270.6	273.3	433.3	154.8	162.6	234.3
9/30/2018	100	331.6	368.2	624.7	157.9	188.2	230.8
10/31/2018	100	268.8	302.8	453	125.8	141.5	174.5
11/30/2018	100	199	355.9	497.8	95.8	162	216.9
12/31/2018	100	202.9	221.2	308.1	127.1	137.6	216.9
1/31/2019	100	143.7	181.9	207.7	102.4	145.1	168
2/28/2019	100	144.6	165.7	227.7	101.2	119.1	134.2
3/31/2019	100	132.9	159.6	204.3	99.2	105.2	141.4
4/30/2019	100	155.8	207.1	471.7	99.2	131.6	199.6
5/31/2019	100	175.6	184.5	254.5	109.7	122.2	159.5
6/30/2019	100	191.6	205.2	283.3	133.4	138.5	171
7/31/2019	100	183.3	193.9	264.2	101.8	110.4	145.7
8/31/2019	100	212.4	252.3	390.4	129.7	144.3	190
9/30/2019	100	253.5	259.5	352.1	168.8	181	203
10/31/2019	100	212.8	268.9	392.6	136.2	173.2	188.6
11/30/2019	100	247.6	279	366.3	143.6	160.1	181.9
12/31/2019	100	179.3	231.1	344.3	109	148.7	196.6
1/31/2020	100	190.3	211.3	239.8	125.7	140.6	170.6
2/29/2020	100	270.4	357.2	599	139.8	151.2	187.5

Parameter	Noel Static 1Hr Fert. Chronic Arbacia	TSS	TSS	TSS	CBOD5/N H3-N	CBOD5/N H3-N	CBOD5/N H3-N
	Daily Min	Monthly Ave	Weekly Ave	Daily Max	Monthly Ave	Weekly Ave	Daily Max
Units	%	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	1.5	Report	Report	Report	Report	Report	Report
Minimum	25	120.1	143.7	185.1	72.4	83.1	105.9
Maximum	100	331.6	368.2	624.7	169.1	205	252.3
Median	100	191.65	227	328.45	112.25	137.9	170.8
No. of Violations	0	N/A	N/A	N/A	N/A	N/A	N/A
3/31/2020	100	201	245.6	331.6	123.1	141.5	171.9
4/30/2020	100	136.2	147.5	185.1	84.8	99	134.7
5/31/2020	100	158.4	178.8	220.2	103.9	129	161.7
6/30/2020	100	210.9	236	352.8	129.4	150.9	196.1
7/31/2020	100	207.8	227	450.6	128.8	138.2	184.4
8/31/2020	100	214.1	226	292.2	145.9	168.7	229
9/30/2020	100	180.6	194.8	290.5	160.3	174.4	202.8
10/31/2020	100	211.3	276.9	437.5	154.9	205	252.3
11/30/2020	100	191.7	236.2	357.6	126.9	146.1	220.4
12/31/2020	100	120.1	143.7	208	72.4	83.1	105.9
1/31/2021	100	164.9	196	328.2	101.6	113.2	159.7
2/28/2021	50	160.6	174.9	216.9	110.7	119.7	142.1
3/31/2021	100	178.4	193.2	309	103.6	116.5	142.3
4/30/2021	100	176	204.9	252.9	103.9	116.8	133.7
5/31/2021	100	190.2	319.4	493.3	103	117.7	140.6
6/30/2021	100	202.8	235.2	415.5	112	116.1	145.3
7/31/2021	100	133.1	209.9	232.3	73.8	100.4	127.9
8/31/2021	100	175.6	192.7	290	94.1	101	117.4
9/30/2021	100	143.6	169.6	239.7	82.3	96.7	123.9
10/31/2021	50	175.1	210.8	261.7	98.2	116.3	129.8
11/30/2021	100	151.6	162.1	246.8	94.1	95.5	132.8
12/31/2021	100	251.5	319.5	380.8	143.3	171.5	223
1/31/2022	100	187.7	214.3	321.6	112.5	121.2	141.3
2/28/2022	100	150.5	180.4	250.6	86.4	109.5	139.5
3/31/2022	100	182.5	189.9	365.9	96.9	99.3	118.3
4/30/2022	100	182.9	194.7	239.1	101.4	118.3	148.8

Parameter	Noel Static 1Hr Fert. Chronic Arbacia	TSS	TSS	TSS	CBOD5/N H3-N	CBOD5/N H3-N	CBOD5/N H3-N
	Daily Min	Monthly Ave	Weekly Ave	Daily Max	Monthly Ave	Weekly Ave	Daily Max
Units	%	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	1.5	Report	Report	Report	Report	Report	Report
Minimum	25	120.1	143.7	185.1	72.4	83.1	105.9
Maximum	100	331.6	368.2	624.7	169.1	205	252.3
Median	100	191.65	227	328.45	112.25	137.9	170.8
No. of Violations	0	N/A	N/A	N/A	N/A	N/A	N/A
5/31/2022	100	217.7	247.5	384	115.5	119.6	177.1
6/30/2022	100	210.5	265.3	378.6	134.9	139.1	188
7/31/2022	100	208.4	227.6	298.9	137.6	158.3	183.9
8/31/2022	100	229.6	239.7	371.6	144.5	166.3	192.7
9/30/2022	50	235	260.9	386.7	142.5	159.2	180.7
10/31/2022	25	227.6	292.5	396.7	141	190.4	228.6
11/30/2022	100	210.1	227.9	290.4	169.1	178.9	196.8
12/31/2022		177.4	260.5	338.5	110.2	162.3	164.7

Parameter	Chloride (as Cl)	Fecal Coliform	Fecal Coliform	Fecal Coliform
	Daily Max	Monthly Geometric Mean	Daily Max	MEDIAN
Units	mg/L	#/100mL	#/100mL	#/100mL
Effluent Limit	Report	200	400	200
Minimum	475	No Data	No Data	No Data
Maximum	2028	No Data	No Data	No Data
Median	853.5	No Data	No Data	No Data
No. of Violations	N/A	No Data	No Data	No Data
1/31/2018	2028			
2/28/2018	1427			
3/31/2018	1287			
4/30/2018	689			
5/31/2018	695			
6/30/2018	966			
7/31/2018	944			
8/31/2018	898			
9/30/2018	904			
10/31/2018	734			
11/30/2018	579			
12/31/2018	515			
1/31/2019	1628			
2/28/2019	1424			
3/31/2019	1316			
4/30/2019	730			
5/31/2019	770			
6/30/2019	728			
7/31/2019	822			
8/31/2019	901			
9/30/2019	932			
10/31/2019	982			
11/30/2019	817			
12/31/2019	1191			
1/31/2020	920			
2/29/2020	932			

Parameter	Chloride (as Cl)	Fecal Coliform	Fecal Coliform	Fecal Coliform
	Daily Max	Monthly Geometric Mean	Daily Max	MEDIAN
Units	mg/L	#/100mL	#/100mL	#/100mL
Effluent Limit	Report	200	400	200
Minimum	475	No Data	No Data	No Data
Maximum	2028	No Data	No Data	No Data
Median	853.5	No Data	No Data	No Data
No. of Violations	N/A	No Data	No Data	No Data
3/31/2020	838			
4/30/2020	760			
5/31/2020	775			
6/30/2020	894			
7/31/2020	944			
8/31/2020	944			
9/30/2020	1237			
10/31/2020	869			
11/30/2020	790			
12/31/2020	1097			
1/31/2021	782			
2/28/2021	1545			
3/31/2021	748			
4/30/2021	1057			
5/31/2021	495			
6/30/2021	593			
7/31/2021	475			
8/31/2021	695			
9/30/2021	565			
10/31/2021	639			
11/30/2021	510			
12/31/2021	557			
1/31/2022	1274			
2/28/2022	1340			
3/31/2022	834			
4/30/2022	541			

Parameter	Chloride (as Cl)	Fecal Coliform	Fecal Coliform	Fecal Coliform
	Daily Max	Monthly Geometric Mean	Daily Max	MEDIAN
Units	mg/L	#/100mL	#/100mL	#/100mL
Effluent Limit	Report	200	400	200
Minimum	475	No Data	No Data	No Data
Maximum	2028	No Data	No Data	No Data
Median	853.5	No Data	No Data	No Data
No. of Violations	N/A	No Data	No Data	No Data
5/31/2022	725			
6/30/2022	822			
7/31/2022	1022			
8/31/2022	903			
9/30/2022	1053			
10/31/2022	869			
11/30/2022	785			
12/31/2022	706			