

## Outfall 001

Parameter	Flow	Flow	CBOD5	CBOD5	CBOD5	CBOD5	CBOD5
	Monthly Ave	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave
Units	MGD	MGD	%	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	Report	480	25	767	40
<b>Minimum</b>	<b>0.831</b>	<b>0.942</b>	<b>96</b>	<b>27</b>	<b>3</b>	<b>39</b>	<b>3</b>
<b>Maximum</b>	<b>1.996</b>	<b>3.402</b>	<b>99</b>	<b>109</b>	<b>10</b>	<b>192</b>	<b>18</b>
<b>Median</b>	<b>1.1535</b>	<b>1.5965</b>	<b>98</b>	<b>52</b>	<b>5</b>	<b>68</b>	<b>7</b>
<b>No. of Violations</b>	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
1/31/2019	1.349	2.1	98	56	5	66	5
2/28/2019	1.314	1.726	98	53	5	69	6
3/31/2019	1.359	2.071	99	42	4	56	5
4/30/2019	1.996	2.962	99	51	3	53	3
5/31/2019	1.775	2.356	98	56	4	49	3
6/30/2019	1.422	1.916	99	36	3	114	7
7/31/2019	1.268	1.631	99	37	3	46	5
8/31/2019	1.05	1.235	98	56	5	75	5
9/30/2019	1.155	1.86	99	39	4	47	5
10/31/2019	1.24	1.643	97	109	10	192	18
11/30/2019	1.26	1.711	98	64	6	102	9
12/31/2019	1.102	1.542	98	36	4	46	6
1/31/2020	1.311	1.709	98	66	6	101	9
2/29/2020	1.211	1.76	99	36	4	50	5
3/31/2020	1.385	1.786	98	45	3	55	4
4/30/2020	1.316	1.705	98	33	3	52	4
5/31/2020	1.091	1.623	98	37	4	46	6
6/30/2020	0.877	1.069	98	41	5	69	9
7/31/2020	0.904	1.07	98	32	4	61	7
8/31/2020	0.856	1.105	98	27	4	39	5
9/30/2020	0.879	1.172	98	37	5	43	6
10/31/2020	0.926	1.132	98	52	7	68	9
11/30/2020	0.831	0.972	97	51	7	88	11
12/31/2020	0.853	1.428	98	28	4	40	6
1/31/2021	0.874	1.066	98	37	5	72	9
2/28/2021	0.844	0.942	98	52	7	79	11
3/31/2021	1.076	1.524	98	43	5	53	6
4/30/2021	1.276	1.786	98	56	5	60	6

## Outfall 001

Parameter	Flow	Flow	CBOD5	CBOD5	CBOD5	CBOD5	CBOD5
	Monthly Ave	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave
Units	MGD	MGD	%	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	Report	480	25	767	40
5/31/2021	1.152	1.521	98	61	6	90	10
6/30/2021	0.92	1.107	98	45	5	66	8
7/31/2021	1.192	1.694	98	57	5	78	7
8/31/2021	1.112	1.611	98	52	5	83	8
9/30/2021	1.13	1.426	97	81	8	130	13
10/31/2021	1.09	1.582	97	83	9	97	11
11/30/2021	1.149	1.475	98	60	6	90	8
12/31/2021	0.912	1.061	98	30	4	41	5
1/31/2022	0.98	1.241	98	41	5	46	6
2/28/2022	1.131	2.488	97	89	9	102	12
3/31/2022	1.41	1.828	98	53	5	80	7
4/30/2022	1.501	1.972	98	47	4	62	5
5/31/2022	1.254	1.455	98	66	6	75	7
6/30/2022	0.99	1.201	97	67	7	101	11
7/31/2022	0.922	1.319	98	41	5	58	7
8/31/2022	0.979	1.141	98	42	5	49	6
9/30/2022	1.071	1.363	98	48	5	71	7
10/31/2022	1.09	1.494	96	86	9	108	12
11/30/2022	1.057	1.222	98	56	6	60	7
12/31/2022	1.018	1.661	98	29	3	73	8
1/31/2023	1.303	1.849	98	55	5	67	6
2/28/2023	1.181	1.356	98	65	6	68	7
3/31/2023	1.327	1.674	98	59	5	97	10
4/30/2023	1.499	1.916	96	103	8	130	11
5/31/2023	1.338	1.96	97	65	6	71	6
6/30/2023	1.199	2.15	97	58	5	80	8
7/31/2023	1.782	3.402	97	76	5	112	9
8/31/2023	1.421	1.862	98	51	4	58	5
9/30/2023	1.23	1.428	98	52	5	63	6
10/31/2023	1.212	1.374	98	57	6	64	7
11/30/2023	1.145	1.378	98	53	5	65	7
12/31/2023	1.361	2.182	97	55	4	89	7

## Outfall 001

Parameter	CBOD5	CBOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	lb/d	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	863	45	Report	575	30	863	45	958
Minimum	35	3	96	22	3	26	3	26
Maximum	224	20	99	111	11	169	16	170
Median	82	8	98	50.5	5	64.5	6	72
No. of Violations	0	0	N/A	0	0	0	0	0
1/31/2019	80	7	98	63	6	73	7	81
2/28/2019	77	7	98	50	5	75	7	61
3/31/2019	57	5	98	51	5	56	5	57
4/30/2019	53	3	98	54	3	57	4	65
5/31/2019	174	11	98	64	4	84	5	89
6/30/2019	52	4	98	62	5	100	8	118
7/31/2019	51	5	98	40	4	48	5	51
8/31/2019	78	5	98	77	6	103	7	120
9/30/2019	53	5	98	55	5	59	6	78
10/31/2019	224	20	96	111	11	169	16	170
11/30/2019	126	11	98	58	5	86	8	80
12/31/2019	61	8	98	37	4	47	6	59
1/31/2020	103	9	97	68	6	103	9	103
2/29/2020	42	4	98	44	4	55	5	60
3/31/2020	56	4	98	36	3	41	3	50
4/30/2020	67	5	97	38	3	52	4	67
5/31/2020	51	6	98	36	4	50	6	51
6/30/2020	98	12	98	33	4	35	5	69
7/31/2020	53	6	99	25	3	52	6	35
8/31/2020	46	5	98	25	3	39	5	46
9/30/2020	59	6	98	31	4	43	6	46
10/31/2020	86	11	98	40	5	48	6	55
11/30/2020	120	15	98	31	4	36	5	40
12/31/2020	46	7	99	22	3	31	4	30
1/31/2021	92	11	99	22	3	26	3	26
2/28/2021	103	14	99	27	4	31	4	31
3/31/2021	72	7	98	35	4	37	5	48
4/30/2021	130	12	98	40	4	53	5	65

## Outfall 001

Parameter	CBOD5	CBOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	lb/d	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	863	45	Report	575	30	863	45	958
5/31/2021	89	10	98	44	4	50	6	53
6/30/2021	81	9	98	39	5	58	7	62
7/31/2021	90	8	97	57	5	83	8	90
8/31/2021	83	8	98	48	5	73	7	83
9/30/2021	143	14	97	88	9	130	13	133
10/31/2021	112	12	97	71	8	99	11	112
11/30/2021	122	11	97	62	6	74	7	81
12/31/2021	54	7	98	29	4	45	6	41
1/31/2022	58	7	98	40	5	46	6	51
2/28/2022	145	12	97	77	8	87	10	104
3/31/2022	85	7	98	51	4	68	6	75
4/30/2022	57	4	98	56	4	68	6	63
5/31/2022	99	10	97	84	8	109	10	129
6/30/2022	121	13	96	88	10	134	15	138
7/31/2022	66	8	98	48	6	79	8	98
8/31/2022	57	6	98	43	5	50	6	61
9/30/2022	80	7	98	49	5	99	9	125
10/31/2022	133	15	97	56	6	80	8	91
11/30/2022	87	10	98	50	5	55	6	60
12/31/2022	35	4	98	30	4	56	6	39
1/31/2023	67	7	98	54	5	64	6	64
2/28/2023	78	8	98	64	6	78	8	107
3/31/2023	121	12	98	50	4	62	6	70
4/30/2023	146	13	97	70	5	92	6	96
5/31/2023	94	8	98	61	5	70	6	84
6/30/2023	106	8	98	58	5	65	7	90
7/31/2023	151	11	97	78	5	111	9	142
8/31/2023	76	6	97	64	5	72	6	101
9/30/2023	84	8	97	79	7	87	8	107
10/31/2023	69	7	97	72	7	89	9	104
11/30/2023	93	10	98	52	5	65	6	74
12/31/2023	105	8	98	45	4	63	4	83

## Outfall 001

Parameter	TSS	pH	pH	E. coli	E. coli	TRC	TRC	TKN
	Daily Max	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	SU	SU	MPN/100mL	MPN/100mL	mg/L	mg/L	lb/d
Effluent Limit	50	6	8	126	406	1	1	Report
Minimum	3	6	6.8	1	1	0	0.02	57
Maximum	17	7.1	7.5	23.8	1732.9	0.12	0.98	531
Median	6.5	6.5	7.15	2.5	18.5	0.01	0.105	172
No. of Violations	0	0	0	0	2	0	0	N/A
1/31/2019	7	6.6	7.1	2.3	15.8	0	0.03	57
2/28/2019	5	6.5	7.3	1.1	2	0	0.04	224
3/31/2019	5	7.1	7.3	5.2	58.1	0	0.03	382
4/30/2019	4	7.1	7.4	20.1	139.6	0.02	0.39	421
5/31/2019	5	6.5	7.4	6.7	42.8	0	0.1	377
6/30/2019	9	6.3	6.9	2.3	23.8	0	0.05	126
7/31/2019	5	6	6.8	4.1	1732.9	0	0.04	88
8/31/2019	9	6.1	7	2.2	23.3	0	0.03	140
9/30/2019	6	6.4	7	1.9	6.3	0.03	0.49	120
10/31/2019	17	6.6	7.4	3.5	1732.9	0.02	0.03	233
11/30/2019	7	6.3	7	3.3	42.6	0.02	0.03	155
12/31/2019	7	6.3	6.9	2.8	33.6	0.02	0.11	60
1/31/2020	9	6.5	7.1	5.7	63.1	0.02	0.12	189
2/29/2020	6	6.2	6.9	1.2	5.2	0	0.03	209
3/31/2020	4	6.4	6.9	1.6	5.2	0.03	0.28	107
4/30/2020	5	6.8	7.4	2.2	31.6	0.03	0.39	177
5/31/2020	6	6.3	7	1.1	4.1	0	0.04	59
6/30/2020	8	6.2	7	2.7	83.3	0	0.02	90
7/31/2020	4	6.4	6.9	2.2	14.8	0	0.03	89
8/31/2020	6	6.5	7.1	2.4	11	0.04	0.83	96
9/30/2020	6	6.3	7.1	7.9	46.4	0	0.02	78
10/31/2020	7	6.6	7.3	2.4	7.5	0.03	0.73	176
11/30/2020	5	6.6	7.2	1.7	13.2	0.02	0.19	141
12/31/2020	4	6.6	7.2	1.2	3.1	0.04	0.59	138
1/31/2021	3	7	7.4	1	1	0.12	0.98	245
2/28/2021	4	7.1	7.4	1.2	5.2	0.07	0.63	357
3/31/2021	6	7	7.5	1.2	4.1	0.02	0.62	328
4/30/2021	6	7.1	7.3	4.1	21.6	0.02	0.58	358

## Outfall 001

Parameter	TSS	pH	pH	E. coli	E. coli	TRC	TRC	TKN
	Daily Max	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	SU	SU	MPN/100mL	MPN/100mL	mg/L	mg/L	lb/d
Effluent Limit	50	6	8	126	406	1	1	Report
5/31/2021	6	7.1	7.5	2.1	8.4	0.03	0.83	434
6/30/2021	7	6.6	7.4	2.1	8.5	0.02	0.05	253
7/31/2021	8	6.6	7.2	2.5	7.5	0.04	0.75	183
8/31/2021	8	6.1	7	2.3	50.4	0.05	0.73	135
9/30/2021	13	6.2	7	4.9	31.8	0.03	0.4	101
10/31/2021	12	6.3	7	4.1	17.1	0	0.15	79
11/30/2021	7	6.3	6.8	2.5	5.2	0	0.06	97
12/31/2021	5	6.3	6.8	2	11.1	0	0.03	63
1/31/2022	6	6.1	6.8	1	3	0	0.03	94
2/28/2022	12	6.1	6.9	1.2	3.1	0	0.05	149
3/31/2022	6	6.2	7	3.3	140.1	0	0.11	157
4/30/2022	5	6.3	7	2.7	21.3	0.02	0.56	221
5/31/2022	13	6.2	7	1.5	5.2	0	0.14	156
6/30/2022	15	6.4	7	4.2	201.4	0.05	0.64	139
7/31/2022	9	6.5	7.3	2.9	27.5	0.06	0.74	227
8/31/2022	8	6.3	7.3	3.3	13.4	0.02	0.04	238
9/30/2022	11	6.1	7.3	1.8	11	0.01	0.03	274
10/31/2022	9	7	7.4	2.3	88.2	0	0.04	355
11/30/2022	6	6.5	7.3	3.1	9.7	0	0.04	164
12/31/2022	4	6.7	7.2	1.2	3	0.05	0.33	223
1/31/2023	6	6.9	7.4	2.3	13.5	0.02	0.21	436
2/28/2023	11	7.1	7.4	3.9	22.8	0	0.08	531
3/31/2023	6	7.1	7.4	7.5	84.2	0.05	0.61	437
4/30/2023	6	7	7.3	23.8	121.1	0	0.07	520
5/31/2023	7	7.1	7.3	6	42.6	0	0.08	482
6/30/2023	8	7	7.3	2	7.4	0	0.02	424
7/31/2023	9	6.7	7.1	3.5	48	0	0.03	168
8/31/2023	9	6.5	7.2	6.3	2.7	0.08	0.9	156
9/30/2023	10	6.3	6.8	5.3	26.2	0	0.15	112
10/31/2023	10	6.1	6.9	6.6	21.3	0.01	0.33	129
11/30/2023	7	6.5	7.2	2.9	19.9	0	0.03	428
12/31/2023	5	6.5	7	4.8	19.9	0	0.03	265

## Outfall 001

Parameter	TKN	TKN	TKN	TN	TN	TN	TN
	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max
Units	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
Minimum	5	57	5	163	15	172	15
Maximum	51	589	54	541	52	601	55
Median	17.5	222	20	227.5	24	266	25.5
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/31/2019	5	57	5	172	15	172	15
2/28/2019	18	224	18	362	29	362	29
3/31/2019	35	487	39	428	39	522	NODI: 9
4/30/2019	24	560	32	445	NODI: 9	581	33
5/31/2019	25	464	33	452	NODI: 9	498	NODI: 9
6/30/2019	10	170	14	NODI: 9	25	NODI: 9	29
7/31/2019	8	116	10	NODI: 9	NODI: 9	NODI: 9	26
8/31/2019	14	196	19	282	NODI: 9	NODI: 9	NODI: 9
9/30/2019	11	135	14	NODI: 9	NODI: 9	301	NODI: 9
10/31/2019	22	233	22	361	34	361	34
11/30/2019	13	155	13	346	29	346	29
12/31/2019	6	60	6	205	21	205	21
1/31/2020	17	189	17	323	29	323	29
2/29/2020	20	209	20	377	36	377	36
3/31/2020	9	124	10	NODI: 9	22	297	NODI: 9
4/30/2020	15	283	21	NODI: 9	NODI: 9	NODI: 9	NODI: 9
5/31/2020	6	78	8	199	NODI: 9	NODI: 9	NODI: 9
6/30/2020	11	104	12	192	NODI: 9	220	27
7/31/2020	11	112	14	183	22	NODI: 9	NODI: 9
8/31/2020	13	106	14	183	24	195	26
9/30/2020	11	109	14	163	23	211	NODI: 9
10/31/2020	20	176	20	255	29	255	29
11/30/2020	18	141	18	217	28	217	28
12/31/2020	21	138	21	197	30	197	30
1/31/2021	33	245	33	280	38	280	38
2/28/2021	49	357	49	364	50	364	50
3/31/2021	38	374	44	NODI: 9	39	386	NODI: 9
4/30/2021	33	381	36	364	NODI: 9	387	37

## Outfall 001

Parameter	TKN	TKN	TKN	TN	TN	TN	TN
	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max
Units	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
5/31/2021	44	446	48	NODI: 9	45	457	NODI: 9
6/30/2021	30	411	46	NODI: 9	NODI: 9	438	NODI: 9
7/31/2021	16	281	25	NODI: 9	NODI: 9	NODI: 9	NODI: 9
8/31/2021	14	241	22	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2021	10	136	14	242	24	NODI: 9	27
10/31/2021	8	79	8	202	21	202	21
11/30/2021	9	97	9	265	25	265	25
12/31/2021	8	63	8	200	25	200	25
1/31/2022	11	94	11	240	28	240	28
2/28/2022	19	149	19	267	34	267	34
3/31/2022	14	225	20	NODI: 9	NODI: 9	345	NODI: 9
4/30/2022	17	270	21	NODI: 9	28	NODI: 9	NODI: 9
5/31/2022	14	221	21	NODI: 9	NODI: 9	NODI: 9	NODI: 9
6/30/2022	16	201	22	NODI: 9	NODI: 9	NODI: 9	NODI: 9
7/31/2022	26	284	34	306	NODI: 9	NODI: 9	NODI: 9
8/31/2022	28	323	36	316	36	377	NODI: 9
9/30/2022	28	365	36	NODI: 9	36	NODI: 9	NODI: 9
10/31/2022	38	355	38	401	43	401	43
11/30/2022	18	164	18	264	29	264	29
12/31/2022	23	223	23	281	29	281	29
1/31/2023	40	436	40	458	42	458	42
2/28/2023	51	531	51	541	52	541	52
3/31/2023	39	503	49	NODI: 9	NODI: 9	517	50
4/30/2023	39	569	48	533	40	581	NODI: 9
5/31/2023	41	589	49	NODI: 9	NODI: 9	601	50
6/30/2023	41	489	54	435	NODI: 9	NODI: 9	55
7/31/2023	11	221	18	NODI: 9	15	NODI: 9	22
8/31/2023	13	229	20	NODI: 9	23	342	28
9/30/2023	10	120	11	277	NODI: 9	297	26
10/31/2023	13	129	13	238	24	238	24
11/30/2023	41	428	41	470	45	470	45
12/31/2023	18	265	18	295	20	295	20



## Outfall 001

Parameter	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate	Aluminum	Aluminum
	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Daily Max
Units	lb/d	mg/L	lb/d	mg/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report	Report
Minimum	7	1	7	1	18	18
Maximum	191	17	210	18	150	150
Median	88.5	10	112	12	37.5	37.5
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A
1/31/2019	115	10	115	10	40	40
2/28/2019	137	11	137	11	40	40
3/31/2019	45	4	58	6	40	40
4/30/2019	24	1	27	2	20	20
5/31/2019	74	5	157	10	30	30
6/30/2019	186	15	210	16	50	50
7/31/2019	183	16	193	17	41	51
8/31/2019	142	15	160	17	51	51
9/30/2019	157	14	171	17	37	37
10/31/2019	127	12	127	12	68	68
11/30/2019	191	16	191	16	50	50
12/31/2019	145	15	145	15	27	27
1/31/2020	134	12	134	12	79	100
2/29/2020	167	16	167	16	38	38
3/31/2020	155	13	173	14	33	33
4/30/2020	84	8	123	12	23	23
5/31/2020	140	15	177	18	18	18
6/30/2020	102	13	122	15	37	37
7/31/2020	94	12	108	14	26	26
8/31/2020	87	11	90	13	45	45
9/30/2020	86	12	102	13	35	35
10/31/2020	79	9	79	9	44	44
11/30/2020	76	10	76	10	32	32
12/31/2020	59	9	59	9	94	94
1/31/2021	35	5	35	5	27	27
2/28/2021	7	1	7	1	34	34
3/31/2021	9	1	12	1	41	41
4/30/2021	7	1	12	1	34	34

## Outfall 001

Parameter	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate	Aluminum	Aluminum
	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Daily Max
Units	lb/d	mg/L	lb/d	mg/L	ug/L	ug/L
Effluent Limit	Report	Report	Report	Report	Report	Report
5/31/2021	10	1	11	1	29	29
6/30/2021	58	7	90	12	34	34
7/31/2021	90	8	126	10	23	23
8/31/2021	126	14	160	17	30	30
9/30/2021	142	14	178	15	46	46
10/31/2021	123	13	123	13	42	42
11/30/2021	168	16	168	16	150	150
12/31/2021	137	17	137	17	41	41
1/31/2022	146	17	146	17	88	88
2/28/2022	118	15	118	15	71	71
3/31/2022	139	12	156	14	21	21
4/30/2022	146	11	173	15	35	35
5/31/2022	107	10	163	15	87	87
6/30/2022	87	10	108	12	140	140
7/31/2022	79	9	98	10	65	75
8/31/2022	77	9	119	13	39	39
9/30/2022	75	8	102	9	26	26
10/31/2022	47	5	47	5	28	28
11/30/2022	100	11	100	11	33	33
12/31/2022	58	6	58	6	35	35
1/31/2023	22	2	22	2	32	32
2/28/2023	10	1	10	1	36	36
3/31/2023	11	1	14	1	35	35
4/30/2023	14	1	16	1	40	40
5/31/2023	12	1	16	1	29	29
6/30/2023	11	1	15	1	37	37
7/31/2023	67	4	98	7	39	40
8/31/2023	123	10	148	13	50	50
9/30/2023	165	15	190	16	58	58
10/31/2023	109	11	109	11	110	110
11/30/2023	42	4	42	4	38	38
12/31/2023	29	2	29	2	29	29

## WET Effluent

Parameter	LC50 Acute Ceriodaphnia	LC50 Acute Pimephales	Ammonia	Aluminum	Cadmium	Copper	Lead
	Monthly Ave Min	Monthly Ave Min	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	%	%	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	50	50	Report	Report	Report	Report	Report
Minimum	100	100	6	0.027	0	0.0048	0.00032
Maximum	100	100	26	0.055	0.0005	0.015	0.0005
Median	100	100	12.6	0.044	0.0001	0.011	0.0005
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A
9/30/2019	100	100	26	0.051	0	0.012	0.0005
9/30/2020	100	100	12.6	0.044	0	0.015	0.0005
9/30/2021	100	100	7.2	0.027	0.0001	0.0088	0.00032
9/30/2022	100	100	21	0.055	0.0005	0.011	0.0005
9/30/2023	100	100	6	0.038	0.0005	0.0048	0.0005

## WET Effluent

Parameter	Nickel	Zinc	Hardness
	Daily Max	Daily Max	Daily Max
Units	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report
Minimum	0.0014	0.027	48
Maximum	0.0026	0.056	94
Median	0.0021	0.036	64
No. of Violations	N/A	N/A	N/A
9/30/2019	0.0022	0.053	64
9/30/2020	0.0026	0.056	60
9/30/2021	0.0014	0.033	88
9/30/2022	0.0021	0.036	48
9/30/2023	0.0019	0.027	94

## WET Ambient

Parameter	pH	Ammonia	Aluminum	Cadmium	Copper	Lead	Nickel
	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	S.U.	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
Minimum	7.45	0	0.044	0	0	0	0
Maximum	7.77	0.64	0.33	0	0.0013	0.00033	0.0012
Median	7.49	0.192	0.1115	0	0.00115	0	0
9/30/2019	7.77	0	0.083	0	0.0012	0	0
9/30/2020	7.45	0.64	0.14	0	0.0011	0	0.0012
9/30/2021	7.53	0.31	0.33	0	0.0013	0.00033	0
9/30/2022	7.45	0.074	0.044	0	0	0	0
9/30/2023							

## WET Ambient

Parameter	Zinc	Hardness
	Daily Max	Daily Max
Units	mg/L	mg/L
Effluent Limit	Report	Report
Minimum	0	30
Maximum	0.0045	46
Median	0.00155	42.5
9/30/2019	0.0045	42
9/30/2020	0.0031	30
9/30/2021	0	43
9/30/2022	0	46
9/30/2023		

## Ambient Total Phosphorus

Parameter	Total Phosphorus
Units	mg/L
Site	Station 30-CNT (0.55 miles upstream)
Minimum	0.007
Maximum	0.048
Median	0.026
6/19/1997	0.012
7/23/1997	0.048
6/21/2000	0.007
8/18/2000	0.04

Effluent Phosphorus
2020 Application
Average (12 samples)
2.6 mg/L
Daily Max
4.9 mg/L