

Outfall 001

Parameter	Flow	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5
	Annual Rolling Ave	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	2.37	Report	Report	593	30	890	45	989
Minimum	0.32	0.162	0.213	6	5	10	6	14
Maximum	0.471	0.717	1.925	97	21	184	31	212
Median	0.397	0.403	0.671	29	8	35	11	43
No. of Violations	0	N/A	N/A	0	0	0	0	0
1/31/2019		0.477	1.078	47	12	67	14	74
2/28/2019		0.403	0.697	31	9	39	11	39
3/31/2019		0.468	0.705	29	8	35	10	40
4/30/2019		0.717	1.51	47	8	48	8	60
5/31/2019		0.553	0.834	36	9	51	10	49
6/30/2019		0.367	0.556	34	12	44	15	41
7/31/2019		0.237	0.333	29	14	42	22	43
8/31/2019		0.247	0.353	16	8	22	12	25
9/30/2019		0.252	0.323	15	7	20	8	20
10/31/2019		0.302	0.531	23	9	30	12	43
11/30/2019		0.402	0.736	40	9	107	19	201
12/31/2019		0.544	1.388	30	7	35	9	54
1/31/2020		0.495	0.96	41	10	62	18	69
2/29/2020		0.383	0.829	30	10	35	12	36
3/31/2020		0.495	0.686	30	8	48	12	51
4/30/2020		0.552	0.836	32	7	56	10	65
5/31/2020		0.38	0.671	21	8	26	8	45
6/30/2020		0.268	0.392	18	7	37	12	39
7/31/2020		0.243	0.324	12	5	37	12	15
9/30/2020	0.37	0.174	0.213	15	10	19	14	19
10/31/2020	0.362	0.209	0.348	22	11	26	12	35
11/30/2020	0.351	0.264	0.536	29	12	31	12	54
12/31/2020	0.347	0.507	1.45	34	9	44	12	61
1/31/2021	0.345	0.463	0.706	37	9	52	12	56
2/28/2021	0.34	0.33	0.503	37	12	44	14	50
3/31/2021	0.335	0.432	0.628	36	10	53	14	55
4/30/2021	0.326	0.448	0.688	28	8	46	10	35
5/31/2021	0.327	0.39	0.648	25	8	27	10	34
6/30/2021	0.32	0.228	0.441	19	9	26	12	30
7/31/2021	0.357	0.635	1.415	28	6	32	8	37
8/31/2021	0.375	0.423	0.849	25	6	54	10	61
9/30/2021	0.396	0.426	0.831	22	6	28	13	43

Outfall 001

Parameter	Flow	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5
	Annual Rolling Ave	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	2.37	Report	Report	593	30	890	45	989
10/31/2021	0.408	0.35	1.042	13	5	20	6	20
11/30/2021	0.427	0.497	0.662	30	7	40	10	42
12/31/2021	0.425	0.482	0.588	44	11	62	15	84
1/31/2022	0.423	0.435	0.673	33	9	44	10	56
2/28/2022	0.44	0.534	0.913	27	7	38	9	45
3/31/2022	0.457	0.64	0.92	33	6	46	7	57
4/30/2022	0.465	0.537	0.858	32	7	50	12	64
5/31/2022	0.464	0.382	0.592	26	8	46	10	54
6/30/2022	0.469	0.287	0.519	19	8	24	11	25
7/31/2022	0.431	0.184	0.292	20	11	26	13	33
8/31/2022	0.41	0.162	0.253	6	5	10	8	14
9/30/2022	0.398	0.287	0.412	12	5	16	6	21
10/31/2022	0.394	0.304	0.466	17	6	26	9	29
11/30/2022	0.377	0.292	0.429	14	6	16	7	18
12/31/2022	0.379	0.498	1.587	17	5	28	6	33
1/31/2023	0.388	0.549	0.923	31	7	13	13	51
2/28/2023	0.38	0.441	0.547	25	7	27	7	32
3/31/2023	0.375	0.575	0.799	39	8	42	11	62
4/30/2023	0.378	0.569	0.938	42	8	59	11	63
5/31/2023	0.398	0.624	1.413	97	17	184	18	212
6/30/2023	0.403	0.351	0.425	66	21	104	31	104
7/31/2023	0.432	0.534	0.924	34	6	52	12	62
8/31/2023	0.451	0.385	0.549	23	7	32	9	33
9/30/2023	0.457	0.364	0.48	30	9	49	20	54
10/31/2023	0.459	0.324	0.412	19	7	23	8	29
11/30/2023	0.459	0.299	0.478	20	7	17	8	36
12/31/2023	0.471	0.635	1.925	44	8	63	9	79

Outfall 001

Parameter	BOD5	BOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Minimum	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	50	85	593	30	890	45	989	50
Minimum	6	79	6	3	7	4	8	0
Maximum	35	98.1	31	10	46	14	72	16
Median	12	94	17	4	22	6	26	6
No. of Violations	0	1	0	0	0	0	0	0
1/31/2019	15	94.8	27	7	35	11	44	13
2/28/2019	11	94.9	19	6	21	6	28	8
3/31/2019	11	96.4	18	5	24	6	27	7
4/30/2019	10	92.5	28	5	31	5	48	6
5/31/2019	12	93.3	25	6	37	4	62	15
6/30/2019	16	93.4	22	7	44	12	41	16
7/31/2019	23	93.8	16	8	27	14	28	14
8/31/2019	10	96.8	9	4	14	7	17	6
9/30/2019	9	98.1	9	4	10	4	12	5
10/31/2019	15	95.8	11	4	13	4	16	5
11/30/2019	35	94.5	11	4	50	5	12	4
12/31/2019	15	95.1	19	4	22	4	29	4
1/31/2020	20	92.5	23	5	34	10	38	11
2/29/2020	13	95.1	13	4	19	5	19	6
3/31/2020	13	94	16	4	17	4	18	4
4/30/2020	11	93.9	20	4	24	6	25	7
5/31/2020	17	93.4	14	5	18	5	21	8
6/30/2020	13	94.7	12	5	18	7	20	6
7/31/2020	7	96.1	10	4	18	6	12	5
9/30/2020	14	96	12	8	16	11	22	15
10/31/2020	12	94.6	12	6	16	8	23	9
11/30/2020	13	91.7	12	5	15	6	18	7
12/31/2020	12	89.7	17	4	24	4	26	5
1/31/2021	12	90.2	17	4	24	4	19	4
2/28/2021	14	93.3	17	6	20	6	26	8
3/31/2021	16	91.7	17	5	23	6	29	9
4/30/2021	10	93.5	17	5	22	6	22	7
5/31/2021	10	92.2	14	5	20	6	24	7
6/30/2021	14	95.1	14	6	32	10	36	13
7/31/2021	8	91.9	21	4	32	6	33	4
8/31/2021	12	96.7	19	5	34	6	44	8
9/30/2021	14	94.9	15	4	21	6	28	6

Outfall 001

Parameter	BOD5	BOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Minimum	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	50	85	593	30	890	45	989	50
10/31/2021	7	96.6	13	4	14	4	15	5
11/30/2021	10	92.4	17	4	20	4	22	4
12/31/2021	20	85.9	19	5	27	6	33	8
1/31/2022	12	91.2	21	6	31	8	37	10
2/28/2022	8	92.6	17	4	24	4	30	5
3/31/2022	8	90.3	25	4	28	6	33	7
4/30/2022	15	90.8	18	4	26	4	29	4
5/31/2022	11	93.8	13	4	18	4	20	5
6/30/2022	12	92.7	10	4	12	5	12	5
7/31/2022	14	94.9	13	7	22	11	29	12
8/31/2022	12	97.6	6	4	7	4	8	< 5
9/30/2022	6	97.3	10	4	12	4	14	4
10/31/2022	10	96	11	4	14	4	15	4
11/30/2022	7	94.6	9	4	12	4	14	4
12/31/2022	6	95.6	14	4	19	4	22	4
1/31/2023	13	92.5	18	4	19	4	29	6
2/28/2023	11	94.7	15	4	22	4	17	5
3/31/2023	12	90.7	20	4	25	4	28	4
4/30/2023	9	88.4	23	4	32	4	35	6
5/31/2023	22	79	29	6	38	4	72	13
6/30/2023	31	87.3	31	10	46	14	50	15
7/31/2023	9	94.3	21	4	34	7	39	5
8/31/2023	11	94.4	19	6	21	7	24	8
9/30/2023	15	94.4	21	7	27	8	36	9
10/31/2023	10	95.9	13	4	18	6	23	7
11/30/2023	9	96.2	12	4	10	4	22	6
12/31/2023	11	88.7	20	3	38	5	55	5

Outfall 001

Parameter	TSS	pH	pH	E. coli	E. coli	TRC	TRC	TKN
	Minimum	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	%	SU	SU	CFU/100mL	CFU/100mL	mg/L	mg/L	mg/L
Effluent Limit	85	6.5	8	126	406	1	1	Report
Minimum	83.8	6.35	6.78	0	1	0.33	0.41	1.3
Maximum	98.8	7.12	7.38	22.3	2419.6	0.65	0.98	32.5
Median	95.2	6.74	7.02	1	7.5	0.47	0.83	10
No. of Violations	1	4	0	0	2	0	0	N/A
1/31/2019	95.2	6.64	7.04	< 2.6	22.8	0.43	0.73	
2/28/2019	95.5	6.85	7.05	< 1.9	7.5	0.42	0.61	
3/31/2019	97.7	6.76	7.07	< 1.2	5.2	0.43	0.59	
4/30/2019	94.3	6.7	6.89	< 2.6	18.9	0.45	0.7	
5/31/2019	93.7	6.76	6.97	< 3.5	26.9	0.38	0.86	
6/30/2019	95.7	6.86	7.13	22.3	37.3	0.41	0.57	
7/31/2019	95.6	7	7.28	18.7	2419.6	0.43	0.94	
8/31/2019	97.9	6.74	7.09	< 1.1	2	0.35	0.93	
9/30/2019	98.8	6.65	6.95	< 1.1	2	0.52	0.87	
10/31/2019	97.9	6.59	6.85	< 1.1	3.1	0.51	0.87	
11/30/2019	96.7	6.54	6.78	< 1	1	0.65	0.94	
12/31/2019	95.8	6.44	6.89	1	3	0.57	0.83	
1/31/2020	94.2	6.67	6.9	2.9	18.7	0.45	0.75	
2/29/2020	96.1	6.8	7.03	4.4	8.5	0.47	0.79	
3/31/2020	94.3	6.74	6.95	5.7	10.9	0.48	0.77	
4/30/2020	95.6	6.75	6.93	2.3	7.5	0.46	0.66	
5/31/2020	97.2	6.68	6.92	4	7.5	0.39	0.63	
6/30/2020	96.4	6.51	6.79	3.3	7.3	0.44	0.82	
7/31/2020	97.5	6.6	6.88	3.7	1413.6	0.47	0.98	
9/30/2020	96.9	6.79	7.07			0.39	0.71	10
10/31/2020	96.3	6.74	6.9			0.44	0.86	6.4
11/30/2020	96.4	6.83	6.99			0.54	0.95	8.4
12/31/2020	92.3	6.66	6.95			0.51	0.98	10
1/31/2021	91.7	6.74	7.06			0.38	0.51	10
2/28/2021	94.1	6.91	7.08			0.33	0.41	22
3/31/2021	93.3	6.89	7.07			0.46	0.65	22
4/30/2021	93	6.87	7.07			0.39	0.59	21
5/31/2021	86.5	6.9	7.2			0.47	0.83	23.3
6/30/2021	95	6.88	7.11			0.47	0.97	24.6
7/31/2021	90.2	6.35	6.94			0.62	0.93	3
8/31/2021	95.4	6.54	6.95			0.49	0.86	2.6
9/30/2021	94	6.52	6.85			0.55	0.9	4.4

Outfall 001

Parameter	TSS	pH	pH	E. coli	E. coli	TRC	TRC	TKN
	Minimum	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	%	SU	SU	CFU/100mL	CFU/100mL	mg/L	mg/L	mg/L
Effluent Limit	85	6.5	8	126	406	1	1	Report
10/31/2021	95.2	6.67	6.9			0.46	0.73	5.6
11/30/2021	91.7	6.61	6.91			0.56	0.81	1.5
12/31/2021	88.1	6.84	7.02			0.52	0.66	13
1/31/2022	86	6.93	7.18			0.47	0.7	11
2/28/2022	94.3	6.82	7.15			0.58	0.91	20
3/31/2022	89.2	6.84	7.03			0.55	0.87	14
4/30/2022	90.7	6.51	6.98			0.49	0.63	14.3
5/31/2022	95.4	6.87	7.07			0.46	0.78	22.6
6/30/2022	96.6	6.94	7.18			0.46	0.76	25.5
7/31/2022	95.7	6.6	6.98			0.46	0.93	12.9
8/31/2022	97.1	6.63	6.87			0.4	0.96	3.5
9/30/2022	97.2	6.36	6.89			0.51	0.86	3.3
10/31/2022	94.2	6.51	7.19			0.49	0.88	3
11/30/2022	94.4	6.46	7.1			0.53	0.76	2.5
12/31/2022	95.4	6.5	7.35			0.62	0.95	1.3
1/31/2023	93.1	6.7	7			0.54	0.88	12
2/28/2023	96.6	6.88	7.14			0.63	0.8	17
3/31/2023	93.1	6.77	7.08			0.55	0.84	21
4/30/2023	89.2	6.8	7.1			0.54	0.93	15.5
5/31/2023	83.8	6.87	7.2			0.47	0.8	19
6/30/2023	89.8	7.12	7.38			0.5	0.9	32.5
7/31/2023	93.4	6.69	7.17			0.43	0.92	9.5
8/31/2023	91.7	6.67	6.93			0.39	0.71	3.2
9/30/2023	93.6	6.67	6.89			0.56	0.9	3.7
10/31/2023	95.5	6.72	6.89			0.51	0.77	5.5
11/30/2023	97.5	6.76	7.13			0.63	0.87	5.9
12/31/2023	96.6	6.61	7			0.58	0.89	9.5

Outfall 001

Parameter	TKN	TN	TN	TN	Nitrite+Nitrate	Nitrite+Nitrate	TP
	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	lb/d	mg/L	mg/L	mg/L	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
Minimum	1.3	6	2.4	2.4	0	0	5
Maximum	38	105	32.5	38	2	3	10
Median	11.5	40.5	10.74	13.81	0.625	0.68	7
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/31/2019							
2/28/2019							
3/31/2019							
4/30/2019							7
5/31/2019							10
6/30/2019							7
7/31/2019							8
8/31/2019							6
9/30/2019							8
10/31/2019							8
11/30/2019							
12/31/2019							
1/31/2020							
2/29/2020							
3/31/2020							
4/30/2020							5
5/31/2020							7
6/30/2020							7
7/31/2020							10
9/30/2020	14	15	10	15	0.7	1	
10/31/2020	6.8	12	6.8	7.9	0.46	1.1	
11/30/2020	8.4	17	9.09	9.09	0.69	0.69	
12/31/2020	10	40	10.78	10.78	0.78	0.78	
1/31/2021	10	41	10.7	10.7	0.66	0.66	
2/28/2021	22	69	22	22	< .5	< .5	
3/31/2021	22	93	22	22	< .5	< .5	
4/30/2021	22	78	21	22	< .5	< .5	
5/31/2021	28	76	23.3	28	< .5	< .5	
6/30/2021	28	47	24.9	28	0.63	0.66	
7/31/2021	6.1	26	4.9	7.7	1.9	3	
8/31/2021	4.4	12	3.54	4.9	1.13	1.6	
9/30/2021	4.8	16	4.57	5.07	< .67	0.67	

Outfall 001

Parameter	TKN	TN	TN	TN	Nitrite+Nitrate	Nitrite+Nitrate	TP
	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	lb/d	mg/L	mg/L	mg/L	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
10/31/2021	11	20	7	12.7	1.4	1.7	
11/30/2021	1.5	18	3.3	3.3	1.8	1.8	
12/31/2021	13	52	13.62	13.62	0.62	0.62	
1/31/2022	11	62	11	11	< .5	< .5	
2/28/2022	20	73	20	20	< .5	< .5	
3/31/2022	14	105	14	14	< .5	< .5	
4/30/2022	15	67	14.3	15	< .5	< .5	
5/31/2022	27	69	22.6	27	< .5	< .5	
6/30/2022	33	58	25.6	33	< .52	0.52	
7/31/2022	19	24	12.9	19	< .5	< .5	
8/31/2022	4.9	6	4.6	5.7	1.11	1.4	
9/30/2022	3.9	13	4.6	5	1.3	1.6	
10/31/2022	3.1	13	4.7	14	1.68	1.8	
11/30/2022	2.5	13	4.5	4.5	2	2	
12/31/2022	1.3	8	2.4	2.4	1.1	1.1	
1/31/2023	12	45	12	12	< .5	< .5	
2/28/2023	17	61	17	17	< .5	< .5	
3/31/2023	21	73	21	21	< .5	< .5	
4/30/2023	21	80	15.5	21	< .5	< .5	
5/31/2023	28	92	19.2	28	0.18	0.89	
6/30/2023	38	104	32.5	38	< .5	< .5	
7/31/2023	21	63	10.2	21.6	0.92	1.5	
8/31/2023	3.5	15	4.3	4.6	1.13	1.2	
9/30/2023	4.9	15	4.7	18	1	1.6	
10/31/2023	7	19	6.2	7.9	0.69	0.87	
11/30/2023	5.9	18	7.2	7.2	1.3	1.3	
12/31/2023	9.5	32	10.4	10.4	0.92	0.92	

Outfall 001

Parameter	TP	TP	TP	E. coli	E. coli
	Monthly Ave	Daily Max	Daily Max	Monthly Geometric Mean	Daily Max
Units	mg/L	lb/d	mg/L	#/100mL	#/100mL
Effluent Limit	Report	Report	Report	126	406
Minimum	0	5	1.1	1	1
Maximum	3.9	10	3.9	55.3	387.3
Median	1.8	7	2.9	4.9	38.35
No. of Violations	N/A	N/A	N/A	0	0
1/31/2019					
2/28/2019					
3/31/2019					
4/30/2019	1.1	7	1.1		
5/31/2019	1.8	10	1.8		
6/30/2019	1.5	7	1.5		
7/31/2019	3.1	8	3.1		
8/31/2019	3.2	6	3.2		
9/30/2019	< 3.2	8	3.2		
10/31/2019	3	9	3.8		
11/30/2019					
12/31/2019					
1/31/2020					
2/29/2020					
3/31/2020					
4/30/2020	1.1	5	1.1		
5/31/2020	1.8	7	1.8		
6/30/2020	2.9	7	2.9		
7/31/2020	3.9	10	3.9		
9/30/2020				1	1
10/31/2020				2.2	124.3
11/30/2020				5.1	209.8
12/31/2020				1.4	74.8
1/31/2021				2.9	18.7
2/28/2021				5.7	36.9
3/31/2021				1.4	18.1
4/30/2021				2.2	14.6
5/31/2021				3.8	63.7
6/30/2021				35.5	143.9
7/31/2021				3	24.3
8/31/2021				3.4	30.1
9/30/2021				2.3	7.5

Outfall 001

Parameter	TP	TP	TP	E. coli	E. coli
	Monthly Ave	Daily Max	Daily Max	Monthly Geometric Mean	Daily Max
Units	mg/L	lb/d	mg/L	#/100mL	#/100mL
Effluent Limit	Report	Report	Report	126	406
10/31/2021				1.4	7.5
11/30/2021				13.5	38.3
12/31/2021				20.7	38.4
1/31/2022				23.8	31.5
2/28/2022				25.9	50.4
3/31/2022				5.2	16.1
4/30/2022				2.3	11.9
5/31/2022				13.5	70.3
6/30/2022				55.3	90.8
7/31/2022				20.9	162.4
8/31/2022				1	1
9/30/2022				1.1	2
10/31/2022				2.1	9.7
11/30/2022				54.5	151.5
12/31/2022				7	26.9
1/31/2023				13	184.2
2/28/2023				2.9	43.1
3/31/2023				4.7	63.3
4/30/2023				10.2	88.8
5/31/2023				13.9	387.3
6/30/2023				40.4	161.6
7/31/2023				17	50.4
8/31/2023				6.2	54.5
9/30/2023				3.1	10.9
10/31/2023				3.4	12.1
11/30/2023				3.8	29.2
12/31/2023				24.9	45.2

WET Effluent

Parameter	LC50 Acute Ceriodaphnia	LC50 Acute Pimephales	Ammonia	Aluminum	Cadmium	Copper	Lead
	Monthly Ave Min	Monthly Ave Min	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	%	%	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	50	50	Report	Report	Report	Report	Report
Minimum	100	100	0.39	0.013	Non-Detect	0.0031	0
Maximum	100	100	4.3	0.017	Non-Detect	0.0062	0.00072
Median	100	100	0.39	0.013	Non-Detect	0.0031	Non-Detect
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A
9/30/2019	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R
9/30/2020	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2021	100	100	0.39	0.016	< .0005	0.0031	< .0005
9/30/2022	100	100	3.5	0.017	< .0005	0.0062	0.00072
9/30/2023	100	100	4.3	0.013	< .0005	0.0038	< .0005

WET Effluent

Parameter	Nickel	Zinc	Hardness	TOC
	Daily Max	Daily Max	Daily Max	Daily Max
Units	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report
Minimum	0	0.031	43	3.6
Maximum	0.0013	0.06	57	11
Median	Non-Detect	0.031	43	3.6
No. of Violations	N/A	N/A	N/A	N/A
9/30/2019	NODI: R	NODI: R	NODI: R	NODI: R
9/30/2020	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2021	0.0013	0.047	57	3.6
9/30/2022	0.0012	0.06	43	10
9/30/2023	< .001	0.031	54	11

WET Ambient

Parameter	pH	Ammonia	Aluminum	Cadmium	Copper	Lead	Nickel	Zinc
	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	SU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
Minimum	6.2	0.058	0.016	Non-Detect	0	0	No Data	0
Maximum	6.64	0.11	0.22	Non-Detect	0.0013	0.00054	No Data	0.047
Median	6.2	0.058	0.016	Non-Detect	Non-Detect	Non-Detect	No Data	Non-Detect
9/30/2019	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R	NODI: R
9/30/2020	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2021	6.64	0.058	0.016	< .0005	0.0013	< .0005	< .001	0.047
9/30/2022	6.59	0.11	0.04	< .0005	< .001	< .0005	< .001	< .005
9/30/2023	6.2	0.072	0.22	< .0005	< .001	0.00054	< .001	< .005

WET Ambient

Parameter	Hardness	TOC	DOC	Temperature
	Daily Max	Daily Max	Daily Max	Daily Max
Units	mg/L	mg/L	mg/L	deg C
Effluent Limit	Report	Report	Report	Report
Minimum	11	4.3	3.5	21
Maximum	15	8.3	7.9	27
Median	11	4.3	3.5	21
9/30/2019	NODI: R	NODI: R	NODI: R	NODI: R
9/30/2020	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2021	11	8.3	7.9	21
9/30/2022	15	4.3	3.5	27
9/30/2023	11	8.2	7.9	23

Ambient Phosphorus

Parameter	Total Phosphorus
Units	mg/L
Site	Station 28A-MER (500 ft upstream)
Minimum	0.0086
Maximum	0.017
Median	0.0128
7/27/2010	0.031
9/21/2010	0.017
5/17/2012	0.0086