

## Outfall 001

Parameter	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5	BOD5
	Monthly Ave	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	%	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	85	796	30	1194	45	1327
Minimum	0.7663	1.0299	92	26	4	30	4	32
Maximum	2.4304	3.9599	99	238	16	400	20	407
Median	1.31085	1.89615	98	60.5	5	78	6	85.5
No. of Violations	N/A	N/A	0	0	0	0	0	0
1/31/2019	1.5523	2.909	98	115	9	130	12	139
2/28/2019	1.4745	2.2038	97	96	8	117	9	118
3/31/2019	1.5459	2.1057	97	120	9	151	11	160
4/30/2019	2.4304	3.3188	92	238	11	400	15	407
5/31/2019	2.2092	2.5664	96	210	11	268	13	281
6/30/2019	2.1059	2.7579	97	105	6	239	13	138
7/31/2019	1.4482	1.8479	96	126	10	148	12	151
8/31/2019	1.0361	1.4148	96	146	16	172	20	189
9/30/2019	0.9606	1.3348	97	79	9	128	14	135
10/31/2019	1.1285	1.9669	98	56	6	60	7	71
11/30/2019	1.2564	1.688	98	71	7	86	8	95
12/31/2019	1.3342	1.9049	99	60	5	64	6	72
1/31/2020	1.4146	1.972	98	78	7	112	8	124
2/29/2020	1.2174	1.9122	97	95	10	142	14	144
3/31/2020	1.6264	1.8933	96	116	9	148	12	164
4/30/2020	1.8912	2.2527	97	107	7	136	8	152
5/31/2020	1.6444	2.3069	97	85	6	136	8	102
6/30/2020	1.1549	1.5851	99	46	4	63	6	79
7/31/2020	1.1096	1.5483	99	36	4	63	6	52
8/31/2020	1.0052	1.2206	98	65	7	91	10	102
9/30/2020	0.9428	1.4111	99	42	5	50	6	70
10/31/2020	1.1183	1.7497	99	35	4	44	4	44
11/30/2020	1.0723	1.4209	98	54	6	54	6	60
12/31/2020	1.3112	2.116	98	64	6	104	8	114
1/31/2021	1.1781	1.3572	97	85	8	129	13	132
2/28/2021	0.959	1.2013	99	34	4	42	5	44
3/31/2021	1.3232	2.1436	99	44	4	68	4	72
4/30/2021	1.6438	2.0668	99	49	4	68	4	58
5/31/2021	1.5023	2.0067	98	81	6	114	8	131
6/30/2021	1.0734	1.3005	98	56	6	74	8	87
7/31/2021	1.6373	3.0416	98	70	5	100	4	112
8/31/2021	1.4116	2.5521	98	61	5	102	8	116

## Outfall 001

Parameter	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5	BOD5
	Monthly Ave	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	%	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	85	796	30	1194	45	1327
9/30/2021	1.102	1.415	99	33	4	50	6	56
10/31/2021	1.1184	1.8073	99	48	5	69	8	71
11/30/2021	1.3815	1.6884	99	47	4	54	4	55
12/31/2021	1.3146	1.5245	98	54	5	73	6	73
1/31/2022	1.1926	1.5859	97	68	7	85	10	90
2/28/2022	1.2294	2.104	98	64	7	82	8	88
3/31/2022	1.6622	2.2764	98	59	4	68	5	69
4/30/2022	1.8029	2.1151	98	64	4	78	5	84
5/31/2022	1.514	1.7486	98	67	5	92	8	108
6/30/2022	1.0924	1.5836	98	45	5	82	8	91
7/31/2022	0.7663	1.0299	99	34	5	46	6	43
8/31/2022	0.8306	1.1211	99	26	4	30	4	32
9/30/2022	0.8715	1.2097	99	37	4	52	6	56
10/31/2022	0.9087	1.5334	98	48	6	64	9	69
11/30/2022	0.9649	1.3658	99	36	4	46	6	53
12/31/2022	1.2228	2.3	98	41	4	42	4	45
1/31/2023	1.469	2.151	99	42	4	51	4	59
2/28/2023	1.3105	1.4904	98	46	4	60	6	64
3/31/2023	1.4999	1.899	98	57	5	67	5	67
4/30/2023	1.7209	2.0197	98	73	5	86	6	88
5/31/2023	1.5503	2.3692	98	67	5	118	6	127
6/30/2023	1.2327	1.9325	99	48	5	58	6	61
7/31/2023	2.208	3.9599	98	85	4	152	6	165
8/31/2023	1.5866	2.0049	97	65	5	78	6	83
9/30/2023	1.2074	1.3943	98	49	5	59	6	65
10/31/2023	1.2422	1.5559	98	46	4	56	6	60
11/30/2023	1.2805	1.6986	98	58	5	75	6	79
12/31/2023	1.8392	2.7801	97	106	6	138	8	156

## Outfall 001

Parameter	BOD5	TSS	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	50	85	796	30	1194	45	1327	50
Minimum	4	96	14	2	18	2	21	3
Maximum	21	100	100	8	146	12	170	13
Median	7	99	44	4	60	6	70.5	6
No. of Violations	0	0	0	0	0	0	0	0
1/31/2019	12	98	65	5	70	6	78	6
2/28/2019	9	98	55	5	72	6	79	6
3/31/2019	11	98	61	5	72	6	80	7
4/30/2019	15	98	88	4	110	5	136	5
5/31/2019	14	98	100	5	146	8	147	8
6/30/2019	8	99	62	4	146	8	86	5
7/31/2019	12	98	61	5	81	7	98	10
8/31/2019	21	99	42	5	58	6	83	7
9/30/2019	14	99	32	4	42	5	53	6
10/31/2019	7	99	46	5	54	6	69	7
11/30/2019	9	99	36	4	54	4	46	4
12/31/2019	6	99	41	4	50	4	58	5
1/31/2020	10	99	46	4	55	3	62	5
2/29/2020	14	98	50	5	66	6	72	7
3/31/2020	13	96	98	8	146	12	170	13
4/30/2020	9	98	74	5	95	6	120	8
5/31/2020	7	98	42	3	86	6	86	5
6/30/2020	6	99	27	3	50	6	69	8
7/31/2020	5	99	21	3	44	4	32	4
8/31/2020	10	98	47	5	95	10	98	11
9/30/2020	7	99	29	4	38	6	59	9
10/31/2020	5	99	24	3	32	4	33	4
11/30/2020	6	99	33	4	36	4	41	5
12/31/2020	9	98	45	4	66	6	76	6
1/31/2021	13	98	45	5	58	6	63	6
2/28/2021	5	99	17	2	18	2	21	3
3/31/2021	5	99	30	3	52	3	54	4
4/30/2021	4	99	31	2	52	3	42	3
5/31/2021	9	99	38	3	40	4	49	5
6/30/2021	9	99	35	4	51	6	56	6
7/31/2021	7	98	62	5	110	6	112	7
8/31/2021	8	99	47	4	73	4	77	5

## Outfall 001

Parameter	BOD5	TSS	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	50	85	796	30	1194	45	1327	50
9/30/2021	7	99	30	4	58	7	60	7
10/31/2021	8	99	44	5	64	8	72	8
11/30/2021	5	99	29	2	42	3	42	3
12/31/2021	6	98	43	4	48	5	52	5
1/31/2022	10	98	60	6	71	8	81	9
2/28/2022	8	98	53	5	78	6	101	8
3/31/2022	5	97	63	5	78	5	87	6
4/30/2022	5	99	46	3	72	4	60	4
5/31/2022	8	99	46	4	70	6	79	6
6/30/2022	9	98	54	6	64	9	79	9
7/31/2022	6	98	45	7	52	8	62	11
8/31/2022	4	100	14	2	29	4	24	3
9/30/2022	7	99	41	5	54	7	75	8
10/31/2022	10	99	42	6	62	10	72	10
11/30/2022	6	99	26	3	30	4	34	4
12/31/2022	5	99	27	3	32	4	39	4
1/31/2023	5	99	25	2	34	3	38	3
2/28/2023	6	99	33	3	41	4	50	5
3/31/2023	5	99	44	4	75	5	76	5
4/30/2023	6	98	63	4	93	6	108	7
5/31/2023	7	99	44	3	64	4	72	5
6/30/2023	6	99	39	4	49	5	54	6
7/31/2023	6	99	64	4	108	6	162	7
8/31/2023	6	98	66	5	108	8	110	8
9/30/2023	6	99	32	3	44	4	45	4
10/31/2023	7	99	40	4	62	6	64	6
11/30/2023	6	98	41	4	49	5	57	5
12/31/2023	8	98	62	4	84	4	112	5

## Outfall 001

Parameter	pH	pH	TRC	TRC	TKN	TKN	TKN	TKN
	Minimum	Maximum	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max
Units	SU	SU	mg/L	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	6.5	8	1	1	Report	Report	Report	Report
Minimum	6.7	7.1	0.33	0.97	9	1	9	1
Maximum	7.2	7.8	0.94	1	119	10	219	15
Median	7	7.3	0.88	0.99	20	2	27	2
No. of Violations	0	0	0	0	N/A	N/A	N/A	N/A
1/31/2019	6.7	7.3	0.93	1	42	4	42	4
2/28/2019	6.9	7.2	0.88	1	31	2	31	2
3/31/2019	7	7.3	0.88	0.99	26	2	32	3
4/30/2019	6.7	7.1	0.8	1	26	1	33	2
5/31/2019	6.8	7.1	0.84	1	31	2	38	3
6/30/2019	6.8	7.1	0.82	0.97	19	1	29	2
7/31/2019	6.8	7.3	0.85	0.99	28	3	43	4
8/31/2019	6.9	7.2	0.87	0.98	13	2	16	2
9/30/2019	6.9	7.3	0.87	0.99	18	2	27	3
10/31/2019	7	7.4	0.93	1	18	2	18	2
11/30/2019	7	7.3	0.88	0.98	12	1	12	1
12/31/2019	6.9	7.3	0.89	0.99	14	1	14	1
1/31/2020	6.8	7.3	0.94	0.99	16	2	16	2
2/29/2020	6.9	7.7	0.9	0.99	36	4	36	4
3/31/2020	7.1	7.4	0.36	0.99	39	3	43	4
4/30/2020	6.8	7.5	0.33	0.99	42	3	77	5
5/31/2020	6.7	7.4	0.88	0.99	21	2	25	2
6/30/2020	7	7.4	0.88	0.99	12	1	18	2
7/31/2020	6.9	7.2	0.92	1	15	2	16	2
8/31/2020	7	7.3	0.83	1	30	3	82	8
9/30/2020	7	7.3	0.84	0.99	11	2	12	2
10/31/2020	7	7.3	0.86	1	9	1	9	1
11/30/2020	6.9	7.7	0.77	0.99	9	1	9	1
12/31/2020	6.8	7.3	0.9	1	16	2	16	2
1/31/2021	6.9	7.3	0.93	0.99	21	2	21	2
2/28/2021	7	7.3	0.9	0.99	12	1.43	12	1.43
3/31/2021	6.9	7.4	0.86	0.99	20	2	29	3
4/30/2021	6.9	7.2	0.86	0.99	18	2	23	2
5/31/2021	7	7.3	0.83	0.98	16	1	18	2
6/30/2021	7.1	7.5	0.91	0.99	13	2	15	2
7/31/2021	7.1	7.6	0.88	1	20	2	28	2
8/31/2021	6.9	7.3	0.88	1	18	2	32	2

## Outfall 001

Parameter	pH	pH	TRC	TRC	TKN	TKN	TKN	TKN
	Minimum	Maximum	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max
Units	SU	SU	mg/L	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	6.5	8	1	1	Report	Report	Report	Report
9/30/2021	7	7.3	0.87	1	18	2	41	5
10/31/2021	7.1	7.6	0.91	1	13	2	16	2
11/30/2021	7.1	7.3	0.9	0.99	16	2	16	2
12/31/2021	7	7.4	0.92	1	10	1	10	1
1/31/2022	6.8	7.2	0.92	0.99	25	2	25	2
2/28/2022	6.8	7.4	0.89	1	25	3	25	3
3/31/2022	6.8	7.1	0.85	0.99	24	2	30	3
4/30/2022	6.9	7.5	0.72	0.99	32	2	47	3
5/31/2022	7	7.5	0.86	1	51	4	125	9
6/30/2022	7.1	7.5	0.91	0.98	20	2	27	3
7/31/2022	6.9	7.8	0.91	1	14	2	18	2.4
8/31/2022	7	7.3	0.89	1	12	2	17	2
9/30/2022	6.9	7.1	0.89	1	13	2	17	2
10/31/2022	6.9	7.4	0.89	0.99	16	2	16	2
11/30/2022	7	7.4	0.88	0.99	15	2	15	2
12/31/2022	7	7.4	0.91	1	19	2	19	2
1/31/2023	7	7.2	0.89	1	31	2	31	2
2/28/2023	7	7.3	0.81	0.99	38	4	38	4
3/31/2023	7	7.5	0.44	0.99	54	5	76	8
4/30/2023	7.1	7.4	0.65	0.99	73	5	217	15
5/31/2023	7	7.5	0.79	0.97	119	10	219	15
6/30/2023	7	7.4	0.85	0.98	17	2	20	2
7/31/2023	7	7.2	0.84	1	31	2	64	3
8/31/2023	7	7.2	0.9	1	26	2	30	3
9/30/2023	7	7.3	0.91	1	20	2	30	3
10/31/2023	7.1	7.3	0.85	0.97	30	3	30	3
11/30/2023	7.2	7.4	0.91	1	37	4	37	4
12/31/2023	7	7.3	0.88	1	44	4	44	4

## Outfall 001

Parameter	TN	TN	TN	TN	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate
	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max
Units	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
Minimum	67	8	67	8	49	6	54
Maximum	199	17	366	25	180	14	227
Median	115.5	11	132.5	12	89	9	103.5
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1/31/2019	162	13	162	13	120	10	120
2/28/2019	155	12	155	12	124	9	124
3/31/2019	111	10	131	12	85	8	100
4/30/2019	156	8	187	10	130	7	161
5/31/2019	178	11	231	14	147	9	196
6/30/2019	199	12	256	16	180	11	227
7/31/2019	127	12	172	17	105	10	146
8/31/2019	86	11	90	12	72	9	75
9/30/2019	106	13	154	14	89	11	126
10/31/2019	113	15	113	15	96	12	96
11/30/2019	124	13	124	13	112	12	112
12/31/2019	139	14	139	14	125	12	125
1/31/2020	136	13	136	13	120	12	120
2/29/2020	139	14	139	14	103	11	103
3/31/2020	133	10	144	11	95	7	108
4/30/2020	165	12	202	14	123	9	149
5/31/2020	172	13	238	16	151	12	215
6/30/2020	89	11	96	12	78	10	86
7/31/2020	102	12	125	13	87	10	109
8/31/2020	105	13	186	18	74	9	104
9/30/2020	73	10	74	11	62	9	64
10/31/2020	67	9	67	9	57	8	57
11/30/2020	85	10	85	10	75	9	75
12/31/2020	89	8	89	8	73	7	73
1/31/2021	151	17	151	17	130	14	130
2/28/2021	101	12	101	12	89	11	89
3/31/2021	95	9	112	11	75	7	83
4/30/2021	129	10	153	12	111	9	136
5/31/2021	104	9	118	10	88	7	102
6/30/2021	69	9	75	10	56	7	62
7/31/2021	115	9	152	9	94	7	130
8/31/2021	89	8	127	10	71	7	112

## Outfall 001

Parameter	TN	TN	TN	TN	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate
	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max
Units	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
9/30/2021	67	8	85	10	49	6	54
10/31/2021	128	11	183	12	115	9	174
11/30/2021	111	11	111	11	95	9	95
12/31/2021	93	10	93	10	83	9	83
1/31/2022	135	11	135	11	110	9	110
2/28/2022	88	11	88	11	63	8	63
3/31/2022	115	9	144	10	91	7	121
4/30/2022	121	8	140	10	89	6	99
5/31/2022	130	10	206	14	79	6	82
6/30/2022	105	11	146	14	85	9	127
7/31/2022	83	12	110.1	12.8	69	10	95
8/31/2022	76	11	100	12	64	9	84
9/30/2022	77	11	92	12	64	9	75
10/31/2022	74	10	74	10	58	8	58
11/30/2022	83	10	83	10	68	8	68
12/31/2022	123	13	123	13	104	11	104
1/31/2023	145	11	145	11	114	9	114
2/28/2023	110	10	110	10	71	7	71
3/31/2023	141	12	164	16	87	7	117
4/30/2023	177	12	366	25	119	8	150
5/31/2023	195	16	318	21	76	6	99
6/30/2023	82	9	99	11	65	7	84
7/31/2023	164	10	257	11	133	8	193
8/31/2023	150	12	178	13	124	10	148
9/30/2023	116	12	128	13	96	10	98
10/31/2023	134	13	134	13	104	10	104
11/30/2023	117	12	117	12	80	8	80
12/31/2023	123	11	123	11	79	7	79



## Outfall 001

Parameter	Nitrite+Nitrate	E. coli	E. coli
	Daily Max	Monthly Geometric Mean	Daily Max
Units	mg/L	CFU/100mL	CFU/100mL
Effluent Limit	Report	126	406
Minimum	6	1.3	3.1
Maximum	14	12.7	2419.6
Median	9.5	4.05	17.8
No. of Violations	N/A	0	2
1/31/2019	10	8.5	25.9
2/28/2019	9	7.1	25.6
3/31/2019	10	7.3	42.8
4/30/2019	9	5.6	25
5/31/2019	12	2.4	16
6/30/2019	14	5.3	10.9
7/31/2019	14	4.2	56.1
8/31/2019	10	3.6	12.2
9/30/2019	12	6.5	35.5
10/31/2019	12	3.8	22.6
11/30/2019	12	2.6	13.5
12/31/2019	12	6.1	16.1
1/31/2020	12	8.1	42
2/29/2020	11	1.9	11
3/31/2020	8	12.7	2419.6
4/30/2020	12	5.5	27.9
5/31/2020	14	7.4	30.5
6/30/2020	11	1.7	8.5
7/31/2020	12	1.4	3.1
8/31/2020	10	2.1	6.3
9/30/2020	9	4.4	13.4
10/31/2020	8	4.5	18.1
11/30/2020	9	9.9	224.7
12/31/2020	7	2.7	9.7
1/31/2021	14	4.1	14.5
2/28/2021	11	3.1	172.5
3/31/2021	9	8.1	65.7
4/30/2021	11	5.1	37.9
5/31/2021	8	6.3	579.4
6/30/2021	8	2.1	6.3
7/31/2021	8	4	8.5
8/31/2021	9	4.6	22.6

## Outfall 001

Parameter	Nitrite+Nitrate	E. coli	E. coli
	Daily Max	Monthly Geometric Mean	Daily Max
Units	mg/L	CFU/100mL	CFU/100mL
Effluent Limit	Report	126	406
9/30/2021	6	2.1	28.8
10/31/2021	12	4.6	22.6
11/30/2021	9	1.7	5.2
12/31/2021	9	3.7	32.3
1/31/2022	9	8.7	38.9
2/28/2022	8	5.5	32.3
3/31/2022	8	7.1	29.5
4/30/2022	7	8	141.4
5/31/2022	7	2.6	10.9
6/30/2022	12	2.5	93.3
7/31/2022	11	2.3	6.3
8/31/2022	10	1.4	3.1
9/30/2022	10	2.9	9.8
10/31/2022	8	6.2	204.6
11/30/2022	8	2	5.2
12/31/2022	11	2.1	11
1/31/2023	9	2.2	10.8
2/28/2023	7	3.3	135.4
3/31/2023	8	1.3	11
4/30/2023	10	4.8	29.5
5/31/2023	7	1.8	13.4
6/30/2023	9	1.8	7.4
7/31/2023	8	3	17.5
8/31/2023	11	7.7	13.2
9/30/2023	11	2.7	9.7
10/31/2023	10	5.4	17.5
11/30/2023	8	2.5	6.3
12/31/2023	7	5.1	18.5

## WET Effluent

Parameter	LC50 Statre 48Hr Acute Ceriodaphnia	LC50 Statre 48Hr Acute Pimephales	Ammonia	Aluminum	Cadmium	Copper	Lead
	Daily Min	Daily Min	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	%	%	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	50	50	Report	Report	Report	Report	Report
Minimum	100	100	0.1	0.015	No Data	0.015	0
Maximum	100	100	0.34	0.044	No Data	0.023	0.0017
Median	100	100	0.11	0.039	No Data	0.017	0.001
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A
9/30/2019	100	100	0.1	0.044	0	0.023	0.0017
9/30/2020	100	100	0.26	0.015	0	0.016	0
9/30/2021	100	100	0.34	0.015	0	0.015	0
9/30/2022	100	100	0.11	0.039	0	0.017	0.001
9/30/2023	100	100	0.11	0.039	0	0.017	0.001

## WET Effluent

Parameter	Nickel	Zinc	Hardness
	Daily Max	Daily Max	Daily Max
Units	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report
Minimum	0.0055	0.055	86
Maximum	0.0072	0.089	150
Median	0.0067	0.087	88
No. of Violations	N/A	N/A	N/A
9/30/2019	0.0072	0.089	110
9/30/2020	0.0062	0.071	86
9/30/2021	0.0055	0.055	150
9/30/2022	0.0067	0.087	88
9/30/2023	0.0067	0.087	88

## WET Ambient

Parameter	pH	Ammonia	Aluminum	Cadmium	Copper	Lead	Nickel	Zinc
	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	S.U.	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
Minimum	0	0	0.025	No Data	0	0	0	0
Maximum	0.055	0.055	0.18	No Data	0.0017	0.0096	0	0.0065
Median	Non-Detect	Non-Detect	0.073	No Data	0.00055	0.00055	Non-Detect	0.0016
9/30/2019	7.22	<0.05	0.025	<0.001	<0.001	<0.001	<0.001	0.0021
9/30/2020	7.45	<0.05	0.099	<0.0005	<0.001	<0.0005	<0.001	0.0011
9/30/2021	7.57	<0.05	0.18	<0.0005	0.0017	0.0011	<0.001	0.0065
9/30/2022	7.35	0.055	0.047	<0.0005	0.0011	0.0096	<0.001	<0.005
9/30/2023								

## WET Ambient

Parameter	Hardness
	Daily Max
Units	mg/L
Effluent Limit	Report
Minimum	36
Maximum	67
Median	45.5
9/30/2019	48
9/30/2020	36
9/30/2021	67
9/30/2022	43
9/30/2023	

## Ambient Total Phosphorus

Parameter	Total Phosphorus
Units	mg/L
Site	Station 28-CNT (1.27 miles upstream)
Minimum	0.041
Maximum	0.058
Median	0.0495
6/18/1997	0.041
7/17/1997	0.058

Effluent Phosphorus
2020 Application
Average (3 samples)
2.77 mg/L
Daily Max
3.1 mg/L