

Outfall 001

Parameter	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5	BOD5
	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	MGD	MGD	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	630	30	940	45	1043	50
Minimum	0.42	0.55	13.9	2.6	19	2.8	17.2	3.4
Maximum	1.29	3.2	122.1	11.3	156.5	13.8	161.3	14.2
Median	0.85	1.235	36.2	4.85	47.55	6.15	57.65	7.4
No. of Violations	N/A	N/A	0	0	0	0	0	0
1/31/2019	0.91	1.79	86.4	11.3	106.6	13.8	111.6	14.2
2/28/2019	1.06	1.24	91.3	10	108.2	11.8	119	12.4
3/31/2019	1.02	1.34	75.7	8.2	109.6	11	140.9	14.2
4/30/2019	1.29	2.05	122.1	10.8	118.8	11.1	161.3	12.4
5/31/2019	1.01	1.52	63.6	7.5	156.5	11.9	111.5	10.7
6/30/2019	0.71	1.06	29.3	5.1	41.4	6.9	50.4	8.4
7/31/2019	0.68	1.07	22.3	3.9	26.4	3.9	38.7	8
8/31/2019	0.61	1.28	27.3	4.5	62.4	8.4	72.1	9.2
9/30/2019	0.83	0.93	38.1	5.3	40	5.4	40.7	5.9
10/31/2019	0.89	1.23	39.2	5.2	44.5	6.1	46.8	6.3
11/30/2019	0.89	1.13	49.2	6.2	55.2	7	61	7.1
12/31/2019	1.04	3.2	56	6.1	83.3	7.8	92.3	8.3
1/31/2020	0.96	1.66	52.2	6.7	62.3	7.4	72.2	8.4
2/29/2020	1.05	1.88	48.4	5.6	67.2	6.8	68.4	8.2
3/31/2020	0.87	1.21	46	6	59.2	6.9	77.1	9.5
4/30/2020	0.9	1.4	35.9	4.8	55.2	5.6	60.4	6.2
5/31/2020	0.58	0.97	20.8	4.4	30.3	5.4	40.7	7.5
6/30/2020	0.42	0.71	22.9	5.9	22.4	6.5	35.5	8.4
7/31/2020	0.46	0.63	13.9	3.6	29.8	6	17.2	4.8
8/31/2020	0.48	0.74	18.7	4.8	23.3	5.9	29.6	7.4
9/30/2020	0.72	0.86	28.2	4.9	30.9	5.9	34.1	6.6
10/31/2020	0.77	0.92	37.3	5.6	50.9	7.4	70.1	10
11/30/2020	0.73	0.88	42.4	6.6	48.6	7.3	56.7	8.6
12/31/2020	0.81	1.33	20.9	3.1	38.2	4.7	47	4.9
1/31/2021	0.66	0.93	23.9	4.3	37.7	6.1	39.6	6.6
2/28/2021	0.81	1.02	34.9	4.9	44.6	6.3	45.7	6.3
3/31/2021	0.93	1.26	40	5	45.2	5.8	57.3	7.1
4/30/2021	0.93	1.22	34.2	4.5	39	4.5	49.9	6.4
5/31/2021	0.82	1.18	35.4	4.8	75.8	9	99.8	12.6
6/30/2021	0.53	0.67	20.2	4.3	20.3	3.9	29.8	7
7/31/2021	0.85	1.49	23.4	3	26	6.2	32	3.4

Outfall 001

Parameter	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5	BOD5
	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	MGD	MGD	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	630	30	940	45	1043	50
8/31/2021	0.67	0.95	24.8	4.5	29.6	6.8	34.7	7
9/30/2021	1	1.75	36.6	4.5	41.5	5.2	53.3	6.2
10/31/2021	0.89	2.32	41.3	5.5	51.2	6	53	7.3
11/30/2021	0.98	1.5	44	5.2	57.9	5.6	76.8	7.8
12/31/2021	0.8	1.13	29.6	4.5	37.9	5.3	52.7	7.1
1/31/2022	0.74	1.07	33.3	5.1	57.7	7.9	60.9	8.3
2/28/2022	1.05	1.35	51.7	5.9	61.8	7.7	68.8	8.7
3/31/2022	0.97	1.28	36.6	4.4	49.7	5.1	65.2	6.8
4/30/2022	1.11	1.85	52.1	5.2	59.1	6.4	66.6	7
5/31/2022	0.76	1.01	36.5	5.4	56.9	8.2	59.4	8.9
6/30/2022	0.51	0.7	19.9	4.6	23.7	5	25.3	5.2
7/31/2022	0.44	0.55	18.9	4.7	33.6	8.4	47.1	11.3
8/31/2022	0.49	0.81	15.6	3.5	25.4	5.7	39.6	8.8
9/30/2022	0.81	1.12	42.6	6	55.4	7.6	58	8.7
10/31/2022	0.85	1.35	34.1	4.6	44.9	6.7	48.1	7.4
11/30/2022	0.81	1.3	41.8	5.7	58.8	6.8	74.8	7.6
12/31/2022	1.04	2.33	49	6	67.3	8.3	87.4	10.4
1/31/2023	1.11	2.67	31.8	3.8	46.5	4.4	63.6	6.1
2/28/2023	0.99	1.27	47.2	5.6	57.5	5.8	70.4	7.6
3/31/2023	1.2	1.63	45.5	4.5	51.3	6.9	67.1	7.6
4/30/2023	0.97	1.64	53	6.3	76.2	9.4	83.4	10
5/31/2023	0.99	2.8	38.6	4.2	91.9	5.6	112.3	6.6
6/30/2023	0.58	0.87	19.1	3.6	19	3.8	26.1	4.3
7/31/2023	0.79	1.58	24.2	3.2	37.9	4	58.5	6.1
8/31/2023	0.74	1.1	16.8	2.6	21	2.8	38.5	4.2
9/30/2023	1.06	2.27	43.2	4.3	71.5	4.9	71.9	6
10/31/2023	0.87	1.02	30.5	4.2	38.5	5.6	40.5	5.6
11/30/2023	0.83	1.13	32.4	4.5	32.6	4.7	43	5.6
12/31/2023	1.11	2.44	26.9	2.8	38.2	4.3	43.7	4.3

Outfall 001

Parameter	BOD5	TSS	TSS	TSS	TSS	TSS	TSS	TSS
	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max	Monthly Ave Min
Units	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	%
Effluent Limit	85	630	30	940	45	1043	50	85
Minimum	94.2	0	0	0	0	0	0	96.9
Maximum	98.3	60.4	5.9	97.8	10.5	180.4	21	100
Median	97.4	10.65	1.6	24.4	3.1	35.15	4.9	99.25
No. of Violations	0	0	0	0	0	0	0	0
1/31/2019	94.2	36.3	4.6	53.1	6.5	56.6	7	97.6
2/28/2019	96.3	30.5	3.4	32.7	3.6	64.8	7	98.7
3/31/2019	96	54.3	5.9	97.8	9.5	164.1	16	97.7
4/30/2019	95.5	60.4	5.4	81.5	7.5	112.8	11	97.7
5/31/2019	96.4	31.7	4.1	46.4	4	58.5	9	98.2
6/30/2019	97	24	4	50.6	8	40.3	7	98.6
7/31/2019	97.5	9.7	1.7	14.4	2.5	28.8	5	99.3
8/31/2019	98	10.7	2.2	22.7	4.5	26.3	5	99.4
9/30/2019	98.2	32.9	4.6	46.9	6.5	63.1	9	98.4
10/31/2019	98.2	18	2.4	37.2	5	52	7	99.2
11/30/2019	97.4	27.8	3.5	35.5	4.5	46	6	98.6
12/31/2019	95.8	10.3	1.1	26.4	2	52.7	4	99.3
1/31/2020	95.9	9.5	1.1	21.3	2.5	42.5	5	99.4
2/29/2020	98.1	36.5	4.2	90.2	10.5	180.4	21	98.9
3/31/2020	96.1	15.3	1.6	65.6	6.5	131.2	13	99.2
4/30/2020	95.6	21.9	2.4	70.4	7	95.3	9	97.9
5/31/2020	97.2	2.6	0.5	4.7	0.7	14.1	2.2	99.8
6/30/2020	97.1	0.9	0.3	3.2	1	6.3	2	99.9
7/31/2020	97.5	1.9	0.5	5.5	1.5	11	3	99.7
8/31/2020	97.1	12.4	3.2	24	6	32	8	98.5
9/30/2020	97.9	15.6	2.8	32.1	6	43.4	8	99
10/31/2020	97.6	3.9	0.6	7	1	14.4	2.5	99.8
11/30/2020	97.1	27.6	4.3	66.4	10	113.4	17	98
12/31/2020	97.2	5.5	0.6	27.4	3	48	5	99.5
1/31/2021	96.5	18	3.5	37.9	7.5	55	11	97.2
2/28/2021	97.3	10.6	1.6	43.9	6.5	87.8	13	99.3
3/31/2021	97.3	0	0	0	0	0	0	100
4/30/2021	97.5	1.9	0.3	3.5	0.5	10.6	1.3	99.9
5/31/2021	97.6	2.9	0.4	7.6	1	15.2	2	99.8
6/30/2021	97.5	0	0	0	0	0	0	100
7/31/2021	97.2	0	0	0	0	0	0	100

Outfall 001

Parameter	BOD5	TSS	TSS	TSS	TSS	TSS	TSS	TSS
	Monthly Ave Min	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max	Monthly Ave Min
Units	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	%
Effluent Limit	85	630	30	940	45	1043	50	85
8/31/2021	96.5	3.5	0.6	8.8	1.5	17.5	3	99.7
9/30/2021	97.8	7	0.9	23.5	3	47	6	99.7
10/31/2021	98	5	0.7	11.4	1.5	22.8	3	99.7
11/30/2021	97.7	14.7	1.7	35.6	4.4	50.2	6.2	99.2
12/31/2021	97.8	11.4	1.8	16.8	2.8	31.9	4.2	99
1/31/2022	96.4	27.9	4.2	54.8	7.5	63.1	8.6	96.9
2/28/2022	97.2	18.3	2.3	38.5	5.4	41.1	5.8	98.7
3/31/2022	97.3	7.5	1.1	25.3	4.2	34.3	5.8	99.4
4/30/2022	97.1	2.2	0.2	10.9	1.2	21.8	2.4	99.9
5/31/2022	97.9	12.9	2	22.9	3.4	30.3	4	99.2
6/30/2022	97.8	9.5	2.1	15.4	2.8	19.6	3.6	99.1
7/31/2022	97.6	6.6	1.6	11.5	2.7	13.8	3.6	99.2
8/31/2022	98.2	7.4	1.6	24.8	5.6	36	8	99.3
9/30/2022	97.1	19.4	2.7	21.8	3.2	36.4	4.8	98.9
10/31/2022	98.3	3.5	0.5	21.8	3.2	19.8	2.8	99.7
11/30/2022	97.6	7.2	0.8	22.8	2.6	29.5	3.2	99.6
12/31/2022	96.4	8	1.1	25.9	3.3	30.1	4.2	99.1
1/31/2023	96.7	5.4	0.5	29.8	2.8	32.5	3	99.6
2/28/2023	97.4	5.3	0.7	0	0	42.1	5.8	99.6
3/31/2023	97.9	15.5	1.6	33.1	4.5	50	5	98.9
4/30/2023	97.5	7.4	0.8	9.6	1.1	38.5	4.2	99.6
5/31/2023	97.7	11.7	0.99	32.5	2.5	34	2.6	99.4
6/30/2023	98.1	8	1.4	9.6	2.1	16	2.8	99.5
7/31/2023	96.2	17.7	2	38	3.6	81.3	7.5	98.6
8/31/2023	98	8.6	1.6	16.9	2.6	33.8	4.6	99.1
9/30/2023	97.4	15.2	1.3	30.3	2.7	60.6	3.2	99.4
10/31/2023	98.3	11.4	1.6	18.8	2.7	22.4	3	99.4
11/30/2023	98	17.2	2.6	28.1	3.9	32.7	4.4	99
12/31/2023	98	11.6	1.4	22.9	2.1	26.4	4.2	98.8

Outfall 001

Parameter	pH	pH	Fecal Coliform	Fecal Coliform	Fecal Coliform	TRC	TRC	Ammonia
	Minimum	Maximum	Monthly Geometric Mean	Daily Max	WKLY GEO	Monthly Ave	Daily Max	Monthly Ave
Units	SU	SU	#/100mL	#/100mL	#/100mL	mg/L	mg/L	mg/L
Effluent Limit	6.5	8	14	14	14	0.05	0.05	Report
Minimum	6.5	6.8	0	0	0	0	0	0
Maximum	7	7.4	1.8	142.1	4.3	0.02	0.05	22.6
Median	6.6	7.1	1	2	1.1	0	0	3.17
No. of Violations	0	0	0	3	0	0	0	N/A
1/31/2019	6.5	7.1	1	1	0	0	0	4
2/28/2019	6.7	7	1	1	0	0	0	15.9
3/31/2019	6.5	7.1	1	1	0	0	0	9.2
4/30/2019	6.5	7.2	1	2	1.1	0	0	4
5/31/2019	6.5	6.9	1	2	1.1	0	0	0.3
6/30/2019	6.5	7.1	1.1	4.1	1.2	0	0	3.3
7/31/2019	6.5	7.2	1.2	5	1	0	0	0.4
8/31/2019	6.6	7.2	1	5	1.5	0	0	0.97
9/30/2019	6.5	7	1.1	3.1	1.2	0	0	0.2
10/31/2019	6.5	7	1	1	1	0	0	0.3
11/30/2019	6.6	7	1	1	1	0.02	0.04	2.6
12/31/2019	6.5	7	1	2	1.1	0	0	1.7
1/31/2020	6.5	7	0	1	1	0	0	3
2/29/2020	6.7	7.1	1.2	11	1.4	0	0	3.1
3/31/2020	6.6	7.3	1.04	3.1	1.2	0	0	4.9
4/30/2020	6.5	6.9	1	1	1	0	0	0.5
5/31/2020	6.7	7.4	1	2	1.1	0	0	0.3
6/30/2020	6.8	7	1	3	1.2	0	0	0.1
7/31/2020	6.5	7	1.1	4.1	1.2	0	0	0
8/31/2020	6.8	7.2	1.2	43.9	2	0	0	0.23
9/30/2020	6.7	7.2	1	2	1.1	0	0	3.7
10/31/2020	6.6	7	1	1	1	0	0	1.3
11/30/2020	6.5	7.1	1	1	1	0	0	4.5
12/31/2020	6.5	6.8	1	1	1	0	0	0.18
1/31/2021	6.6	7	1	2	1.1	0	0	0.39
2/28/2021	6.6	7	0	0	0	0	0	5.6
3/31/2021	6.5	7	1	1	1	0	0	4.5
4/30/2021	6.5	6.8	1	2	1	0	0.02	1.9
5/31/2021	6.5	7.1	0	1	1.1	0	0.02	2.3
6/30/2021	6.9	7.2	1	2	1	0	0	1
7/31/2021	6.8	7.1	1.1	4.1	1.2	0	0	0.3

Outfall 001

Parameter	pH	pH	Fecal Coliform	Fecal Coliform	Fecal Coliform	TRC	TRC	Ammonia
	Minimum	Maximum	Monthly Geometric Mean	Daily Max	WKLY GEO	Monthly Ave	Daily Max	Monthly Ave
Units	SU	SU	#/100mL	#/100mL	#/100mL	mg/L	mg/L	mg/L
Effluent Limit	6.5	8	14	14	14	0.05	0.05	Report
8/31/2021	6.7	7.2	1.1	2	1.1	0	0.03	4.1
9/30/2021	6.6	7.1	1.1	13	1.1	0	0	4.1
10/31/2021	6.9	7.4	1	1	1.4	0	0.02	8.4
11/30/2021	6.7	7.1	1.1	5	1.3	0	0	4.3
12/31/2021	6.6	7	1	3.1	1.2	0	0	1.14
1/31/2022	6.7	7.4	1	1	1	0	0	5.6
2/28/2022	7	7.3	1	1	1	0	0	21.9
3/31/2022	6.7	7.3	1	1	1	0	0	12.6
4/30/2022	6.5	7.2	1	2	1.1	0	0	6.6
5/31/2022	6.6	7.3	1	1	1	0	0.04	13
6/30/2022	6.8	7.1	1.1	3.1	1.2	0	0	4.2
7/31/2022	6.9	7.2	1.1	2	1.2	0	0	1.9
8/31/2022	6.7	7.3	1.17	3.1	1.3	0	0.02	0.6
9/30/2022	6.7	7.2	1.25	142.1	2.2	0	0	4.24
10/31/2022	6.8	7.2	1	2	1.1	0	0	5.8
11/30/2022	6.5	7	1	1	1	0	0.02	7.4
12/31/2022	6.5	7.1	1	2	1.1	0.01	0.03	3.19
1/31/2023	6.5	7.1	1.06	3.1	1.1	0.01	0.02	3.15
2/28/2023	6.9	7.4	1	1	1	0	0.03	10.8
3/31/2023	6.5	7.3	1	2	1.1	0.01	0.03	15.37
4/30/2023	6.8	7.3	1	1	1	0.01	0.03	22.6
5/31/2023	6.7	7	1.15	3.1	1.7	0.01	0.05	2.2
6/30/2023	6.7	7.1	1	2	1.1	0.01	0.03	3.6
7/31/2023	6.8	7.1	1.2	5.2	1.5	0.01	0.05	3.909
8/31/2023	6.8	7	1.8	33.6	4.3	0.01	0.03	1.21
9/30/2023	6.7	7.2	1	2	1.1	0.01	0.02	3.6
10/31/2023	6.7	7.1	1	1	1	0.01	0.03	2.7
11/30/2023	6.6	7	1	4.1	1.2	0.01	0.02	2.13
12/31/2023	6.6	7	1.1	5.2	1.3	0.01	0.05	2.6

Outfall 001

Parameter	Ammonia	Copper	Copper	Zinc	Zinc
	Daily Max	Monthly Ave	Daily Max	Monthly Ave Min	Daily Max
Units	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report
Minimum	0	0.0042	0.0048	0.027	0.031
Maximum	28	0.034	0.065	0.41	0.19
Median	6.4	0.00965	0.00965	0.052	0.0555
No. of Violations	N/A	N/A	N/A	N/A	N/A
1/31/2019	12	0.012	0.014	0.034	0.037
2/28/2019	22	0.01	0.01	0.053	0.053
3/31/2019	16	0.012	0.012	0.069	0.087
4/30/2019	9.6	0.011	0.011	0.044	0.044
5/31/2019	1.3	0.01	0.01	0.042	0.042
6/30/2019	5.7	0.007	0.006	0.045	0.049
7/31/2019	1.3	0.008	0.008	0.047	0.049
8/31/2019	3.8	0.008	0.008	0.072	0.076
9/30/2019	1.3	0.01	0.01	0.054	0.055
10/31/2019	2	0.017	0.017	0.06	0.061
11/30/2019	4.1	0.019	0.02	0.048	0.05
12/31/2019	4	0.017	0.017	0.046	0.05
1/31/2020	6.6	0.012	0.012	0.039	0.039
2/29/2020	4.8	0.017	0.017	0.05	0.05
3/31/2020	13	0.017	0.017	0.052	0.056
4/30/2020	1.5	0.011	0.012	0.043	0.045
5/31/2020	1.5	0.007	0.0068	0.048	0.054
6/30/2020	0.6	0.008	0.0087	0.051	0.052
7/31/2020	0	0.011	0.012	0.068	0.07
8/31/2020	1.2	0.011	0.014	0.044	0.044
9/30/2020	13	0.011	0.011	0.052	0.052
10/31/2020	2.8	0.018	0.019	0.056	0.061
11/30/2020	11	0.015	0.015	0.072	0.081
12/31/2020	1.1	0.01	0.011	0.061	0.068
1/31/2021	1.7	0.007	0.0078	0.052	0.056
2/28/2021	11	0.012	0.012	0.059	0.064
3/31/2021	8	0.013	0.013	0.066	0.069
4/30/2021	4.3	0.012	0.012	0.053	0.063
5/31/2021	6.8	0.0095	0.0098	0.052	0.056
6/30/2021	2	0.006	0.0068	0.059	0.061
7/31/2021	1.3	0.0077	0.0077	0.054	0.056

Outfall 001

Parameter	Ammonia	Copper	Copper	Zinc	Zinc
	Daily Max	Monthly Ave	Daily Max	Monthly Ave Min	Daily Max
Units	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report
8/31/2021	7.8	0.006	0.0062	0.057	0.067
9/30/2021	6.2	0.034	0.065	0.038	0.065
10/31/2021	15	0.0086	0.0087	0.064	0.067
11/30/2021	7.9	0.01	0.01	0.052	0.052
12/31/2021	3.3	0.009	0.0095	0.057	0.063
1/31/2022	24	0.008	0.0083	0.068	0.095
2/28/2022	28	0.011	0.012	0.074	0.081
3/31/2022	25	0.012	0.014	0.061	0.068
4/30/2022	15	0.008	0.009	0.055	0.057
5/31/2022	27	0.0075	0.0076	0.057	0.058
6/30/2022	6.6	0.005	0.0056	0.071	0.072
7/31/2022	4.4	0.0046	0.0048	0.047	0.052
8/31/2022	4.1	0.0042	0.0048	0.044	0.044
9/30/2022	10	0.01	0.012	0.056	0.063
10/31/2022	8.2	0.0084	0.0085	0.044	0.044
11/30/2022	13	0.0091	0.0093	0.049	0.052
12/31/2022	11	0.007	0.0073	0.04	0.04
1/31/2023	13	0.0074	0.0075	0.41	0.042
2/28/2023	18	0.0091	0.0093	0.042	0.046
3/31/2023	24	0.0081	0.0083	0.056	0.067
4/30/2023	28	0.0065	0.007	0.047	0.051
5/31/2023	4.4	0.0079	0.0085	0.092	0.19
6/30/2023	5.5	0.006	0.006	0.06	0.06
7/31/2023	7.2	0.0069	0.007	0.027	0.031
8/31/2023	5.6	0.005	0.0062	0.044	0.044
9/30/2023	5.9	0.0098	0.01	0.035	0.047
10/31/2023	4.3	0.011	0.0079	0.04	0.042
11/30/2023	4.5	0.0124	0.015	0.068	0.073
12/31/2023	6.6	0.0079	0.0084	0.044	0.049

WET Effluent

Parameter	LC50 Acute Menidia	C-NOEC Chronic Menidia	LC50 Static 48Hr Acute Mysid. Bahia	Noel Static 1Hr Fert. Chronic Arbacia	Cadmium	Lead	Nickel
	Daily Min	Daily Min	Daily Min	Daily Min	Daily Max	Daily Max	Daily Max
Units	%	%	%	%	mg/L	mg/L	mg/L
Effluent Limit	100	58.8	100	58.8	Report	Report	Report
Minimum	100	50	100	58.8	0	0	0
Maximum	100	100	100	100	0	0.0004	0.0047
Median	100	100	100	100	0	0	0.00157
No. of Violations	0	1	0	0	N/A	N/A	N/A
3/31/2019	100	100	100	100	0	0	0.0015
6/30/2019	100	100	100	100	0	0	0
9/30/2019	100	100	100	100	0	0.0004	0.0026
12/31/2019	100	100	100	100	0	0	0.0021
3/31/2020	100	100	100	100	0	0	0.002
6/30/2020	100	100	100	100	0	0	0.0015
9/30/2020	100	100	100	100	0	0	0.0022
12/31/2020	100	100	100	100	0	0	0.0028
3/31/2021	100	100	100	100	0	0	0
6/30/2021	100	58.8	100	58.8	0	0	0.00139
9/30/2021	100	100	100	100	0	0	0.00157
12/31/2021	100	58.8	100	100	0	0.000324	0.0019
3/31/2022	100	100	100	100	0	0	0.00129
6/30/2022	100	50	100	100	0	0	0.0013
9/30/2022	100	100	100	100	0	0	0.00157
12/31/2022	100	100	100	100	0	0	0.0019
3/31/2023	100	58.8	100	100	0	0	0.0047
6/30/2023	100	58.8	100	100	0	0	0.0012
9/30/2023	100	58.8	100	100	0	0	0.0015
12/31/2023	100	100	100	58.8	0	0	0.0018

WET Ambient

Parameter	pH	Salinity	Ammonia
	Daily Max	Daily Max	Daily Max
Units	S.U.	ppt	mg/L
Effluent Limit	Report	Report	Report
Minimum	6.7	0	0
Maximum	7.79	29	0.5
Median	7.15	22	0
No. of Violations	N/A	N/A	N/A
3/31/2019	NODI	NODI	NODI
6/30/2019	NODI	NODI	NODI
9/30/2019	7.23	22	0
12/31/2019	6.99	7	0
3/31/2020	NODI	NODI	NODI
6/30/2020	7.02	0	0
9/30/2020	7.44	26	0
12/31/2020	7.43	29	0
3/31/2021	6.95	4	0.5
6/30/2021	6.87	3	0
9/30/2021	7.44	22.1	0
12/31/2021			
3/31/2022	7.15	15	0
6/30/2022	7.43	6	0
9/30/2022			
12/31/2022	7.79	27	0
3/31/2023	7.27	16	0.058
6/30/2023	6.93	25	0.054
9/30/2023	6.7	25	0.077
12/31/2023	6.79	25	0.1