

## Outfall 001

Parameter	Flow	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5
	Annual Rolling Ave	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	1.8	Report	Report	451	30	676	45	751
Minimum	0.57	0.513	0.064	6.7	1.3	25	3.7	26
Maximum	0.786	0.836	1.25	116.8	19.9	183.1	25.7	243.3
Median	0.708	0.6805	0.83	49.5	8.3	77.55	10.1	68.05
No. of Violations	0	N/A	N/A	0	0	0	0	0
1/31/2019		0.631	1.0083	43	8.2	56	10.9	94
2/28/2019		0.658	0.7869	40	6.3	40	7.5	44
3/31/2019		0.68	0.7968	54	9.1	66	11	73
4/30/2019		0.669	0.8427	41	7.2	52	9.2	70
5/31/2019		0.669	0.7981	57	10.6	80	18.2	94
6/30/2019		0.6153	0.719	38	7	42	7.5	54
7/31/2019		0.7106	0.7754	45	7.5	55	9	81
8/31/2019		0.6878	0.7882	29	5.3	50	8.3	64
9/30/2019		0.5882	0.6359	16	3.2	45	9	49
10/31/2019		0.574	0.7195	41	8.2	54	9	60
11/30/2019		0.555	0.6543	26	5.4	41	8.3	43
12/31/2019		0.704	1.056	43	5.6	56.4	9	64
1/31/2020		0.681	0.8123	60	10.1	102	16.3	104
2/29/2020		0.664	0.7989	64	11.6	84	16	95
3/31/2020		0.671	0.8496	71	12.1	108	19	113
4/30/2020		0.708	0.919	50	8.2	64	11	64
5/31/2020		0.647	0.789	49	8.8	63	11.7	65
6/30/2020		0.627	0.6898	42	8.1	53	10.3	67
7/31/2020		0.661	0.7708	31	5.5	40	7	59
8/31/2020		0.655	0.918	14	2.6	41	7.5	52
9/30/2020		0.562	0.651	10	2.2	30	6	33
10/31/2020		0.571	0.6818	6.7	1.3	18	3.7	27
11/30/2020		0.568	0.715	17	3.4	33	6.5	36
12/31/2020		0.578	0.81	58	12	76	15	94
1/31/2021		0.556	0.64	44	9	58	11	68
2/28/2021		0.546	0.67	50	10.3	62	12	67
3/31/2021		0.549	0.86	36	7.7	51	9.7	60
4/30/2021		0.513	0.064	28	6.2	36	7	43

## Outfall 001

Parameter	Flow	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5
	Annual Rolling Ave	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	MGD	MGD	MGD	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	1.8	Report	Report	451	30	676	45	751
5/31/2021	0.58	0.53	0.77	29	6.9	32.4	7.3	44
6/30/2021	0.57	0.52	0.62	25	5.6	32	8	40
7/31/2021	0.57	0.62	0.914	30	6	32	6	35
8/31/2021	0.57	0.7	0.77	24	4.1	34	5.5	50
9/30/2021	0.58	0.73	1.22	22	3.6	32	4.9	40
10/31/2021	0.59	0.675	1.2	20	3.6	25	4.4	26
11/30/2021	0.61	0.758	0.92	67	10.1	83	12.9	99
12/31/2021	0.62	0.683	0.88	83.1	14	89	13.8	139.5
1/31/2022	0.63	0.706	0.92	93.7	15.1	127	20.5	147.3
2/28/2022	0.65	0.771	1.11	93.9	14.3	112.8	15.6	149.2
3/31/2022	0.66	0.717	0.86	85.4	14.3	110.8	17.6	113.5
4/30/2022	0.679	0.728	0.94	74.5	11.6	146.9	19.7	185.7
5/31/2022	0.691	0.677	0.84	41.9	7.5	50.7	8.2	68.1
6/30/2022	0.706	0.699	0.78	36.4	6.2	48.4	8.53	45.9
7/31/2022	0.709	0.657	0.79	72.6	13.1	105.3	20.6	126.7
8/31/2022	0.713	0.746	0.969	101.7	15.5	183.1	25.7	243.3
9/30/2022	0.709	0.684	0.851	65.5	10.6	75.4	12.4	92.1
10/31/2022	0.71	0.688	0.82	76.3	12.9	89.7	15.4	100.2
11/30/2022	0.703	0.678	0.75	42.3	7.3	47.7	8.5	66.5
12/31/2022	0.707	0.724	0.92	52.7	8.4	59	9.3	65.2
1/31/2023	0.715	0.811	1.25	79.1	11.7	96.8	13.2	123.4
2/28/2023	0.714	0.757	0.95	67.4	10.6	78.3	11.9	102.2
3/31/2023	0.724	0.836	1.09	57.2	8.1	67.1	9.7	66
4/30/2023	0.725	0.737	1.13	80	11.6	155.5	17.9	236
5/31/2023	0.735	0.807	1.12	89.2	19.9	128.6	14.9	150
6/30/2023	0.741	0.767	0.92	40.7	6.3	60.6	9.9	59.9
7/31/2023	0.756	0.831	1.03	67.5	9.7	76.4	10.8	90.6
8/31/2023	0.763	0.831	1.15	107.7	15.1	125.8	16.3	151.8
9/30/2023	0.773	0.806	1.12	116.8	16.3	158	19.4	180.2
10/31/2023	0.775	0.715	0.81	60	9.7	81.5	12.6	105.2
11/30/2023	0.776	0.695	0.8	53.1	8.9	56.9	9.5	75.8
12/31/2023	0.786	0.836	1.2	64.9	8.6	76.8	9	107.2

## Outfall 001

Parameter	BOD5	BOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Minimum	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	50	85	451	30	676	45	751	50
Minimum	5	94	16	2.8	19	3.3	22	3.8
Maximum	30.1	99	126.1	18.8	325.1	45.1	458.3	56.7
Median	12.35	98	40.3	7.15	57.25	8.8	71.5	11.7
No. of Violations	0	0	0	0	0	1	0	1
1/31/2019	19	98	34	6.3	38	7.2	67	8.6
2/28/2019	7.8	98	41	7.3	43	7.8	90	14.3
3/31/2019	12.7	98	62	10.5	96	16.7	191	32.9
4/30/2019	12.5	98	42	7.4	49	8.8	70	12.5
5/31/2019	21.4	97	44	8.2	70	15.2	97	24.1
6/30/2019	9.9	98	18	3.2	22	4.1	26	5.6
7/31/2019	13.2	98	35	5.9	51	8.3	105	17.2
8/31/2019	10.4	99	27	5	34	5.6	44	7.5
9/30/2019	9.8	99	16	3.1	26	5.2	29	5.7
10/31/2019	11	98	38	7.7	47	9.8	73	12.9
11/30/2019	9.5	98	22	4.7	29	5.9	34	7.4
12/31/2019	9	98	35	6.1	37	6.1	62	11.2
1/31/2020	18	96	67	11.7	98	17.9	117	20.2
2/29/2020	17	97	72	12.9	81	15.2	107	19
3/31/2020	19	95	88	15.3	109	20.2	123	22.8
4/30/2020	11	97	71	11.9	88	14.8	115	18.4
5/31/2020	12	98	51	9.4	56	10.2	71	14
6/30/2020	13	98	37	7.2	45	9.1	56	11.6
7/31/2020	10	99	39	7	58	10.2	113	19.2
8/31/2020	9	99	26	4.5	46	8.6	40	6.9
9/30/2020	6	99	20	4.2	22	4.6	41	7.6
10/31/2020	5	99	23	4.6	28	5.6	51	9.6
11/30/2020	7	98	21	4.3	21	4.3	35	6.9
12/31/2020	20	97	37	8	54	11	58	14
1/31/2021	13	98	33	7	37	7.5	54	10
2/28/2021	13	97	53	11	66	13.9	72	18
3/31/2021	11	98	43	9.3	55	10.4	71	14
4/30/2021	8	98	22	4.9	43	6.9	32	7

## Outfall 001

Parameter	BOD5	BOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Minimum	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max	Daily Max
Units	mg/L	%	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	50	85	451	30	676	45	751	50
5/31/2021	9.1	98	25.2	5.71	35	7.3	64	12.6
6/30/2021	9	99	17	3.8	23	5.7	26	6.1
7/31/2021	7	98	27	5	34	7	42	8
8/31/2021	7.9	99	26	4.4	34	5.6	47	7.4
9/30/2021	7.9	99	27	4.3	38	6	44	7.3
10/31/2021	5	99	16	2.8	19	3.3	22	3.8
11/30/2021	14.9	97	63	9.8	78	12.3	93	13.7
12/31/2021	20.2	96	91.2	15.1	81.8	13.3	187.1	26.3
1/31/2022	23.2	96	97.5	15.7	171.5	26	192.9	30.2
2/28/2022	16.1	96	81.6	12.4	102.6	13.9	131.6	15.2
3/31/2022	19.7	96	64.5	10.7	83.2	13.6	85.6	14
4/30/2022	23.7	97	76.9	11.8	144.9	20	218.2	31.1
5/31/2022	10.8	98	40.8	7.2	51.9	8.3	75.8	10.8
6/30/2022	7.6	98	43	7.3	56.5	9.5	74.1	11.8
7/31/2022	26.4	97	61.3	11.2	82.1	15.6	90.7	15.9
8/31/2022	30.1	96	126.1	18.8	325.1	45.1	458.3	56.7
9/30/2022	13.6	98	39.7	6.4	43.2	6.8	54.6	8.8
10/31/2022	16.3	96	69.1	11.7	94.5	15.3	104.5	17
11/30/2022	12.2	98	37.6	6.5	53.6	9.2	58.2	9.7
12/31/2022	10.5	97	37.7	6.1	44.4	6.5	46.8	7.5
1/31/2023	15.4	97	59.2	8.7	71.4	9.8	88.1	11.6
2/28/2023	15	97	44.1	7	58.3	8.7	77	11.3
3/31/2023	10.2	98	34.3	4.9	40.9	6	45.6	6.6
4/30/2023	25.1	97	48.8	7.1	89.5	10.3	134.4	14.3
5/31/2023	23.3	96	43.4	6.3	55.5	7.1	79.5	9.7
6/30/2023	8.5	98	28.2	4.4	34.3	5.6	43.7	7
7/31/2023	13.3	98	39.8	5.6	50.1	7.1	67.6	10
8/31/2023	17.1	96	107.7	14.8	149.4	18.4	205.6	21.4
9/30/2023	23.3	94	98.3	13.3	160.2	19.4	215.7	27.9
10/31/2023	15.8	97	45.6	7.3	58	8.9	86.4	13.6
11/30/2023	11.4	97	36	6	41.4	6.6	52	8.2
12/31/2023	10.7	97	59.1	7.8	76.5	8.8	114.2	11.4

## Outfall 001

Parameter	TSS	pH	pH	Enterococci	Enterococci	Fecal Coliform	TRC	TRC
	Minimum	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Geometric Mean	Monthly Ave	Monthly Ave
Units	%	SU	SU	#/100mL	#/100mL	#/100mL	mg/L	ug/L
Effluent Limit	85	6.5	8	35	104	14	0.54	240
Minimum	95	6.43	7.2	0.7	1	0	0	0
Maximum	99	7.26	7.7	29.3	2419.6	4.3	0.2	111
Median	98	6.76	7.44	2.25	24.65	1.0	0.035	40
No. of Violations	0	1	0	0	8	0	0	0
1/31/2019	98	6.8	7.3	2.8	14.8	1	0	
2/28/2019	98	6.8	7.4	4.3	28.5	1	0	
3/31/2019	97	6.9	7.3	5.9	66.3	1	0	
4/30/2019	98	6.6	7.5	2	14.8	1	0	
5/31/2019	98	6.6	7.4	2.4	32.3	1	0	
6/30/2019	99	6.79	7.52	0.7	27.9	0.5	0.06	
7/31/2019	98	6.81	7.51	1.2	6.3	1.1	0.02	
8/31/2019	99	6.84	7.47	1.4	478.6	1	0.01	
9/30/2019	99	6.68	7.27	1.4	6.3	1.3	0.01	
10/31/2019	98	6.83	7.21	1.5	8	1	0.05	
11/30/2019	99	6.73	7.2	2.8	9.8	1	0.07	
12/31/2019	98	6.5	7.3	2.9	9.8	<= 1	0	
1/31/2020	97	6.91	7.29	10.2	71.2	1	0	
2/29/2020	96	6.87	7.33	10.5	33.1	< 1	0	
3/31/2020	96	6.43	7.28	8.7	76.7	1	0	
4/30/2020	97	6.72	7.24	1.7	8.6	1	0.05	
5/31/2020	98	6.65	7.31	1.1	4.1	0	0	
6/30/2020	99	6.85	7.38	1.2	9.6	1	0.05	
7/31/2020	98	6.5	7.42	1	1	1	0	
8/31/2020	99	6.7	7.5	1.1	5.2	2	0.07	
9/30/2020	99	6.74	7.7	1.4	5	2	0.07	
10/31/2020	99	6.67	7.52	1.8	17.3	1	0.1	
11/30/2020	99	6.82	7.52	1.4	21.6	1	0.14	
12/31/2020	98	6.84	7.5	7.9	69.7	1	0.09	
1/31/2021	98	6.67	7.45	9.3	51.2	< 1	0.12	
2/28/2021	97	6.74	7.42	9.2	119.8	1	0.2	
3/31/2021	97	6.84	7.42	2.1	11	1	0.1	
4/30/2021	99	6.86	7.44	2.2	16.1	1	0.07	

## Outfall 001

Parameter	TSS	pH	pH	Enterococci	Enterococci	Fecal Coliform	TRC	TRC
	Minimum	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Geometric Mean	Monthly Ave	Monthly Ave
Units	%	SU	SU	#/100mL	#/100mL	#/100mL	mg/L	ug/L
Effluent Limit	85	6.5	8	35	104	14	0.54	240
5/31/2021	99	6.69	7.52	1.6	12.2	< 1.8		60
6/30/2021	99	6.7	7.6	1.3	9.8	< 1.8		50
7/31/2021	98	7.03	7.61	1.1	4.1	1		70
8/31/2021	99	7.01	7.59	1	4.1	1		0
9/30/2021	99	6.71	7.56	1.7	22.8	2.5		40
10/31/2021	99	6.67	7.52	1.8	13.4	1.9		0
11/30/2021	97	6.9	7.42	7.5	78	2		70
12/31/2021	96	6.78	7.42	14.6	137.9	1.8		80
1/31/2022	95	6.84	7.44	29.3	172	1.8		0
2/28/2022	96	6.62	7.36	27.2	158.5	1.8		70
3/31/2022	96	6.7	7.42	11.1	2419.6	1.8		40
4/30/2022	97	6.62	7.53	8.3	2419.6	4.3		27
5/31/2022	98	6.66	7.46	1.9	54.8	2		30
6/30/2022	98	6.74	7.47	2.3	43.5	2.5		40
7/31/2022	97	6.66	7.66	2.3	328.2	3		80
8/31/2022	95	6.76	7.57	2.1	12.2	1.8		78
9/30/2022	99	6.63	7.41	5.2	34.1	1.8		69
10/31/2022	95	6.73	7.47	3.2	20.3	1		60
11/30/2022	97	7.01	7.43	4.1	16.1	1		103
12/31/2022	98	6.68	7.42	9	47.1	1		45
1/31/2023	97	6.85	7.37	12.5	49.5	1		59
2/28/2023	98	6.63	7.4	8.5	37.4	1		111
3/31/2023	98	6.54	7.4	5.6	36.9	1		15
4/30/2023	98	7.26	7.5	3	43.2	1		12
5/31/2023	98	7.12	7.56	1.5	17.1	1		18
6/30/2023	99	6.93	7.52	1.7	20.3	1		41
7/31/2023	98	7.07	7.49	1	3.1	1		21
8/31/2023	96	7	7.5	1.8	26.5	1		25
9/30/2023	95	6.76	7.44	1.9	69.7	1		21
10/31/2023	97	6.84	7.51	1.1	8.6	1		31
11/30/2023	98	6.87	7.45	2.8	50	1		2
12/31/2023	97	6.92	7.42	9.1	44.8	1		29

## Outfall 001

Parameter	TRC	TRC	Arsenic, total recoverable	Arsenic, total recoverable	Coliform, fecal - % sample exceeds limit
	Daily Max	Daily Max	Monthly Ave	Daily Max	Daily Max
Units	mg/L	ug/L	mg/L	mg/L	%
Effluent Limit	0.94	420	Report	Report	10
Minimum	0.25	50	0	0	0
Maximum	0.93	500	0.0018	0.0019	16.7
Median	0.63	366	0.0014	0.00145	0
No. of Violations	0	1	N/A	N/A	1
1/31/2019	0.41		0.0012	0.0012	0
2/28/2019	0.73		0.0014	0.0015	0
3/31/2019	0.34		0.0013	0.0013	0
4/30/2019	0.43		0.0012	0.0013	0
5/31/2019	0.44		< .001	0.0013	0
6/30/2019	0.44		0.001	0.0014	0
7/31/2019	0.44		0.0015	0.0017	0
8/31/2019	0.25		0.0018	0.0018	0
9/30/2019	0.29		0.0018	0.0019	0
10/31/2019	0.44		0.0018	0.0019	0
11/30/2019	0.66		0.0017	0.0018	0
12/31/2019	0.47		0.0014	0.0014	0
1/31/2020	0.77		0.00135	0.0017	0
2/29/2020	0.61		0.0013	0.0013	0
3/31/2020	0.51		0.0014	0.0016	0
4/30/2020	0.86		0.0014	0.0015	0
5/31/2020	0.28		0.0012	0.0012	0
6/30/2020	0.82		0.0015	0.0016	0
7/31/2020	0.3		0.0016	0.0016	0
8/31/2020	0.67		0.0017	0.0018	0
9/30/2020	0.76		0.0012	0.0013	0
10/31/2020	0.73		0.0014	0.0014	0
11/30/2020	0.82		0.0016	0.0017	0
12/31/2020	0.67		0.0015	0.0017	0
1/31/2021	0.93		0.0011	0.0011	0
2/28/2021	0.78		0	0	0
3/31/2021	0.85		0	0	0
4/30/2021	0.65		0.0012	0.0012	0

## Outfall 001

Parameter	TRC	TRC	Arsenic, total recoverable	Arsenic, total recoverable	Coliform, fecal - % sample exceeds limit
	Daily Max	Daily Max	Monthly Ave	Daily Max	Daily Max
Units	mg/L	ug/L	mg/L	mg/L	%
Effluent Limit	0.94	420	Report	Report	10
5/31/2021		500			0
6/30/2021		370			0
7/31/2021		420			0
8/31/2021		70			0
9/30/2021		380			0
10/31/2021		320			0
11/30/2021		350			0
12/31/2021		410			0
1/31/2022		340			0
2/28/2022		380			0
3/31/2022		320			0
4/30/2022		180			16.7
5/31/2022		390			0
6/30/2022		320			0
7/31/2022		419			0
8/31/2022		400			0
9/30/2022		415			0
10/31/2022		408			0
11/30/2022		375			0
12/31/2022		340			0
1/31/2023		308			0
2/28/2023		400			0
3/31/2023		355			0
4/30/2023		362			0
5/31/2023		248			0
6/30/2023		406			0
7/31/2023		275			0
8/31/2023		350			0
9/30/2023		297			0
10/31/2023		398			0
11/30/2023		50			0
12/31/2023		385			0



## WET Effluent

Parameter	LC50 Acute Mysid. Bahia	LC50 Acute Menidia	Ammonia	Cadmium	Copper	Lead	Nickel	Zinc
	Daily Min	Daily Min	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	%	%	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	100	100	Report	Report	Report	Report	Report	Report
Minimum	100	100	0	0	0.0059	0	0.0017	0.059
Maximum	100	100	6.1	0.0001	0.11	0.00072	0.0042	0.13
Median	100	100	0.66	0	0.011	0.0004	0.003	0.081
No. of Violations	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3/31/2019	100	100	0.71	0	0.012	0.0005	0.0041	0.13
6/30/2019	100	100	0.5		0.0062	0.0006	0.0027	0.081
9/30/2019	100	100			0.0093	0.0004	0.0031	0.092
12/31/2019	100	100	0	0	0.011	0.0004	0.0034	0.12
3/31/2020	100	100	0.37	0	0.041	0.0006	0.0042	0.13
6/30/2020	100	100	0.41	0	0.01	0.0006	0.0026	0.08
9/30/2020	100	100	1.38	0	0.0083	0.0004	0.0035	0.098
12/31/2020	100	100	0.16	0	0.01	0.0003	0.0032	0.081
3/31/2021	100	100	0.85	0	0.0087	0.0003	0.0032	0.066
6/30/2021	100	100	0	0.0001	0.011	0.0005	0.003	0.0805
9/30/2021	100	100	0.83	0	0.0139	0.000381	0.00209	0.0738
12/31/2021	100	100	0	0	0.00943	0.000307	0.00248	0.0742
3/31/2022	100	100	0.66	0	0.0184	0.00064	0.00321	0.082
6/30/2022	100	100	0.35	0	0.11	0.00072	0.003	0.076
9/30/2022	100	100	3.8	0	0.012	0.00057	0.0032	0.085
12/31/2022	100	100	0.69	0	0.015	0	0.0023	0.076
3/31/2023	100	100	1.9	0	0.0059	0	0.0023	0.082
6/30/2023	100	100	0.58	0	0.0071	0	0.0025	0.076
9/30/2023	100	100	6.1	0	0.019	0.00059	0.0021	0.083
12/31/2023	100	100	1.1	0	0.011	0	0.0017	0.059

## WET Effluent

Parameter	TOC
	Daily Max
Units	mg/L
Effluent Limit	Report
Minimum	5.1
Maximum	15.1
Median	10
No. of Violations	N/A
3/31/2019	
6/30/2019	
9/30/2019	
12/31/2019	
3/31/2020	
6/30/2020	
9/30/2020	
12/31/2020	
3/31/2021	
6/30/2021	9.6
9/30/2021	5.1
12/31/2021	5.8
3/31/2022	15.1
6/30/2022	15
9/30/2022	7.2
12/31/2022	9
3/31/2023	10
6/30/2023	10
9/30/2023	13
12/31/2023	12

## WET Ambient

Parameter	pH	Ammonia	Salinity	Cadmium	Copper	Lead	Nickel	Zinc
	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	SU	mg/L	ppt	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
Minimum	7.42	0	30	0	0	0	0	0
Maximum	8.07	0.36	32	0	0.044	0.0029	0.0004	0.033
Median	7.82	0	31	0	0	0	0	0
3/31/2019	7.72	0	31					
6/30/2019	7.97	0	30					
9/30/2019	7.83	0	31					
12/31/2019	7.5	0	31					
3/31/2020	7.6	0.36	32					
6/30/2020	7.64	0.24	31					
9/30/2020	7.42	0.11	31					
12/31/2020								
3/31/2021	7.62	0	30					
6/30/2021	7.87	0		0	0.0009	0	0.0004	0.0051
9/30/2021	7.99	0		0	0.000621	0	0.00038	0.00341
12/31/2021	8.07	0		0	0.000572	0	0.000364	0.00447
3/31/2022	7.64	0		0	0	0	0	0
6/30/2022	7.98	0		0	0	0	0	0
9/30/2022	7.82	0		0	0.044	0.0029	0	0.033
12/31/2022	7.91	0		0	0	0	0	0
3/31/2023	7.54	0		0	0	0	0	0
6/30/2023	7.9	0		0	0	0	0	0
9/30/2023	7.88	0		0	0	0	0	0
12/31/2023	7.74	0		0	0	0	0	0.0071

## WET Ambient

Parameter	TOC	Temperature
	Daily Max	Daily Max
Units	mg/L	deg C
Effluent Limit	Report	Report
Minimum	0	1.8
Maximum	0	18
Median	0	4.4
3/31/2019		
6/30/2019		
9/30/2019		
12/31/2019		
3/31/2020		
6/30/2020		
9/30/2020		
12/31/2020		
3/31/2021		
6/30/2021	0	12.2
9/30/2021	0	5
12/31/2021	0	18
3/31/2022	0	4
6/30/2022	0	1.8
9/30/2022	0	5.2
12/31/2022	0	6.6
3/31/2023	0	3.1
6/30/2023	0	4.4
9/30/2023	0	1.9
12/31/2023	0	3.4