

**Attachment B**  
**Fact Sheet No. MA0040134**  
**Massachusetts Water Resources Authority**  
**Cosgrove Intake Facility Pipe Loop Building**

**July 1, 2002**

**Effluent Characteristics**  
**Sampling conducted June 4, 2002**

<b>Parameter</b>	<b>Average</b>	
Flow	336.5 gpm	
pH	7.07 su	
Total Residual Chlorine	0.05 mg/l	

Average

