

**AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)**

In compliance with the provisions of the Federal Clean Water Act, as amended, (33 U.S.C. §1251 et seq.; the "CWA"),

**SUEZ Energy NA, Inc.**

is authorized to discharge from a facility located at

**Bethlehem Power Plant  
1241 Whitefield Road  
Bethlehem, NH 03574**

to receiving water named

**Ammonoosuc River (Hydrologic Basin Code 01070001)**

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective November 1, 2006.

This permit and the authorization to discharge expire October 31, 2011.

This permit supersedes the permit issued on December 19, 1986.

This permit consists of 10 pages in Part I including Effluent Limitations and Monitoring Requirements, Reporting Requirements, and State Permit Conditions; Attachment A (10 pages); Attachment B (19 pages) and Part II including General Conditions and Definitions.

Signed this 22<sup>nd</sup> day of SEPTEMBER, 2006

/s/ SIGNATURE ON FILE

---

Linda M. Murphy, Director  
Office of Ecosystem Protection  
U.S. Environmental Protection Agency  
Region I - New England  
Boston, Massachusetts

**PART I**

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

1. The term "Regional Administrator" means the Regional Administrator of Region I of the U.S. Environmental Protection Agency and the term "Commissioner" means the Commissioner of the New Hampshire Department of Environmental Services, Water Division (NHDES-WD) or their respective designee.
2. All procedures used for the purpose of collecting, preserving, and analyzing wastewater samples shall be in conformance with 40 C.F.R. Part 136 unless alternative procedures are specified in this NPDES permit.
  - a. Alternate analytical methods shall be approved by EPA at the permittee's written request should the permittee demonstrate to EPA's satisfaction that it will utilize equally sensitive test methods. Such a request will be considered a minor modification to the permit.
  - b. The Whole Effluent Toxicity (WET) test required by this permit is a 48-Hour Static Acute test on effluent samples using two species, Daphnid (Ceriodaphnia dubia) and Fathead Minnow (Pimephales promelas) following the protocol in Attachment A (Freshwater Acute Toxicity Test Procedure and Protocol dated December 1995).
    - i. LC50 (Lethal Concentration 50 Percent) is the concentration of wastewater (effluent) causing mortality to 50 percent (%) of the test organisms. The "100 % or greater limit" is defined as a sample which is composed of 100 % effluent. This limit is considered to be a maximum daily limit.
    - ii. A-NOEC (Acute-No Observed Effect Concentration) is defined as the highest concentration of toxicant or effluent to which organisms are exposed in a life-cycle or partial life-cycle test which causes no adverse effects (in this case, death) at a specific time of observation as determined from hypothesis testing where the test results (again, death) exhibit a linear dose-response relationship. However, where the test results do not exhibit a linear dose-response relationship, report the lowest concentration where there is no observable effect. See Attachment A, page A-8 (VII. Toxicity Test Data Analysis) for additional clarification.
    - iii. All pollutant parameters shall be determined to at least the Minimum Quantification Level (MLs) shown in Attachment A, page A-8, or as amended.

3. During the period beginning on the effective date and lasting through the expiration date, the permittee is authorized to discharge from outfall serial number 001(process): boiler blowdown, sandfilter backwash, demineralizer regeneration, mechanical equipment cooling, cooling tower treatment filtrate (blowdown), artesian well flushing, condenser cleaning, laboratory wastewater and other miscellaneous floor drain wastes to the Ammonoosuc River only during emergencies. Such discharges shall be limited and monitored by the permittee as specified below.

Effluent Characteristic	Maximum Daily Discharge Limitations	Monitoring Requirements	
		Measurement Frequency	Sample Type
Flow Rate (million gallons per day)	0.20	Continuous	Recorder
Total Suspended Solids (mg/l)	100	Each Discharge Event	Composite
Temperature (°F)	85	Continuous	Recorder
Temperature Rise, ( $\Delta T$ ), (°F) <sup>1</sup>	20	Continuous	Recorder
Oil and Grease (mg/l)	20	Each Discharge Event	Grab
The 126 priority pollutants contained in chemicals added for cooling tower maintenance (except Cr and Zn)	No detectable amount	Each Discharge Event	Grab
Total Recoverable Chromium (mg/L)	0.2	Each Discharge Event	Composite
Total Recoverable Zinc (mg/L)	1.0	Each Discharge Event	Composite
Total Recoverable Copper (mg/l)	0.35	Each Discharge Event	Composite
Total Recoverable Iron (mg/l)	0.30	Each Discharge Event	Composite
Total Residual Chlorine (mg/l)	0.2	Each Discharge Event	Grab
pH (standard units)	$\geq 6.5$ and $\leq 8.0$ <sup>2</sup>	Continuous	Recorder <sup>3</sup>
Whole Effluent Toxicity			
LC50 (%)	$\geq 100$	Each Discharge Event	Composite
A-NOEC (%)	Report	Each Discharge Event	Composite
Ammonia Nitrogen as Nitrogen (mg/l)	Report	Each Discharge Event	Composite
Hardness (mg/l)	Report	Each Discharge Event	Composite
Total Recoverable Aluminum (mg/l)	Report	Each Discharge Event	Composite
Total Recoverable Cadmium (mg/l)	Report	Each Discharge Event	Composite
Total Recoverable Lead (mg/l)	Report	Each Discharge Event	Composite
Total Recoverable Nickel (mg/l)	Report	Each Discharge Event	Composite

<sup>1</sup> Temperature Rise is the temperature difference between the intake water and the discharge.

<sup>2</sup> See State Permit Conditions, Part I.C.

<sup>3</sup> Report minimum and maximum values.

- a. Effluent samples shall be representative of the discharge and shall be taken from the discharge pipe within the manhole located approximately 10 feet from the river, prior to discharging into the Ammonoosuc River and without mixing with storm water. At no time shall the discharge flow rate exceed 150 gallons per minute. The permittee shall notify EPA and NHDES-WD within 24 hours by telephone after initiating discharge from this location.
  - b. Compliance with the “no detection” limitation for the 126 priority pollutants may be determined by engineering calculations. (See 40 CFR § 423.15(j)(3)) If this approach is taken, the permittee shall demonstrate that none of the 126 priority pollutants occurs in any of the treatment chemicals added by the company and this information (updated if chemicals change) shall be submitted to the EPA and NH DES-WD with every December Discharge Monitoring Report (DMR) thereafter.
  - c. Whole Effluent Toxicity (WET) test results are to be submitted by the 15th day of the month following the month the discharge event occurred.
4. During the period beginning on the effective date and lasting through the expiration date, the permittee is authorized to discharge from outfall serial numbers 002: storm water runoff to the Ammonoosuc River. Such discharges shall be limited and monitored by the permittee as specified below.

Effluent Characteristic	Maximum Daily Discharge Limitations	Monitoring Requirements	
		Measurement Frequency	Sample Type
Oil and Grease (mg/l)	15	1/Quarter	Grab
Total Suspended Solids (mg/l)	100	1/Quarter	Grab
Total Recoverable Iron (mg/l)	1.0	1/Quarter	Grab
Chemical Oxygen Demand (mg/l)	Report	1/Quarter	Grab
pH (standard units)	≥6.5 and ≤8.0	1/Quarter	Grab
pH (standard units) of rainfall	Report	1/Quarter	Grab

- a. Effluent samples shall representative of the discharge and shall be taken from stormwater collection system drain pipe, prior to discharging into the Ammonoosuc River.
- b. At each outfall, grab samples shall be collected from the discharge resulting from a storm event that is greater than 0.1 inches in magnitude and that occurs at least 72 hours from the previously measurable (greater than 0.1 inch rainfall) storm event. The grab samples shall be taken during the first thirty minutes of the discharge. If collection of the grab sample(s) during the first thirty minutes is impracticable, grab sample(s) can be taken as soon after that as possible, and the permittee shall submit with the monitoring report a description of why the collection of the grab sample(s) during the first thirty minutes was impracticable. When a permittee is unable to collect grab sample(s) due to adverse climatic conditions,

the permittee must submit, in lieu of sampling data, a description of why the grab sample(s) could not be collected, including available documentation of the event. The permittee must submit this information either in the comments section of the DMR(s) or in an attached letter. Adverse weather conditions which may prohibit the collection of sample(s) include weather conditions that create dangerous conditions for personnel (such as local flooding, high winds, hurricane, tornadoes, electrical storms, etc.) or otherwise make the collection of sample(s) impracticable (drought, extended frozen conditions, specified storm event did not occur during sampling period, etc.). A "no discharge" report shall be submitted for those quarters in which there is no discharge.

- c. The pH shall not be less than 6.5 S.U. nor greater than 8.0 S.U. unless due to naturally occurring conditions in the rainfall. The pH shall be within 0.5 S.U. of the rainfall pH when the pH is outside the above range. Rainfall pH shall be monitored when the discharge is monitored and shall be reported on the appropriate Discharge Monitoring Report.

5. Water Treatment Chemicals

- a. Every July the permittee must collect a representative sample of water from the drain/tempering tank and perform on that sample a: 48-Hour static acute WET test following the protocol shown in Attachment A (Freshwater Acute Toxicity Test Procedure and Protocol dated December 1995). Results of all required testing shall be submitted on Discharge Monitoring Reports (DMR) to EPA and the NHDES-WD by September 15<sup>th</sup> of each year.
- b. The permittee may propose to conduct feasibility studies involving new chemicals containing pollutants not currently approved for water discharge (See Part I.A.7.c). The permittee shall gain approval from the Regional Administrator and the Commissioner before any such studies take place. A report summarizing the results of any such studies shall be submitted to the Regional Administrator and the Commissioner regarding discharge frequency, concentration, and the impact, if any, on the indigenous populations of the receiving water. The Regional Administrator or the Commissioner may require, among other parameters, Whole Effluent Toxicity testing as part of feasibility studies.

6. Storm Water Pollution Prevention Plan (SWPPP)

- a. The permittee shall continue to implement its SWPPP. Review and updating the SWPPP shall be done at least annually. Except as provided elsewhere in this permit, the SWPPP for this facility shall provide for compliance with the terms of the permit and the plan. The SWPPP shall identify potential sources of pollution which may reasonably be expected to affect the quality of storm water discharges associated with industrial activity from this facility. In addition, the SWPPP shall describe and ensure the implementation of practices to reduce the pollutants in storm water discharges associated with industrial activity and to assure compliance with the terms and conditions of this permit. Attachment B provides the minimum requirements that must be addressed in the SWPPP for this facility.

- b. Within sixty (60) days of the effective date of this permit, the permittee shall submit to EPA and NHDES-WD a copy of its updated SWPPP.

7. Water Quality Requirements

- a. Discharges and water withdrawals shall not either cause a violation of the water quality standards or jeopardize any Class B use of the Ammonoosuc River.
- b. The thermal plumes from the station shall: (a) not block zones of fish passage, (b) not interfere with spawning of indigenous populations, (c) not change the balanced indigenous population of the receiving water, and (d) have minimal contact with surrounding shorelines.
- c. Pollutants which are not limited by the permit, but have been specifically disclosed in the last permit application, may be discharged at the frequency and level disclosed in the application, provided that such discharge does not violate sections 307 and 311 of the Act or applicable water quality standards.
- d. Discharges to the Ammonoosuc River shall be adequately treated to insure that the surface water remains free from pollutants in concentrations or combinations that settle to form harmful deposits, float as foam, debris, scum or other visible pollutants. They shall be adequately treated to insure that the surface waters remain free from pollutants which produce odor, color, taste, or turbidity in the receiving water which is not naturally occurring and would render it unsuitable for its designated uses.
- e. The effluent shall not contain metals and/or materials in concentrations or in combinations which are hazardous or toxic to aquatic life or which would impair the uses designated by the classification of the receiving waters.

8. Cooling Water Intake Structure Requirements

It has been determined that the cooling water intake structure presently designed employs the best technology available for minimizing adverse environmental impact. No change in the location, design or capacity of the present structure can be made without prior approval of the Regional Administrator and the Commissioner. The present design shall be reviewed for conformity to regulations pursuant to CWA § 316(b) at each permit renewal.

9. Other Requirements

- a. There shall be no discharge of polychlorinated biphenyl (PCB) compounds such as those commonly used for transformer fluid. The permittee shall dispose of all known PCB equipment, articles, and wastes in accordance with 40 CFR 761. The permittee shall submit to EPA and NHDES-WD a certification that this disposal has been accomplished within thirty (30) days of such disposal.
- b. Chlorine only may be used as a biocide. No other biocide shall be used without explicit approval from EPA and the Commissioner.

- c. There will be no discharge as a result of metal cleaning wastes, including washing of air precipitators, preheaters, boilers, or other types of process equipment.
- d. Wood chips, sawdust, waste ash, and other wood related debris shall not enter the Ammonoosuc River from any runoff area. These materials shall be prevented from entering the storm water collection system. All solids collection areas shall be inspected at least quarterly for compliance with this provision and, if necessary, cleaned. All debris removed from collection areas shall be disposed of according to applicable State and Federal regulations.
- e. The permittee shall comply with all existing federal, state, and local laws and regulations that apply to the reuse or disposal of solids, such as those which may be removed from the cooling towers, water and waste treatment operations and equipment cleaning. At no time shall these solids be discharged to the Ammonoosuc River.
- f. All existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Regional Administrator as soon as they know or have reason to believe (40 CFR §122.42):
  - i. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
    - (1) One hundred micrograms per liter (100 ug/l);
    - (2) Two hundred micrograms per liter (200 ug/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
    - (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR §122.21(g)(7); or
    - (4) Any other notification level established by the Regional Administrator in accordance with 40 CFR §122.44(f).
  - ii. That any activity has occurred or will occur which would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
    - (1) Five hundred micrograms per liter (500 ug/l);
    - (2) One milligram per liter (1 mg/l) for antimony;
    - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR §122.21(g)(7); or
    - (4) Any other notification level established by the Regional Administrator in accordance with 40 CFR §122.44(f).

10. Possible Permit Requirement Changes

a. Storm Water Monitoring Frequency Adjustment

If four consecutive storm water (Part I.A.4) monitoring values show compliance with the permit limits, the permittee may request to reduce monitoring for that pollutant to no less than once per year for the duration of the permit. The permittee shall submit the requests, with copies of the monitoring data, to the EPA. Until written notice is received by certified mail from the EPA indicating that the storm water monitoring requirements have been changed, the permittee is required to continue testing at the frequency specified in this permit.

b. pH Limit Adjustment

The permittee may submit a written request to the EPA requesting a change in the permitted pH limit range to be not less restrictive than 6.0 to 9.0 S.U. The permittee's written request must include the State's letter containing an original signature (no copies). The State's letter shall state that the permittee has demonstrated to the State's satisfaction that as long as discharges to the receiving water from a specific outfall are within a specific numeric pH range, the naturally occurring receiving water pH will be unaltered. That letter must specify for each outfall the associated numeric pH limit range. Until written notice is received by certified mail from the EPA indicating the pH limit range has been changed, the permittee is required to meet the permitted pH limit range in the respective permit.

c. Whole Effluent Toxicity Test Frequency Adjustment

The permittee may submit a written request to the EPA-New England requesting a reduction in the frequency of required toxicity testing to no less than once every three years, after completion of a minimum of the most recent two (2) successive toxicity tests of the yearly drain/tempering tank analysis (Part I.A.5.a), which must be valid tests and must demonstrate compliance with the  $LC50 \geq 100$  permit limit for whole effluent toxicity. Until written notice is received by certified mail from the EPA indicating that the Whole Effluent Testing requirement has been changed, the permittee is required to continue testing at the frequency specified in this permit.

11. This permit shall be modified, or alternatively, revoked and reissued to comply with any applicable standard or limitation promulgated or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:

- (1) contains different conditions or is otherwise more stringent than any effluent limitation in this permit; or
- (2) controls any pollutant not limited by this permit.

12. This permit may be modified, or alternatively, revoked and reissued to incorporate additional testing requirements, including chemical specific limits, for Outfalls 001 and 002 and the water in the drain/tempering tank, if any testing result indicates that the discharge causes or has reasonable potential to cause or contribute to an exceedance of any State water quality criterion. Results of the analyses required by this Permit are considered "New Information" and the Permit may be modified as provided in 40 CFR Section 122.62(a)(2).

**B. MONITORING AND REPORTING**

Monitoring results shall be summarized for each calendar month and reported on separate Discharge Monitoring Report Form(s) (DMRs) postmarked no later than the 15th day of the month following the completed reporting period. The permittee shall provide written explanations of all violations in DMR cover letters.

Bethlehem Power Plant may assert a business confidentiality claim with respect to part or all of the information submitted to EPA in the manner described at 40 CFR Part 2.203(b). Information covered by such a claim will be disclosed by EPA only to the extent, and by means, of the procedures set forth in 40 CFR Part 2, Subpart B. If no such claim accompanies the information when it is submitted to EPA, it may be made available to the public by EPA without further notice to Bethlehem Power Plant. Effluent information shall not be regarded as confidential.

Signed and dated originals of the DMRs, and all other reports required herein or in Part II, shall be submitted to the Director at the following addresses:

U.S. Environmental Protection Agency  
Water Technical Unit (SEW)  
P.O. Box 8127  
Boston, Massachusetts 02114-8127

All 24 hour notifications (Part I.A.3.a) shall be made to Sharon Zaya at phone number 617-918-1995. All permit change requests shall be directed to the Industrial Permits Branch, One Congress Street, Suite 1100 (CIP), Boston, Massachusetts 02114.

In addition, duplicate signed copies of all DMRs and all other notifications and reports required by this permit shall be submitted to the State at:

New Hampshire Department of Environmental Services  
Water Division  
Wastewater Engineering Bureau  
29 Hazen Drive, P.O. Box 95  
Concord, New Hampshire 03302-0095

**C. STATE PERMIT CONDITIONS**

The permittee shall comply with the following conditions which are included as State Certification requirements.

The pH range of 6.5-8.0 S.U. must be achieved in the final effluent unless the permittee can demonstrate to NHDES-WD: (1) that the range should be widened due to naturally occurring conditions in the receiving water, or (2) that the naturally occurring source water pH is unaltered by the permittee's operations. The scope of any demonstration project must receive prior approval from NHDES-WD. In no case, shall the above procedure result in pH limits less restrictive than applicable federal effluent limitation guideline(s) published in the CFRs.

This NPDES Discharge Permit is issued by the U.S. Environmental Protection Agency under Federal and State law. Upon final issuance by the EPA, the NHDES-WD may adopt this permit, including all terms and conditions, as a State permit pursuant to RSA 485-A:13.

Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of the Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation.

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
NEW ENGLAND - REGION I  
ONE CONGRESS STREET  
BOSTON, MASSACHUSETTS 02114

FACT SHEET

**DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
PERMIT TO DISCHARGE TO WATERS OF THE UNITED STATES**

NPDES PERMIT NO.: **NH0021423**

NAME AND ADDRESS OF APPLICANT:

**SUEZ Energy NA, Inc.  
1241 Whitefield Road  
Bethlehem, NH 03574**

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

**Bethlehem Power Plant  
1241 Whitefield Road  
Bethlehem, NH 03574**

SIC CODE: **4911** NAICS Code(s): **221112**

RECEIVING WATER: **Ammonoosuc River (Hydrologic Basin Code: 01040001)**

CLASSIFICATION: **Class B**

CURRENT PERMIT ISSUED: **12-19-1986**  
EXPIRED: **12-19-1991**  
RE-APPLICATION: **7-03-1991**

**Table of Contents**

1.0 Type of Facility, Discharge Location and Proposed Action ..... 1

2.0 Description of Discharge ..... 2

3.0 Permit Limits and Conditions ..... 2

4.0 Basis of Permit Limits ..... 2

    4.1 Permit Limits, Generally ..... 2

    4.2 Facility Information ..... 5

    4.3 Derivation of Effluent Limits ..... 6

        4.3.1 Limits for Conventional Pollutants ..... 6

        4.3.2 Limits for Nonconventional and Toxic Pollutants ..... 7

        4.3.3 Whole Effluent Toxicity ..... 9

        4.3.4 Water Treatment Chemicals (WTCs) ..... 10

        4.3.5 Storm Water ..... 11

5.0 Cooling Water Intake Structure -CWA § 316(b) ..... 13

6.0 Antidegradation ..... 14

7.0 Essential Fish Habitat ..... 14

8.0 Monitoring Frequency ..... 15

9.0 State Certification Requirements ..... 15

10.0 General Conditions and Definitions ..... 16

11.0 Comment Period, Hearing Requests, and Procedures for Final Decisions ..... 16

12.0 EPA Contact ..... 17

---

Attachment A - Effluent Concentrations

Attachment B - Site Location Map

Attachment C - Water-balance Line Diagram

Attachment D - Pertinent Equations

Attachment E - Toxicity Strategy for Municipal Permits

## 1.0 Type of Facility, Discharge Location and Proposed Action

Bethlehem Power Plant (BPP), located in Bethlehem, New Hampshire, is a 17 gross-megawatt (MW) woodchip-fired electrical generation facility (referred to hereafter as either Bethlehem Power Plant (BPP), the Station or the Facility). The Station is a "base-load" facility, having an average yearly capacity utilization rate of 98.1% for the past five years. Electricity is generated by means of one 15 MW<sub>net</sub> wood-fired steam turbine unit, which began commercial operation on December 18, 1986.

Bethlehem Power Plant's current National Pollutant Discharge Elimination System (NPDES) Permit allows the discharge of pollutants to the adjacent Ammonoosuc River. Mechanical draft cooling towers are used to recycle non-contact condenser cooling water. BPP is permitted to discharge cooling tower wastewater mixed with other process wastes and stormwater. BPP discharges stormwater through one outfall location, although the current permit (issued in 1986) indicates there are two locations.<sup>1</sup> Stormwater runoff is from the land adjacent to the facility, roadways, and vehicle parking areas. Although BPP has not needed to discharge any cooling/process water since it began operating in 1986<sup>2</sup>, the Station requests that it continues to have the option of discharging during emergencies.

Under the Clean Water Act (CWA) §§ 301(a), 316 and 402, Bethlehem Power Plant's pollutant discharges must receive authorization from a NPDES permit issued by the U.S. Environmental Protection Agency (EPA). EPA may not issue a permit for BPP unless the New Hampshire Department of Environmental Services (NH DES) either certifies that the effluent limitations and/or conditions contained in the permit are stringent enough to assure, among other things, that the discharge will not cause the receiving water to violate the New Hampshire Surface Water Quality Regulations (NH-Standards) or waives its right to certify as set forth in 40 CFR §124.53. Bethlehem Power Plant has in the past obtained the necessary federal permits and state certifications. EPA last reissued the Station's federal permit number NH0021423 on December 19, 1986. This permit expired on December 19, 1991. The permit was administratively continued, however, because the Station timely applied for permit reissuance. As a result, Bethlehem Power Plant remains subject to the existing permit until EPA issues it a new one.

EPA received Bethlehem Power Plant's application for reissuance of the Facility's NPDES permit on July 3, 1991. EPA currently intends to reissue the Facility's NPDES permit. This Draft Permit proposes to continue to authorize the discharge of storm and cooling/process water.

---

<sup>1</sup> Consequently, storm water outfall 003 was removed from the Draft Permit.

<sup>2</sup> The only discharge from this facility since operations began was in 1991 to perform a benthic macrovertebrate study. Effluent was discharged at a rate of 30 gpm for two hours.

## **2.0 Description of Discharge**

Refer to Section 4.2 of this Fact Sheet for a description of the discharges associated with each outfall location. A schematic drawing of the flow of water at the facility and the various discharges from the facility is presented in Attachment C. A site location plan is presented in Attachment B.

## **3.0 Permit Limits and Conditions**

The Draft Permit's proposed effluent discharge and cooling water intake limits, monitoring requirements, and implementation schedules may be found in Part I (Effluent Limitations and Monitoring Requirements) of the Draft Permit.

## **4.0 Basis of Permit Limits**

### **4.1 Permit Limits, Generally**

The CWA prohibits the discharge of pollutants from point sources to waters of the United States without authorization from a NPDES permit, unless the CWA specifically exempts a particular type of point source discharge from requiring a permit. The NPDES permit is the mechanism used to apply the CWA's pollution control standards and monitoring and reporting requirements directly to particular facilities. This draft NPDES permit was developed in accordance with the CWA, EPA regulations promulgated thereunder, and any other applicable federal and state legal requirements. The regulations governing the EPA NPDES permit program are generally found at 40 C.F.R. Parts 122, 124, 125, and 136.

When developing permit limits, EPA must apply both technology-based and water quality-based requirements. To the extent that both may apply, whichever is more stringent governs the permit limits. Criteria and standards for the imposition of technology-based treatment requirements in permits under Section 301(b) of the CWA, including the application of EPA-promulgated effluent limitations and case-by-case determinations of effluent limitations under Section 402(a)(1) of the CWA, are set out in 40 C.F.R. Part 125, Subpart A. Development of water quality-based permit limits is addressed in, among other provisions, CWA §§ 301(b)(1)(C) and 401, as well as 40 C.F.R. §§ 122.4, 122.44, 124.53 and 124.55.

Technology-based treatment requirements represent the minimum level of control that must be imposed under Sections 301(b) and 402 of the CWA (see 40 C.F.R. §125 Subpart A) to meet best practicable control technology currently available (BPT) for certain conventional pollutants, best conventional control technology (BCT) for conventional pollutants, and best available technology economically achievable (BAT) for toxic and non-conventional pollutants. The technology-based guidelines for industrial dischargers can be found at 40 CFR Parts 400 - 471 and represent the minimum level of control that must be imposed under section 301(b) and 402 of the CWA (See 40 CFR Part 125, Subpart A). In the absence of published technology-based

effluent guidelines, the permit writer is authorized under Section 402(a)(1)(B) of the CWA to establish appropriate technology-based effluent limitations (*e.g.*, BAT limits) on a case-by-case basis using best professional judgement (BPJ). [See also 40 C.F.R. § 125.3.] The effluent guidelines for steam electric power plants are specific for fossil fuel or nuclear fuel facilities but do not include wood fuel units. Therefore, the effluent guidelines which represent BPT and BAT as set forth in 40 CFR Part 423 are not applicable to these types of units. However, since the discharges from wood fuel units are similar to fossil fuel units, the Steam Electric Power Generating Guidelines may serve as guidance for establishing effluent limitations for those types of discharges. Therefore, limitations for wood fuel units may be based on BPT and BAT requirements established in the Federal Guidelines for the Steam Electric Power Generating Point Source Category (40 CFR Part 423) using EPA's BPJ authority.

Water-quality based limitations are required in NPDES permits when EPA and the State determine that effluent limits more stringent than technology-based limits are necessary to maintain or achieve state or federal water-quality standards. See CWA §§ 301(b)(1)(C) and 401. State Water Quality Standards provide a classification for all the water bodies in the state and specify the "designated uses" and numeric and narrative water quality criteria that water bodies in each classification should be able to achieve. The NH-Standards include a narrative statement that prohibits the discharge of any pollutant or combination of pollutants in quantities that would be toxic or injurious to human health or aquatic life. In addition, the State has adopted EPA's numerical criteria for specific toxic pollutants and toxicity criteria. State Water Quality Standards also contain antidegradation requirements to ensure that once a use is attained it will not be degraded. Permit limits must then be devised so that discharges do not cause violations of these Water Quality Standards.

The permit must limit any pollutant or pollutant parameter (conventional, non-conventional, toxic and whole effluent toxicity) that is or may be discharged at a level that causes, or has the "reasonable potential" to cause or contribute to, an excursion above any water-quality criterion. See C.F.R. § 122.44(d)(1). An excursion would occur if the projected or actual in-stream concentration exceeds the applicable criterion. In determining "reasonable potential," EPA considers: (1) existing controls on point and non-point sources of pollution; (2) pollutant concentrations and variability in the effluent and receiving water as determined from the permit application, the permittee's monthly Discharge Monitoring Reports (DMRs), and State and Federal Water Quality Reports; (3) the sensitivity of the species to toxicity testing; (4) the known water quality impacts of processes on wastewater; and, where appropriate, (5) the dilution of the effluent that would be provided by the receiving water.

In accordance with State regulations [N.H. Code of Administrative Rules, PART Env-Ws 1705.02], the flow used to calculate permit limits for facilities on rivers or streams is based on a known or estimated value of the annual seven (7) consecutive-day mean low flow at the 10-year recurrence interval (7Q10) for aquatic life and human health (non-carcinogens only) in the receiving water. Furthermore, 10 percent (%) of the receiving water's assimilative capacity is held in reserve for future needs in accordance with New Hampshire's Surface Water Quality

Regulations Env-Ws 1705.01. The current set of New Hampshire Surface Water Quality Regulations were adopted on December 3, 1999, and became effective on December 10, 1999.

When using chemical-specific numeric criteria to develop permit limits, both the acute and chronic aquatic-life criteria, expressed in terms of maximum allowable in-stream pollutant concentrations, are used. Acute aquatic-life criteria are considered applicable to daily time periods (maximum daily limit) and chronic aquatic-life criteria are considered applicable to monthly time periods (average monthly limit). Chemical-specific limits are allowed under 40 C.F.R. § 122.44(d)(1) and are implemented under 40 C.F.R. § 122.45(d). In the Draft Permit for Bethlehem Power Plant, the Region has established, pursuant to 40 C.F.R. § 122.45(d)(1), maximum daily and average monthly discharge limits for specific chemical pollutants to satisfy Water Quality Standards.

Under CWA § 401, EPA may not issue a NPDES permit unless it first obtains a certification from the state confirming that all water-quality standards will be satisfied or the state waives its certification rights. If the state issues a certification with conditions, then the permit must conform to the conditions. See 40 C.F.R. §§ 124.53 and 124.55.

The Draft Permit's effluent monitoring requirements have been established under the authority of CWA §§ 308(a) and 402(a)(2) and in accordance with 40 C.F.R. §§ 122.41(j), 122.44(i) and 122.48. The monitoring program in the permit specifies routine sampling and analysis which will provide continuous, representative information on the levels of regulated materials in the waste water discharge streams. The approved analytical procedures are to be found in 40 C.F.R. Part 136 unless other procedures are explicitly required in the permit.

The CWA's anti-backsliding requirements prohibit a NPDES permit from being renewed, reissued or modified with less stringent limitations or conditions than those contained in the previous permit unless an exception to the anti-backsliding requirements applies. See CWA §§ 402(o) and 303(d)(4) and 40 C.F.R. § 122.44(l)(1) and (2). EPA's anti-backsliding provisions found at 40 C.F.R. § 122.44(l) generally prohibit the relaxation of permit limits, standards, and conditions. Considering that (1) the Facility has not needed to discharge process water in 20 years of operation, (2) they will only discharge during emergency situations, and (3) the sampling frequency for all parameters in the Draft Permit (outfall 001-process) has been changed to "each discharge event," the average monthly limits for outfall 001 have been removed from the Draft Permit. EPA has made this change based on new information since the last permit issuance. The last permit was issued when the plant was built and when it was believed that there would be a regular discharge of process wastewater to the river. Furthermore, the Facility has never had an emergency where a discharge was necessary. Therefore, it is unlikely that two or more emergencies would occur within one months time. The change in the Draft Permit is considered more representative of actual conditions at the plant. If two emergency discharges did somehow occur within one month, the permittee is required to sample each discharge event and meet maximum daily limits.

In addition to technology-based and water quality-based requirements, limits for thermal discharges may potentially be based on a variance from such requirements under CWA § 316(a). Section 4.3.2 includes a discussion about temperature limits. Furthermore, permit limits on cooling water withdrawals may be imposed in a NDPEs permit under CWA § 316(b). The requirements of CWA § (b) are discussed in further detail in Section 5 of this Fact Sheet.

The permit must also satisfy the requirements of the Endangered Species Act (ESA) and the Essential Fish Habitat (EFH) provisions of the 1996 Amendments (PL 104-297) to the Magnuson-Stevens Fishery Conservation and Management Act (16 U.S.C. § 1801 et seq. (1998)). There are no endangered species located in the Ammonoosuc River and EFH requirements are discussed further in Section 7 of this Fact Sheet.

#### **4.2 Facility Information**

The Station is located on the north bank of the Ammonoosuc River in Bethlehem, New Hampshire. See Attachment B for a map showing the geographical location of the facility. As previously discussed, the plant uses wood chips as fuel to generate approximately 15 Megawatts of electric power. Heat resulting from incineration of the wood chips produces steam in the boiler. Steam is used to power a turbine electric generator which produces electric power for commercial sale. The turbine exhaust is directed to the surface condenser (non-contact) to convert the steam to water for reuse in the boiler. A two-cell mechanical draft cooling tower (180,000 gallon capacity) is used to cool and recirculate cooling water through the condenser.

Water used for domestic purposes at the facility is withdrawn from four artesian wells and discharged to a septic system. Cooling tower make-up water is taken from the Ammonoosuc River. Depending on the time of year, the Station may need up to 165,000 gallons per day. On hot days the cooling tower may evaporate an estimated 200 gallons per minute.

There are two intake structures located five feet apart, imbedded in the middle of the river and flush with the river bottom. Each intake structure consists of a small excavated area covered with a 2' by 4' Johnson (aka wedgewire) screen. The screens are made of stainless steel and have a mesh size of 0.03 inches (0.76 mm). Water flows by gravity through the screens and then through a 10 inch pipe to a below ground sump located on the bank of the river. The gravity feed rate is approximately 450 gpm depending on the height of the river. Station personnel clean the intake screens of rocks and debris twice per year or more if flow is impeded. No aquatic organisms have ever been observed on the screens. (personal communication between Sharon Zaya, EPA and Mark Driscoll, Plant Manager on July 5, 2006) The sump's capacity is 50,000 gallons. Three variable drive pumps are used to transfer sump water up to the Station. There are two 300 gpm and one 200 gpm maximum capacity pumps, although only one pump at a time is used to transfer water. Water is continually recirculated in the sump until needed.

River water is pumped up to a "drain/tempering" tank at maximum rate of 300 gpm prior to its use in the cooling tower. Other wastewater streams from the station are directed to this tank including: boiler blowdown, sandfilter backwash, demineralizer regeneration, mechanical

equipment cooling, cooling tower “graver” treatment filtrate (blowdown), artesian well flushing (2-3 hours/month), condenser cleaning<sup>3</sup>, laboratory wastewater and other miscellaneous floor drain wastes. The cooling tower is used to remove heat from the condenser non-contact cooling water in a closed-looped system. When needed because of evaporation, water is pumped from the drain/tempering tank to the towers. A schematic drawing of the flow of water at the facility and the various discharges from the facility is presented in Attachment C. Every three to five years, solids are removed from the tempering tank. Solids are removed from the cooling tower water by a side-stream softener system called “graver”. The filtrate from this system, containing tower treatment chemicals, is directed to the tempering tank (at 50 gpm) and the solids are removed for off-site disposal.

There are four underground storage tanks (each with 37,500 gallon capacity) that are also used to store cooling/process water. Usually, two of the tanks remain full in case water is needed and two tanks are kept empty for internal wastestream discharges (i.e. boiler blowdowns) when needed. These tanks are filled during an outage to perform maintenance on the cooling system.

The drain/tempering tank has three 50 gpm pumps that are used to transfer water to the cooling towers, storage tanks, or the discharge line. Therefore a maximum flow rate of 150 gpm may be discharged to the Ammonoosuc River. An eight inch pipe is used for the discharge. In case of an emergency discharge, samples would be collected from a manhole located about ten feet from the river. Historically, the only discharge to the Ammonoosuc River of cooling/process waste was in 1991 to conduct a benthic macroinvertebrate study in the receiving stream. Although BPP has never needed to discharge since the Station began operations in 1986, the company requests that it continues to have the option of discharging during emergencies.

### **4.3 Derivation of Effluent Limits**

#### **4.3.1 Limits for Conventional Pollutants**

Limitations for conventional pollutants in the Draft Permit (pH, Oil and Grease, and Total Suspended Solids) are based upon those in the existing permit in accordance with the antibacksliding requirements found in 40 CFR §122.44.

The maximum daily flow limit of 0.72 MGD in the current permit has been reduced to 0.20 MGD in the Draft Permit to reflect the actual need of the facility should an emergency situation arise.

Limits for Total Suspended Solids (TSS) and Oil & Grease (O&G) were originally established based on Best Practicable Control Technology (BPT) requirements established in the Federal Guidelines for the Steam Electric Power Generating Point Source Category (40 CFR Part 423.12) using EPA’s BPJ authority.

---

<sup>3</sup> Plugs are used to clean the condenser tubes. The solids are collected and disposed of off-site. The filtrate and rinse waters are directed to the recirculating cooling system.

The pH limits are based on New Hampshire's Surface Water Quality Regulations Env-Ws 1703.18 and New Hampshire's State statutes (N.H. RSA 485-A:8). Language has been added to the Draft Permit that allows for a change in pH limit(s) under certain conditions for process wastewater flows. A change would be considered if the applicant can demonstrate to the satisfaction of the New Hampshire Department of Environmental Services, Water Division (NHDES-WD) that the in-stream pH standard will be protected when the discharge is outside the permitted range. At that time, the applicant or NHDES-WD may request (in writing) that the permit limits be modified by EPA to incorporate the results of the demonstration.

Anticipating the situation where NHDES-WD grants a formal approval changing the pH limit(s) to outside the 6.5 to 8.0 Standard Units (S.U.), EPA added a provision to the Draft Permit allowing EPA to modify the pH limit(s) using a certified letter approach. (See Part I.A.10.b of the Draft Permit) This change would be allowed as long as it can be demonstrated that the revised pH limit range does not alter the naturally occurring receiving water pH. However, the pH limit range shall not be less restrictive than 6.0 - 9.0 S.U. as found in the National Effluent Limitation Guideline (Steam Electric Power Generating Point Source Category at 40 CFR §423.12(b)(1)).

If the State approves results from a pH demonstration study, the permit's pH limit range can be relaxed in accordance with 40 CFR 122.44(1)(2)(i)(B), based on new information not available at the time of this permit's issuance. This new information includes results from the pH demonstration study that justifies the application of a less stringent effluent limitation. EPA anticipates that the limit determined from the demonstration study, as approved by the NHDES-WD, would satisfy all effluent requirements for this discharge category and would comply with NH-Standards.

#### **4.3.2 Limits for Nonconventional and Toxic Pollutants**

##### Total Residual Chlorine

The limit for Total Residual Chlorine (TRC) is based on the existing permit in accordance with the antibacksliding requirements found in 40 CFR §122.44. This limit was originally established based on Best Available Technology Economically Achievable (BAT) requirements established in the Federal Guidelines for the Steam Electric Power Generating Point Source Category (40 CFR Part 423.13) using EPA's BPJ authority.

##### Metals

Limits for 126 priority pollutants<sup>4</sup>, total chromium and total zinc have been added to the Draft

---

<sup>4</sup> The 126 priority pollutants (See 40 C.F.R. 423 Appendix A) are those potentially contained in chemicals added for cooling tower maintenance. No detectable amount is allowed in the discharge. As per the effluent guidelines and included in the Draft Permit, compliance may be determined by engineering calculations.

Permit based on Best Available Technology Economically Achievable (BAT) requirements established in the Federal Guidelines for the Steam Electric Power Generating Point Source Category (40 CFR Part 423.13(d)(1) for cooling tower blowdown) using EPA's BPJ authority.

The iron limit is based on the limit in the existing permit in accordance with the antibacksliding requirements found in 40 CFR §122.44.

The total recoverable copper limit has been updated based on new information, including a change in the NH-Standards, an update 7Q10 assessment, and a maximum daily limit of 0.2 MGD (from 0.72). A recomputation of the maximum daily copper limit to account for these changes shows a higher copper limit than the existing limit. This relaxation of the permit limit meets the anti-backsliding exemptions found at 40 C.F.R. 122.44(l)(2)(i)(B).

The maximum daily copper limit in the Draft Permit is based on the acute aquatic-life criteria, found in the current NH-Standards, multiplied by the appropriate available dilution of the receiving water. An available dilution of 93.5 for the maximum daily limit was developed for an emergency process flow event from the drain/tempering tank (Outfall 001). A maximum flow of 0.2 million gallons per day (MGD) was used, along with an estimate of the 7Q10 low flow of 32.2 cubic feet per second (cfs)<sup>5</sup> (20.8 MGD) in the Ammonoosuc River just above the facility's outfall, and a 10 % set aside or reserve (Env-Ws 1705.01). See Attachment D for equation to calculate available dilution.

NH-Standards for metals such as copper are in terms of dissolved metal. However, EPA is required by 40 CFR 122.45(c) to regulate the total recoverable metals. Therefore, to convert the dissolved metal acute aquatic-life criteria to total recoverable metal, a default translator equal to the conversion factor found in Table 1703.2 of the NH-Standards was used. The default factor used assumes a receiving water hardness of 25 mg/l unless the permittee can show that different translator and hardness values are more appropriate. Accordingly, the dissolved metal standard found in Env-Ws 1703.21(b), Table 1703.1 is divided by the appropriate conversion factor (Table 1703.2) prior to deriving the appropriate total recoverable acute aquatic-life criteria. In this case, the conversion factor for acute copper is 0.96 and the acute aquatic-life criteria is 3.6 ug/l prior to the division by the conversion factor. This is consistent with the recommendations contained in Section 1.5 of the Metals Translator Guidance cited at the end of this paragraph. If there is disagreement with the above assessment, the permittee has the option of performing additional sampling of the effluent, receiving waters and effluent/receiving water mixtures in order to develop site-specific partition coefficients for these metals using the procedures described in "The Metals Translator: Guidance for Calculating A Total Recoverable Permit Limit From A Dissolved Criterion," EPA, Office of Water, EPA 823-B-96-007, June 1996." For Total Recoverable Copper, EPA calculated a maximum daily limit of 0.35 mg/l. (See Attachment D for the equation used in this calculation).

---

<sup>5</sup> See August 9, 2005 memo from Jeff Andrews, NHDES to Janson Turgeon, EPA indicating that the 7Q10 was "[r]ecalculated in 2000 by DES by using the ratio of the drainage are[a] between the facility and the upstream gage."

The boiler, preheaters and air precipitator at BPP are physically dry cleaned. Solids are mixed with bottom ash and landfilled. Therefore, the Draft Permit includes a provision that prohibits the discharge of metal cleaning wastes.

Based on available dilution, EPA has determined that there is no reasonable potential for other metals or toxic pollutants in the discharge to cause an exceedence of NH-Standards.

### Temperature

The temperature limit of 85 degrees Fahrenheit (°F) and a temperature change ( $\Delta T$ ) of 20 °F in the Draft Permit meets the narrative temperature criteria of the NH-Standards [Env-Ws 1703.13(b)]. Performing an energy balance on this facility's discharge using the river's temperature extremes, its 7Q10 flow likely to occur during either the summer or the winter low-flow periods, and the facility's maximum discharge temperature indicates that this facility's thermal discharge would cause an indiscernible rise in the ambient streamflow temperature. For example, assuming that during the summer and the winter low-flow periods, the in-stream ambient temperatures just above the outfall are 70 °F and 35 °F, respectively, and that the 7Q10 flow is 29 cfs (includes the reduction for the State's 10 percent reserve rule [Env-Ws 1705.01]), the 85 °F thermal discharge will only cause an increase in receiving water temperatures of 0.2 and 0.5 °F, respectively, over ambient conditions (See Attachment D for the energy balance equation). Complete mixing is assumed in this case because the river flow is rapid and turbulent in the area of the discharge. In addition, the discharge temperature is expected to be lower than the 85 °F limit because the discharge originates from the drain/tempering tank and not directly from the cooling tower. Furthermore, EPA has determined that, for this facility, the best available technology (BAT) for thermal pollution control is the use of its cooling towers. Therefore, there is no need for a 316(a) variance from this technology standard.

### **4.3.3 Whole Effluent Toxicity**

In order to protect the Anadromous Fish Program by assuring that Bethlehem Power Plant does not discharge an effluent of toxic nature into the Ammonoosuc River, EPA-New England has included Whole Effluent Toxicity (WET) testing in the Draft Permit. EPA believes this is warranted given the discharge has reasonable potential to contain Water Treatment Chemicals (WTCs) used in the boiler water and cooling system which may be toxic to aquatic organisms if released in sufficient concentrations.

New Hampshire law states that, "all surface waters shall be free from toxic substances or chemical constituents in concentrations or combination that injure or are inimical to plants, animals, humans, or aquatic life;...." (N.H. RSA 485-A:8, VI and the N.H. Code of Administrative Rules, PART Env-WS 1703.21(a)(1)). The federal NPDES regulations at 40 CFR §122.44(d)(1)(v) require whole effluent toxicity limits in a permit when a discharge has a "reasonable potential" to cause or contribute to an excursion above the State's narrative criterion for toxicity. Where EPA - New England believes toxicity testing is appropriate and necessary as

described above, the type of toxicity testing (acute and/or chronic) and the effluent limitation (LC50 and/or C-NOEC) are set based upon available dilution as outlined in Attachment D. When WET limits are required for industrial dischargers such as this facility, EPA-New England adopts those limits from the Toxicity Strategy for Municipal Permits (Attachment E).

Based upon available dilution and in accordance with EPA-New England's Toxicity Policy, an acute limit of LC50 using a sample of 100 percent effluent is added to the Draft Permit. LC50 is defined as the concentration of toxicant, or in this case, as percentage of effluent that would be lethal to 50 % of the test organisms during a specific time period. The Acute-No Observed Effect Concentration (A-NOEC) monitoring-only requirement is included in the Draft Permit due to the potential presences of WTCs in the discharge.

Results of these toxicity tests will demonstrate compliance with the no toxic provision of the NH-Standards. The Draft Permit includes the WET testing requirement for each discharge event. The acute WET test calls for 48 hour testing using the species Daphnid (Ceriodaphnia dubia) and Fathead Minnow (Pimephales promelas). Results from these tests will provide the EPA, the State and the permittee with an estimate of the overall toxic content of its discharge. If toxicity violations are shown, monitoring frequency and testing requirements may be increased in addition to enforcement actions. The permit may also be modified, or alternatively, revoked and reissued to incorporate additional toxicity testing requirements or chemical specific limit(s).

This Draft Permit requires reporting of selected parameters determined from the chemical analysis of the WET tests 100 % effluent sample. Specifically, Ammonia Nitrogen as Nitrogen, Hardness, and Total Recoverable Cadmium, Copper, Chromium, Lead, Nickel and Zinc are to be reported on the appropriate Discharge Monitoring Report (DMR) for entry into EPA's Permit Compliance System's Data Base. EPA-New England does not consider these reporting requirements an unnecessary burden as reporting these constituents is required with the submission of each toxicity testing report. (See Draft Permit, Attachment A, page A-8.)

#### **4.3.4 Water Treatment Chemicals (WTCs)**

This facility operates its cooling tower and steam condenser system as a continuous recycle, closed-loop system resulting in no discharge to the receiving water. However, cooling tower blowdown, boiler blowdown, and other process wastewater may be discharged from Bethlehem Power Plant through Outfall 001 (drain/tempering tank) during an emergency. Given the nature of the possibly sudden and infrequent discharge, EPA-New England is concerned about the potential build-up of toxic substances in the drain/tempering tank. Water treatment chemicals are added to both the cooling water and the boiler water, therefore the blowdown wastewater contains these chemicals. Thus, monitoring water in the drain/tempering tank would lend insight into whether or not there is potential for the discharge of toxic substances in the process waste through Outfall 001.

Consequently, EPA has required that every July, the permittee must collect a representative sample of water from the drain/tempering tank and perform, on that sample, a: 48-Hour static

acute WET test using two species, Daphnid (Ceriodaphnia dubia) and the Fathead Minnow (Pimephales promelas) as previously described.

EPA-New England believes this approach is necessary to monitor for the potential build up, if any, of toxic substances in the drain/tempering tank due to the facility's method of operation and in order to prevent future exceedances in permitted limits and/or in-stream NH-Standards should the tempering tank need to be suddenly drained. Furthermore, when an emergency discharge situation occurs, there will be little or no opportunity to evaluate this effluent's ability to meet permitted limits and/or in stream NH-Standards. Therefore, EPA-New England decided to take the proactive stance outlined above to be prepared for the onset of an "emergency discharge" situation if and when it occurs. Results of these analyses are considered "New Information" and could result in additional limits and/or monitoring requirements for Outfall 001 (process wastewater).

Should BPP discharge the contents of the drain/tempering tank, the flow rate shall not exceed 150 gpm as required by the Draft Permit. At this flow rate, the effluent adds a one percent increase over the 7Q10 flow levels after accounting for the State's 10 percent reserve rule. At 150 gpm discharge rate, it will take approximately 24 hours to completely empty the tank of its 140,000 gallon contents. Monitoring for all parameters including performing a WET test is required during any discharge.

#### 4.3.5 Storm Water

##### Effluent Limitations

Since EPA has not promulgated any guidelines for storm water discharge from wood burning power plants, EPA is using the following approach in this Draft Permit: (1) continue the existing permit's storm water limit for Oil & Grease in the Draft Permit in accordance with the antibacksliding requirements found in 40 CFR §122.44; (2) adding monitoring with a maximum discharge limit for iron based on the 2006 Draft Multi-Sector General Permit for Stormwater Discharges Associated with Industrial Activities<sup>6</sup> (MSGP); (3) continue TSS monitoring but adding a maximum discharge limit based on the 2006 Draft MSGP; and (4) require the permittee to annually update its Storm Water Pollution Prevention Plan (SWPPP) for its storm water discharges.

A provision has been added to the Draft Permit, similar to that required by the 2006 Draft MSGP, which allows for a reduction in monitoring if four consecutive monitoring values show compliance with the permit limits.

---

<sup>6</sup> Federal Register, Vol. 70, No. 230, December, 1, 2005, p. 72116 - 72120.

### Storm Water Pollution Prevention Plan

Pursuant to Section 304(e) of the CWA and 40 C.F.R. §125.103(b), Best Management Practices (BMP) may be expressly incorporated into a permit on a case-by-case basis where necessary to carry out Section 402(a)(1) of the CWA. This facility engages in activities which could result in the discharge of toxic and hazardous pollutants to waters of the United States either directly or indirectly through storm water runoff. These operations include at least one of the following from which there is or could be site runoff: material storage, in-facility transfer, material processing, material handling, or loading and unloading. The permit requires this facility to update its SWPPP which includes Best Management Practices appropriate for this specific facility to control storm water discharges from these and other activities which could contribute pollutants to waters of the United States, potentially violating the State's Water Quality Standards. Specifically, at this facility, waste ash and wood chip storage areas are examples of material storage, processing and handling operations that shall continue to be included in the SWPPP.

The goal of the SWPPP is to eliminate or reduce the potential for the discharge of pollutants through the storm water system. In the event the potential cannot be eliminated, the permittee should select BMPs to reduce, to the maximum extent possible, the pollutant loading to the receiving water. The SWPPP requirements direct the permittee to review the physical equipment, the operational procedures, and the operator training at the facility. The objective of this review is to protect waters of the United States by eliminating or minimizing the potential discharge of any pollutants.

The SWPPP requirements in the Draft Permit are intended to facilitate a process whereby the permittee thoroughly evaluates potential pollution sources at the power plant, and following that, selects and implements appropriate measures necessary to prevent or control the discharge of those potential pollutants in storm water runoff.

This process involves the following four main steps: (1) forming a team of qualified facility personnel who will be responsible for updating the SWPPP and assisting the plant manager in its implementation; (2) reassessing the potential storm water pollution sources; (3) selecting and implementing appropriate management practices and controls for these potential pollution sources; and (4) reevaluating, periodically, the effectiveness of the SWPPP in preventing storm water contamination and in complying with the various terms and conditions of the Draft Permit.

The Draft Permit requires the permittee to update and submit the SWPPP no later than 60 days after the permit's effective date and continue to implement the plan throughout the duration of the permit. The SWPPP is a supporting element to any numerical effluent limitation by minimizing the discharge of pollutants through proper operation of the facility. Consequently, the SWPPP is as equally enforceable as the numerical limits on the storm water discharges. EPA has developed a Multi-Sector General Permit for Stormwater Discharges Associated with

Industrial Activities, which includes the Timber Products (Sector A) and Steam Electric Power Generating (Sector O) categories, that while not directly applicable to this facility, have components in their individual SWPPP that are potentially applicable to this facility. For example, in the Steam Electric category, runoff from coal piles is akin to runoff from waste ash piles; while, in the Timber Products category, runoff from log storage and handling areas is akin to runoff from wood chip storage areas. Therefore, the permittee is encouraged to review both SWPPP plans which can be found in the Federal Register, Vol. 70., No. 230, December 1, 2005, p. 72116 - 72120.

## 5.0 Cooling Water Intake Structure -CWA § 316(b)

With any NPDES permit issuance or reissuance, EPA is required to evaluate or re-evaluate compliance with applicable standards, including those stated in Clean Water Act (CWA) Section CWA §316(b) regarding cooling water intake structures. CWA §316(b) applies if the permit applicant seeks to withdraw cooling water from a water of the United States. To satisfy §316(b) the permit applicant must demonstrate to the satisfaction of the EPA (or, if appropriate, the State) that the location, design, construction, and capacity of the facility's cooling water intake structure(s) (CWIS) reflect the Best Technology Available (BTA) for minimizing adverse environmental impacts. Such impacts include death or injury to aquatic organisms by impingement (being pinned against screens or other parts of a cooling water intake structure) or entrainment (being drawn into cooling water systems and subjected to thermal, physical or chemical stresses).

EPA has promulgated final §316(b) regulations providing specific technology standard requirements for the following:

1. new power plants and other types of new facilities with CWISs (so-called "Phase I" facilities). 66 Fed. Reg. 65255 (Dec. 18, 2001) (effective date of the regulations is January 17, 2002);
2. existing power plants with flows of 50 million gallons per day or more ("Phase II" facilities). 69 Fed. Reg. 41576 (July 9, 2004) (effective date is September 7, 2004); and
3. new offshore oil and gas extraction facilities that have a design intake flow threshold of greater than 2 million gallons per day ("Phase III" facilities). 71 Fed. Reg. 35006 (June 16, 2006) (effective date is July 17, 2006).

These regulations do not, however, apply to existing *small* power plants such as Bethlehem Power Plant (or to existing manufacturing facilities). Instead, EPA continues to rely upon the existing NPDES program, which implements section 316(b) for these facilities on a case-by-case, best professional judgment basis. See 40 C.F.R. § 125.90(b). EPA has determined that BPP's CWIS presently employs the best technology available for minimizing adverse environmental impact for the reasons presented below.

### "Location"

Bethlehem Power Plant's CWIS is imbedded in the stream bed, flush with the bottom, in the

middle of the Ammonoosuc River. The river water flow rate at this location is rapid at all times. For this reason, it is unlikely that fish or any other aquatic organisms would be impinged. Mark Driscoll, Plant Manager of BPP indicated that no aquatic organisms have ever been observed on the screens (personal communication with Sharon Zaya, EPA and on July 5, 2006). Furthermore, the segment of the river in Bethlehem, NH, where the facility is located, is not a preferred location for spawning of salmon or other indigenous species. As a transient area only, there is little potential for entrainment of eggs and larvae.

#### *“Design and Construction”*

Bethlehem Power Plant's CWIS consists of two embedded chambers in the stream bed, covered with 2' by 4', 0.76 mm mesh wedgewire screens. This size mesh reduces entrainment of larvae and certain eggs. Water flows by gravity through the screens and then through a 10 inch pipe to a 50,000 gallon below ground sump, located on the bank of the river. The low intake velocity further reduces any potential for impingement.

#### *“Capacity”*

Bethlehem Power utilizes two mechanical draft cooling towers for cooling condenser water. This recirculating system significantly reduces the amount of river water withdrawn compared to a once-through system.

### **6.0 Antidegradation**

The Draft Permit is being reissued with added sampling parameters and more stringent monitoring frequency's, limits and requirements. Therefore, EPA expects the State of New Hampshire to indicate that there will be no lowering of water quality and no loss of existing water uses and that no additional antidegradation review is warranted.

### **7.0 Essential Fish Habitat**

Under the 1996 Amendments (PL 104-267) to the Magnuson-Stevens Fishery Conservation and Management Act (16 U.S.C. § 1801 et seq.(1998)), EPA is required to consult with the National Marine Fishery Service (NMFS) if EPA's action or proposed actions that it funds, permits, or undertakes, “may adversely impact any essential fish habitat.” 16 U.S.C. § 1855(b). The Amendments broadly define “essential fish habitat” (EFH) as: “waters and substrate necessary to fish for spawning, breeding, feeding, or growth to maturity. 16 U.S.C. § 1802(10). Adversely impact means any impact which reduces the quality and/or quantity of EFH. 50 C.F.R. § 600.910(a). Adverse effects may include direct (e.g., contamination or physical disruption), indirect (e.g., loss of prey, reduction in species' fecundity), site-specific or habitat-wide impacts, including individual, cumulative, or synergistic consequences of actions. Id.

Essential fish habitat is only designated for fish species for which federal Fisheries Management Plans exist. 16 U.S.C. § 1855(b)(1)(A). EFH designations for New England were approved by the U.S. Department of Commerce on March 3, 1999.

The Connecticut River and its tributaries, including the Ammonoosuc River in the vicinity of Bethlehem, are designated essential fish habitat (EFH) for Atlantic salmon (*Salmo salar*). According to the New Hampshire Fish and Game Department, there is an extensive stocking program in the upper Ammonoosuc River. The reach of the Ammonoosuc River where the intake and discharge is located is a fish transient area, used by smolts during their spring migration to the sea via the Connecticut River.

EPA has concluded that the plant operating conditions and the limits and conditions contained in this draft permit minimize adverse effects to Atlantic salmon EFH for the following reasons:

- 1- the Facility has been operating closed-loop, with no discharge for 20 years;
- 2- the only permitted process waste discharge is during an emergency;
- 3- EPA and NHDES must be notified of a discharge and extensive monitoring is required;
- 4- cooling towers are used to cool condenser cooling water;
- 5- if there were a discharge, the effluent would be rapidly diluted so as to raise the ambient temperature by no more than 0.5 degrees Fahrenheit;
- 6- yearly WET testing is required for the drain/tempering tank contents to evaluate this effluent's ability to meet permitted limits and/or in stream NH-Standards; and
- 7- the location, design, construction, and capacity of the facility's cooling water intake structure(s) (CWIS) reflect the Best Technology Available (BTA) for minimizing adverse environmental impacts.

EPA believes the Draft Permit adequately protects Atlantic salmon EFH, and therefore additional mitigation is not warranted. If adverse impacts to EFH do occur as a result of this permit action, or if new information becomes available that changes the basis for this determination, then NMFS will be notified and consultation will be promptly initiated.

## **8.0 Monitoring Frequency**

Considering both that the Facility has not needed to discharge process water in 20 years of operation and that they will only discharge during an emergency situation, the sampling frequency for all parameters in the Draft Permit (outfall 001) has been changed to "each discharge event".

Storm water monitoring frequency has been changed from monthly to quarterly based on EPA's Storm Water Multi-Sector General Permit for Industrial Activities (70 Fed. Reg. 72116) using EPA's BPJ authority.

The effluent monitoring requirements have been established to yield data representative of the discharge under authority of Section 308(a) of the CWA as required by 40 C.F.R. 122.41 (j), 122.41 (j)(4), (5), 122.44 and 122.48.

## **9.0 State Certification Requirements**

EPA may not issue a permit unless the State Water Pollution Control Agency with jurisdiction over the receiving water(s) either certifies that the effluent limitations and/or conditions

contained in the permit are stringent enough to assure, among other things, that the discharge will not cause the receiving water to violate the State's Surface Water Quality Regulations (NH-Standards) or waives its right to certify as set forth in 40 CFR §124.53.

Upon public noticing of the Draft Permit, EPA is formally requesting that the State's certifying authority make a written determination concerning certification. The State will be deemed to have waived its right to certify unless certification is received within 60 days of receipt of this request.

The NHDES-WD is the certifying authority. EPA expects that the Draft Permit will be certified. Regulations governing state certification are set forth in 40 CFR §§124.53 and 124.55.

The State's certification should include the specific conditions necessary to assure compliance with applicable provisions of the CWA, Sections 208(e), 301, 302, 303, 306 and 307 and with appropriate requirements of State law. In addition, the State should provide a statement of the extent to which each condition of the Draft Permit can be made less stringent without violating the requirements of State law. Since certification is provided prior to permit issuance, failure to provide this statement for any condition waives the right to certify or object to any less stringent condition which may be established by EPA during the permit issuance process following public noticing as a result of information received during that noticing. If the State believes that any conditions more stringent than those contained in the Draft Permit are necessary to meet the requirements of either the CWA or State law, the State should include such conditions and, in each case, cite the CWA or State law reference upon which that condition is based. Failure to provide such a citation waives the right to certify as to that condition. The sludge conditions implementing section 405(d) of the CWA are not subject to the 401 certification requirements. Reviews and appeals of limitations and conditions attributable to State certification shall be made through the applicable procedures of the State and may not be made through the applicable procedures of 40 CFR Part 124.

## **10.0 General Conditions and Definitions**

The remaining general and special conditions of the permit are based on the NPDES regulations, 40 C.F.R. Parts 122 through 125, and consist primarily of management requirements common to all permits.

## **11.0 Comment Period, Hearing Requests, and Procedures for Final Decisions**

All persons, including applicants, who believe any condition of the Draft Permit is inappropriate must raise all issues and submit all available arguments and all supporting material for their arguments in full by the close of the public comment period, to Sharon Zaya, U.S. EPA, Office of Ecosystem Protection, Industrial Permits Branch (CIP), 1 Congress Street, Suite 1100, Boston, Massachusetts 02114-2023. Any person, prior to such date, may submit a request in writing for a public hearing to consider the Draft Permit to EPA and the State Agency. Such requests shall state the nature of the issues proposed to be raised in the hearing. A public meeting may be held if the criteria stated in 40 C.F.R. § 124.12 are satisfied. In reaching a final decision on the Draft

Permit, the EPA will respond to all significant comments and make these responses available to the public at EPA's Boston office.

Following the close of the comment period, and after any public hearings, if such hearings are held, the EPA will issue a Final Permit decision and forward a copy of the final decision to the applicant and each person who has submitted written comments or requested notice. Within 30 days following the notice of the Final Permit decision, any interested person may submit a petition for review of the permit to EPA's Environmental Appeals Board consistent with 40 C.F.R. § 124.19.

## **12.0 EPA Contact**

Additional information concerning the Draft Permit may be obtained between the hours of 9:00 A.M. and 5:00 P.M., Monday through Friday, excluding holidays from:

**Ms. Sharon Zaya, Environmental Engineer  
U.S. Environmental Protection Agency  
Office of Ecosystem Protection  
1 Congress Street, Suite 1100 (CIP)  
Boston, Massachusetts 02114-2023  
Telephone: (617) 918-1995 / FAX No.: (617) 918-0995**

August 4, 2006

**Date:**

**Linda M. Murphy, Director  
Office of Ecosystem Protection  
U.S. Environmental Protection Agency**