

NPDES PERMIT MODIFICATION

issued to

Pfizer Inc.
445 Eastern Point Road
Groton, Connecticut 06340

Location Address:

445 Eastern Point Road
Groton, Connecticut 06340

Facility ID: 059-003

Permit ID: CT0000957

Receiving Stream: Thames River

Permit Expires: July 28, 2013

This permit modification is issued in accordance with section 22a-430 of Chapter 446k, Connecticut General Statutes ("CGS"), section 22a-430-4(p)(5) of the Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and Section 402(b) of the Clean Water Act, as amended 33 USC 1251, et. seq., and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut to administer a N.P.D.E.S. permit program.

The Commissioner of Environmental Protection ("the Commissioner") has made a final determination on this permit modification and found that modification of the existing system or installation of a new system will protect the waters of the state from pollution. The Commissioner's decision is based on Application No. 200900120 for a permit modification received on January 23, 2009 and the administrative record established in the processing of that application.

Pfizer Inc. ("Permittee") shall comply with all conditions of Permit No. CT0000957 issued on July 29, 2008 with the following modification:

With respect to DSN 009, the average monthly flow limit is increased from 75,000 gallons/day to 300,000 gallons/day and the maximum daily flow limit is increased from 75,000 gallons/day to 600,000 gallons/day. The revised Table B is attached. Revisions are in bold.

The Commissioner reserves the right to make appropriate revisions to the permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions that may be authorized under the Clean Water Act or the Connecticut General Statutes or regulations adopted thereunder, as amended. The permit as modified under this paragraph may also contain any other requirements of the Clean Water Act or Connecticut General Statutes or regulations adopted thereunder which are then applicable.

All other terms and conditions of Permit No. CT0000957 issued on July 29, 2008 shall continue in full force and effect.

This modification is hereby issued on April 16, 2009.

/s/ GINA MCCARTHY
GINA MCCARTHY, Commissioner

GM/CMG
Permit No. CT0000957
Sent RRR

Table BDischarge Serial Number: **009-1**Monitoring Location: **1**Wastewater Description: **Intake structure screen backwash**Monitoring Location Description: **Traveling screen outfall pipe**

PARAMETER	UNITS	FLOW/TIME-BASED MONITORING				INSTANTANEOUS MONITORING			Minimum Level Test
		Average Monthly Limit	Maximum Daily Limit	Sample//Reporting Frequency ²	Sample Type or Measurement to be reported	Instantaneous limit or required range	Sample//Reporting Frequency ²	Sample Type or measurement to be reported	
Flow, Average and Maximum ¹	gpd	300,000	600,000	Daily//Monthly	Daily flow	NA	NR	NA	
Suspended Solids, Total	mg/l	NA	NA	NR	NA	---	Annual	Grab	

Table B Footnotes:**Footnotes:**

¹ For this parameter, the Permittee shall maintain at the facility a record of the total flow for each day of discharge and shall report the Average Daily Flow and the Maximum Daily Flow for each month.

² The first entry in this column is the 'Sample Frequency'. If a 'Reporting Frequency' does not follow this entry and the 'Sample Frequency' is more frequent than monthly then the 'Reporting Frequency' is monthly. If the 'Sample frequency' is specified as monthly, or less frequent, then the 'Reporting Frequency' is the same as the 'Sample Frequency'.